

## First results of the bundle test QUENCH-19 with FeCrAl claddings.

*J. Stuckert, M. Große, J. Laier, J. Moch, U. Peters, U. Stegmaier, M. Steinbrück (KIT),  
K. Terrani (ORNL)*

The QUENCH-19 bundle experiment with FeCrAl(Y) claddings and 4 FeCrAl(Y) spacer grids as well as 8 KANTHAL APM corner rods and KANTHAL APM shroud was conducted at KIT on 29<sup>th</sup> August 2018. This was performed in cooperation with the Oakridge National Laboratory (ORNL).

The test objective was the comparison of FeCrAl(Y) and ZIRLO<sup>TM</sup> claddings under similar electrical power and gas flow conditions. In common with the previous QUENCH-15 experiment, the bundle was heated by a series of stepwise increases of electrical power from room temperature to a maximum of  $\approx 600$  °C in an atmosphere of flowing argon (3.45 g/s) and superheated steam (3.6 g/s). The bundle was stabilised at this temperature, the electrical power being  $\approx 4$  kW. During this time the operation of the various systems was checked.

In a first transient, the electrical power was controlled with the same electrical power history as the QUENCH-15 test. As a result, the bundle was heated to peak cladding temperature of about 1000 °C reached at about 4000 s. It showed a slowed bundle heating than for the QUENCH-15 bundle (1200 °C reached at about 3000 s). In this test phase about 0.3 g of hydrogen were produced (QUENCH-15: 23.3 g).

In the following phase, the power was increased continuously to 18.12 kW (corresponds to maximal power of the QUENCH-15 test). After reaching of this value the power was kept constant during about 2000 s. At the end of this phase the maximal peak cladding temperature of  $T_{\text{pct}} \approx 1500$  °C was reached. Much lower heating rate in comparison to QUENCH-15 was measured. Exceeding  $T_{\text{pct}} \approx 1400$  °C sharp increase of hydrogen release rate was observed.

Then reflood was initiated at  $\approx 9100$  s, connected with switching the argon injection to the top of the bundle, first rapidly filling the lower plenum of the test section with 4 kg of water, and continuing by injecting  $\approx 48$  g/s of water. The electrical power was reduced to 4.1 kW during the reflood.

A temperature excursion was not observed. The temperatures at all elevations decrease immediately after water injection. The total hydrogen release during the whole test was 9.2 g compared to 47.6 g in the QUENCH-15 test with much shorter high electrical power phase.


The videoscope observation of the bundle at the positions of the withdrawn corner rods showed the damage of several claddings at the bundle elevations between 850 and 1000 mm. The claddings were failed either due to interaction with melted thermocouples (mostly) or by spalling of small annular cladding parts.

# First results of the bundle test QUENCH-19 with FeCrAl claddings

J. Stuckert, M. Große, J. Laier, J. Moch, U. Peters, U. Stegmaier, M. Steinbrück (KIT),  
K. Terrani (ORNL)

*QWS-24, Karlsruhe 2018*

Institute for Applied Materials; Program NUSAFE



# Chemical compositions and oxidation in steam of FeCrAl alloys

Material	Fe	Cr	Al	Y	Si	Mn	C	comment
Conventional Kanthal APM	Balance	22	5.8	-	0.7	0.4	0.08	used for shroud and corner rods in QUENCH-19
<b>FeCrAl(Y) alloy B136Y3 (ORNL)</b>	<b>Balance</b>	<b>13*</b>	<b>6.2</b>	<b>0.03</b>			<b>0.01</b>	used for <b>claddings</b> of heated rods in QUENCH-19


\*reduced in comparison to Kanthal to decrease the hardening under irradiation

$$\Delta m/S = K_m \sqrt{t}$$

$$K_m(T) = K_0 \exp\left(-\frac{E_0}{RT}\right)$$

Material	$E_0$ (J/mol)	$K_0$ (g/cm <sup>2</sup> s <sup>0.5</sup> )
Zry-4*	87144	0.724
APMT**	172000	2.8

Oxidation kinetics in steam




Oxidation in steam at 1200 °C in comparison with Zry-4



\*G. Schanz, FZKA 6827,  
<https://publikationen.bibliothek.kit.edu/270054544/3814367>

\*\*K. Field et al., ORNL/SPR-2018/905,  
<https://info.ornl.gov/sites/publications/Files/Pub114121.pdf>

# Cladding tubes B136Y3 (by Century Tubes Inc./ORNL)




- Made by **cold-drawing**
- OD: **9.52** mm
- WT: **382  $\mu\text{m} \pm 12 \mu\text{m}$**
- Grain size:  **$\sim 80\text{-}100 \mu\text{m}$**




Hardness:  $254 \pm 7$  HV

# Cross sections of fuel rod simulators

(in comparison to reference test QUENCH-15 with ZIRLO claddings)




QUENCH-15 (ZIRLO cladding with OD=9.5 mm, WT=572  $\mu\text{m}$ )



QUENCH-19 (FeCrAl(Y) cladding with OD=9.52 mm, WT=381  $\mu\text{m}$ )


	heat capacity	heat conductivity	thermal expansion	melting point
FeCrAl (Kanthal)	$\approx 460 \text{ J}/(\text{kg}\cdot\text{K})$	$\approx 11 \text{ W}/(\text{m}\cdot\text{K})$	$14\cdot 10^{-6} /\text{K}$	$\approx 1790 \text{ K}$
ZIRLO	$\approx 270 \text{ J}/(\text{kg}\cdot\text{K})$	$\approx 23 \text{ W}/(\text{m}\cdot\text{K})$	$5.7\cdot 10^{-6} /\text{K}$	$\approx 2030 \text{ K}$

# QUENCH test section






# Composition of test bundle QUENCH-19




cross section  
(arrangement the same as for QUENCH-15)



test bundle (length 2m)





**ORNL FeCrAl(Y) spacer grids:**  
height 22 mm,  
sheet thickness 0.5 mm



**AREVA Inconel spacer grid:**  
height 45 mm,  
sheet thickness 0.5 mm

# QUENCH-19 bundle instrumentation (thermocouples at cladding surface)




TFS 12/15  
W/Re TC sheathed by steel  
at 1150 mm, rod #12

TFS 14/14  
W/Re TC sheathed by steel  
at 1050 mm, rod #14

TFS 15/13  
W/Re TC sheathed by steel  
at 950 mm, rod #15




# Test performance: comparison of QUENCH-15 (ZIRLO) and -19 (FeCrAl)




Energy release during Q15 pre-oxidation (i.e. until 6000 s):
   
 electrical  $E_e = 63.7\text{ MJ}$ 
  
 chemical  $E_{ch} = 3.5\text{ MJ}$ 
  
 $\Rightarrow E_{ch} \ll E_e$

# Parameters of gas atmosphere at bundle inlet and outlet



**QUENCH-15:**


inlet gas (steam + Ar)  $T_g \approx 720$  K;  
 steam flow rate  $3.2 < F_s < 3.4$  g/s;  
 Ar flow rate  $F_{Ar} = 3.5$  g/s



**QUENCH-19:**

inlet gas (steam + Ar)  $640 < T_g < 700$  K;  
 steam flow rate  $F_s \approx 3.8$  g/s;  
 Ar flow rate  $F_{Ar} = 3.5$  g/s



(Q15  $\approx$  Q19)  
**similar inlet and outlet**




TCI thermocouple at cooling jacket  
thermal insulation

# Boundary conditions (temperatures behind heat insulation)


(Q15 ≠ Q19)  
porous heat insulation filled with dry Ar in Q15 and with humid Ar in Q19 (leakage of steam into insulation)



# Readings of thermocouples at 850 mm (hottest elevation for QUENCH-19)




**QUENCH-15:**  
strong T escalation  
during transient




**QUENCH-19:** 1) no temperature escalation during extended transition;  
2) special features of test (the reason is not yet clarified):  
a) lower temperatures ; b) larger radial  $\nabla T$ .

# Axial temperature profiles at shroud




at the beginning of transient




at the onset of reflow

# Quench stage: evaporation of injected water, collapsed water front progress




QUENCH-15: water rise duration 330 s




QUENCH-19: water rise duration 270 s




# QUENCH-19: wetting of thermocouples by two-phase fluid



# Hydrogen release




QUENCH-15: max rate 1830 mg/s; totally 47.6 g H<sub>2</sub>




QUENCH-19: max rate 280 mg/s; totally 9.2 g H<sub>2</sub>



# QUENCH-19: videoscope observations of damaged (partly melted) claddings at upper part of heated zone




rods 19, 8, 7  
(front look at 1000 mm)




rods 19, 8, 7  
(side look at 1000 mm)



rods 5, 17, 16, 15, 24  
(front look at 950 mm)



rods 16, 15, 24  
(side look at 950 mm)







# Videoscope observations of claddings at hottest positions of bundles QUENCH-15 (ZIRLO) and -19 (FeCrAl)

**Q15:** circumferential cladding cracks at hottest elevation of 950 mm



thick oxide


partially molten metal captured between pellet and oxide




molten claddings of rods 13 and 12 (Q19 front look at 1000 mm)



900 mm  
pellet



850 mm



800 mm


Q19 side look: molten claddings of rods 14 and 13



# QUENCH-19 bundle extracting



Bundle inside cooling jacket



Bundle surrounded by porous  $ZrO_2$  heat insulation




Bundle surrounded by FeCrAl shroud (KANTHAL APM)



Bundle



# QUENCH-19 bundle at elevations between 900 and 1100 mm: cladding damages by molten thermocouple steel (AISI 304) sheaths




Positions of TC (●) at elevations 13 (950 mm) and 14 (1050 mm)

- the melting range of 304 steel is 1400...1450°C
- the melting range of FeCrAl alloys is 1500...1520°C



0°: TFS 9/13 and 19/14



90°: TFS 3/13, 21/13, 9/13



180°: TFS 15/13 and 14/14



270°: TFS 1/13, 15/13



## Summary

- The QUENCH-19 test with bundle containing 24 heated rods with FeCrAl(Y) cladding and 4 FeCrAl(Y) spacer grids as well as 8 KANTHAL APM corner rods and KANTHAL APM shroud was performed at KIT on August 29, 2018 with similar electrical power history as reference test QUENCH-15 (ZIRLO™ claddings).
- Four test stages of QUENCH-19:
  - 1) pre-oxidation during about 6000 s (similar to QUENCH-15),
  - 2) transient during about 1130 s (similar to QUENCH-15),
  - 3) extended period with constant electrical power of 18.32 kW during 1970 s (to extend the temperature increase stage),
  - 4) test termination by water flooding with rate of 48 g/s (similar to QUENCH-15).
- The peak cladding temperatures during the pre-oxidation stage were about 200 K lower in comparison to QUENCH-15. The radial temperature gradient was noticeable larger in comparison to QUENCH-15. The reason of these test differences are not yet completely clarified.

## Summary (cont.)

- Much lower heating rate in comparison to QUENCH-15 was measured. A temperature of about 1150°C was reached at the time point as a local melting of QUENCH-15 claddings occurred. No temperature escalation was observed during the extended transient. Maximum cladding temperature measured before reflood was about 1460 °C.
- The coping time was about 3200 s ( $\approx$  1200 s for QUENCH-15).
- Sharp increase of hydrogen release rate was observed about 800 s before reflood. Probable trigger of this event could be the melting of steel thermocouple claddings. The maximum hydrogen release rate reached before reflood was 280 mg/s (1830 mg/s for QUENCH-15). Total hydrogen production 9.2 g (47.6 g for QUENCH-15).
- Many claddings were damaged at elevations between 850 and 1000 mm: 1) by interaction with melted thermocouples or 2) parts of claddings were spalled (probably due to thermal expansion followed by quench shrinkage).

## Acknowledgment

The QUENCH-19 experiment was supported by the KIT program NUSAFE and partly sponsored by ORNL. The cladding materials and thermocouples were provided by ORNL. IKET/KIT colleagues were involved into bundle dismounting.

The authors would like to thank all colleagues involved in the pre-test calculations (GRS, ORNL, PSI).

*Thank you for your attention*

<http://www.iam.kit.edu/awp/666.php>

<http://quench.forschung.kit.edu/>