KERNTECHNIK 2022

Impact of Realistic Fuel Inventories on the Radiological Consequences of a Severe Accident Scenario in a Generic KONVOI Plant by means of the ASTEC Code

F. Gabrielli¹, A. Stakhanova¹, V.-H. Sanchez-Espinoza¹, E.-M. Pauli², A. Hoefer², H. Feldmann²

¹ Karlsruhe Institute of Technology
 ² Framatome GmbH



Motivation

- Evaluation of source term (ST) and fission product (FP) dispersion during a severe accident (SA) in NPPs is one of the major objectives of the nuclear reactor safety research program at KIT.
- Main goal → supporting the emergency and management teams during such abnormal events → a reliable evaluation of the source term is mandatory.
- <u>Reference</u> codes to be employed for assessing a database of STs during SA scenarios for different NPPs → Realistic fuel inventories, ST evaluation (ASTEC), U&S and ST prediction (FSTC+MOCABA algorithm), FP dispersion (JRODOS).
- Activities triggered by the KIT/Framatome joint participation to the EU H2020 MUSA and German WAME projects.
- The amount of FPs initially loaded in the core is one of the main parameters affecting the in-vessel and ex-vessel accident progression as well as the ST.
- Large mass of FPs loaded → larger decay power → larger in-vessel degradation → larger FP release from the vessel to the containment and then to the environment.

KIT Strategy for Source Term Analyses (1/2)



- European reference Accident Source Term Evaluation Code (ASTEC), developed by IRSN and co-developed by KIT since 2020 → SA scenario analyses and ST evaluations.
- ASTEC results employed to analyze the FP dispersion in the environment by means of the Java based Real-Time On-Line Decision Support system (JRODOS, KIT).



KIT Strategy for Source Term Analyses (2/2)

- Development of in-house Fast Source Term Code (FSTC) → Uncertainty Quantification (UQ) of the ASTEC ST results + training database for
- Source Term prediction → Monte Carlo-based Bayesian inference model (MOCABA algorithm from Framatome GmbH embedded)



ASTEC Model of a Generic KONVOI NPP

- Significant improvement and extension of the original generic ASTEC input deck available in the code release.
- All the calculation modules activated → analysis of the SA scenario from the initiation up to the basemat rupture.
- SOPHAEROS module for element- and isotope-wise FP transport and behavior from the core to the environment.
- Heat exchange (convection, conduction, and radiation) and oxidation models.
- Main models governing the in-vessel and ex-vessel (relocation to the cavity after the lower head vessel rupture+MCCI) behaviour of the molten material.



Plant rooms (11 volumes) Operating rooms (9 volumes, white) Annulus (3 volumes, light yellow)

Fuel Inventory

- Library of fuel inventories for an equilibrium cycle with 328 effective full power days computed.
- Core is loaded with 193 Fuel Assemblies (48 U FAs, 6 batches; 81 U-Gd FAs, 6 batches; 64 MOX FAs, 4 batches).
- Depletion calculations, the ORIGEN-ARP tool has been used, employing the ORIGEN reactor libraries for an 18x18 FA design embedded in SCALE 6.2.3.
- Two initial fuel inventories employed:
 - Beginning of Cycle (BOC)
 - End of Cycle (EOC)

Element	Volatility	Activity @BOC (Bq)	Activity @EOC (Bq)
Xe	Noble Gas	1.502E+19	1.678E+19
Kr	Noble Gas	4.323E+18	4.576E+18
I	Very Volatile	4.311E+19	4.726E+19
Cs	Very Volatile	3.718E+19	7.702E+20
Те	Moderately Volatile	2.258E+19	2.547E+19
Sr	Moderately Volatile	1.104E+19	1.393E+19
Ва	Moderately Volatile	5.492E+20	6.913E+20
Ru	Less Volatile	1.298E+19	1.541E+19
La	Less Volatile	2.236E+19	2.465E+19
Ce	Less Volatile	1.662E+19	1.895E+19

Scenarios

MBLOCA (12") and SBLOCA (2")

- 1. Medium (12") and small (2") break of the cold leg at t=0 s
- 2. Reactor scram, if the primary pressure < 132 bar or containment overpressure > 30 mbar
- 3. Admission to turbine and closure of the main feed water pumps into the steam generator;
- 4. Emergency Core Cooling System (ECCS) activated if two of the following three conditions are fulfilled containment overpressure >30 mbar, RCS pressure <110 bar or pressurizer liquid level< 2.30 m
- 5. Main Coolant Pumps are coasted down and the pressure regulation in the pressurizer is switched off
- 6. Activation of the Emergency Feed Water System (EFWS) when the liquid level of one SG falls <4.50 m
- 7. HPIS (SBLOCA) and LPIS (MBLOCA) activated (T_gas in the primary > 650 °C) up to the tanks are empty \rightarrow severe accident
- 8. Activation of the Extra Borating System when the pressurizer water level <2.30 m
- 9. When the horizontal erosion reaches 4.4 m radius, water from SUMPF flows into the cavity and the spalt

MBLOCA (12") and SBLOCA (2") + Station Black Out (SBO)

- AC loss @t=0 s
- As above but no 4 8 actions (namely only accumulator discharge available)

MBLOCA Scenarios: Quicklook

	BOC		EOC	
Phenomenon	MBLOCA	MBLOCA+SBO	MBLOCA	MBLOCA+SBO
FPs Release (s)	644	644	434	444
20/50 tons relocated to the LP (h)	4.6	0.5	-/-	0.2/0.4
70/90 tons relocated to the LP (h)	4.6	0.8/0.9	-/-	0.5/0.6
LPV Failure (h)	5.7	1.6	1.5	0.8
Basemate Rupt. (h)	93.2	7.8	4.3	5.0
Total H2 In-vessel/Containm. (kg)	938/1820	731/2124	638/1987	825/2270
Final Aerosols in Cont. (kg)	184	135	100	145

- Significant effect of the composition of the fuel inventory on the accident progression.
- Significant effect of scenarios on the mass of aerosols in the containment.

SBLOCA Scenarios: Quicklook

	BOC		EOC	
Phenomenon	SBLOCA	SBLOCA+SBO	SBLOCA	SBLOCA+SBO
FPs Release (s)	11056	1133	10619	1426
20/50 tons relocated to the LP (h)	6.6	0.5/0.7	6.0	0.5
70/90 tons relocated to the LP (h)	6.6	-/-	6.0	-/-
LPV Failure (h)	8.5	1.3	6.8	1.0
Basemate Rupt. (h)	102.2	48.5	77.8	6.0
Total H2 In-vessel/Containm. (kg)	865/2241	741/2790	862/2095	546/1652
Final Aerosols in Cont. (kg)	1159	144	1032	544

- Significant effect of the composition of the fuel inventory on the accident progression.
- By comparison with MBLOCA results, huge effect of scenarios on the mass of aerosols in the containment.

Containment and Annulus Pressure



Containment

- Higher pressures in EOC conditions.
- Long term higher pressures w/o SBO.
- In SBLOCA (EOC), pressure containment up to about 9 bar
- No containment rupture modeled (WAME project).

Annulus

 Pressure in the annulus decreases due to the release to the environment

Total activity in the Plant



- MBLOCA scenarios \rightarrow about 1% of the initial activity of the fuel inventory transported to the containment.
- SBLOCA scenarios more severe
 - SBLOCA+SBO (@EOC) → about 3% of the initial activity in the vessel transported to the containment in the long term.
 - SBLOCA @EOC → max. activity release to the containment about 15-20% (no SBO) and 70% (+SBO) of the initial activity.
 - The release to the containment is almost twice as high for a fuel inventory at EOC as for a fuel inventory at BOC.

Xe Mass in Containment and Environment



 Noble gases almost completely transported to the containment.

- Largest release at higher fuel burn-up in SBLOCA scenarios.
- (SBLOCAs and MBLOCA+SBO) Release with fuel at EOC is about twice than at BOC

Xe-wise isotopes in the Containment and Environment



300000

250000

50000

100000

150000

Time(s)

200000



SBLOCA results shown

- Element- and isotope wise results stored in the database:
 - Dose rates in Containment
 and Annulus
 - Activity in the containment, annulus, and environment

I Mass in the containment: Total and Aerosols





- Release strongly dependent on:
 - Scenario
 - Initial core inventory
- SBLOCA+SBO (@EOC)
- Total: Up to 75% of the initial inventory
- Aerosols: up to 60% of the initial inventory

Cs Mass in the containment: Total and Aerosols





- Release strongly dependent on:
 - Scenario
 - Initial core inventory
- SBLOCA+SBO (@EOC)
 - Total: Up to 55% of the initial inventory
 - Aerosols: up to 20% of the initial inventory

Conclusion and Outlook

- Platform of reference codes (ASTEC, FSTC, JRODOS) for the analysis of the radiological impact of severe accidents assessed at KIT, triggered by the KIT/Framatome joint participation to EU and National projects.
- ASTEC results for selected SA scenarios in a generic KONVOI NPP showed large effect of the initial amount of FPs in the core both on the accident progression and on the ST.
- Evaluation of realistic fuel inventories and employment in integral codes modelling is mandatory to perform reliable evaluations ST evaluations → final goal: supporting the emergency and decision teams during severe accidents.
- Source term databases from ASTEC results + UQ currently under assessment for generic KONVOI and VVER-1000 NPPs.
- Rather solid basis of understanding in view of the planned ASTEC analyses at KIT of SA scenarios in generic Small Modular Reactors (SMRs).
 - Evaluation of the fuel inventories challenging because of the rather heterogeneous core arrangements in these systems → insights from the EU H2020 McSAFER project
 - Employment of innovative materials, e.g. Accident Tolerant Fuels (ATFs)