



Nuclear Reactor Safety (LWRs) in the 21st Century

G. Kessler




- Radioactivity release
at normal operation
- Accidental Risk



 Atmospheric diffusion transfers

 Hydrological/hydrogeological diffusion transfers


 Marine diffusion transfers



Total : $\approx 10^{10}$ Ci oder $\approx 3 \cdot 10^{20}$ Bq

Isotope	$T_{1/2}$	Ci	Bq
H-3	12,4 a	$4 \cdot 10^4$	$1 \cdot 10^{15}$
Kr-85	10,7 a	$6 \cdot 10^5$	$2 \cdot 10^{16}$
I-129	$1,6 \cdot 10^7$ a	3	$1 \cdot 10^{11}$
I-131	8 d	$8 \cdot 10^7$	$3 \cdot 10^{18}$
I-133	21 h	$2 \cdot 10^8$	$6 \cdot 10^{18}$
Cs-134	2,1 a	$1 \cdot 10^7$	$4 \cdot 10^{17}$
Cs-137	30 a	$1 \cdot 10^7$	$3 \cdot 10^{17}$

Radioactivity-inventory at reactor core
(1300 MWe, 40,000 MWd/t)




Safety Design Principles (LWRs)


- negative doppler coefficient
- negative coolant void coefficient
- safe control and shut down by neutron poison rods or borated water
- leak before rupture criterion
- safety valves
- emergency power supply (diesel generators, gas turbines batteries)
- emergency cooling systems
- emergency feedwater systems
- principles of redundancy and diversity
- aerosol filters
- barrier system against radioactivity release
- outer containment barrier

Probabilistic Risk Analysis

WASH-1400 (1982)

FREQUENCY (EVENTS/YEAR)





**INITIATING
EVENT:**

**PIPE
BREAK**

**ELECTRIC
POWER**


ECCS


**FISSION
PRODUCT
REMOVAL**


**CONTAINMENT
INTEGRITY**

**RADIOACTIVE
RELEASE**

**SEQUENCE
FREQUENCY**








	Sheltering Area – 0.005Sv	4 Hours Radiation Release
	Evacuation Area – 0.1Sv	25% – Noble Gases
	Evacuation Area – 0.3Sv	5% – Aerosols
	Evacuation Area – 0.5Sv	Wind Velocities – 2.5m/s

RODOS Calculations

Action	Reference dose	Lower Reference value [mSv]	Upper Reference value [mSv]
Remain in house sheltering	Effective dose through inhalation and external radiation	5	50
	Lung and each individual organ	50	250
Evacuation	Effective dose through inhalation and external radiation	100	500
	Lung and individual organ	300	1500
Relocation	Effective dose through inhalation and external radiation	50	250
Food ban	Effective equivalent dose by ingestion over 1 year	5	50

Reference dose values for initiation of protection and countermeasures



Amendment of GERMAN ATOMIC LAW (1994)

Future Fission reactors can only obtain a license for construction and operation , if they are built such that also ...

severe accidents (core melt) do not lead to catastrophes or protection measures (evacuation, relocation) of the population outside the nuclear plant.

Radiological Objectives


In case of severe accidents: only very limited protection measures



- limited sheltering only**
- no evacuation outside the immediate vicinity of the plant**
- no permanent relocation**
- no long-term restrictions in food consumption**

Largest radioactivity releases
after containment failure
caused by

- steam explosion
- large hydrogen detonation
- high pressure core melt through
- containment bypass (pipes)

(These phenomena were assumed in
Probabilistic Risk Analysis
to lead to containment failures)





Result Analysis

High pressure melt through

- present structures around reactor pressure vessel hold 100 bar internal pressure
- structures can be reinforced to hold 155 bar internal pressure
- 2 high pressure safety valves can be opened within ½ h


(TMI-2 core did not melt through)

(High pressure coolant pipe could fail because of high steam temperatures)

BERDA

Behaviour of the Reactor Pressure Vessel Head during a Postulated Steam Explosion


Investigation Program




If $E_{expl} \approx E_{plate}$, then upper head integrity is confirmed


BERDA Slug Impact Scenarios BERDA I

without upper internal structures





including upper internal structures








COM3D verification (1)


- Large scale experiments performed in RUT facility near Moscow (FZK, CEA, partly NRC), H₂-air, H₂-air-steam
 - Total length 62 m
 - Total volume 480 m³
 - First channel with obstacles
 - Second part without obstacles








rut_ddt




H₂, H₂O clouds and temperature plume GKN at 5932s

deformation factor 5.0



deformation factor 1.0









Figure 6.4-1: The main components of the EPR core catcher



Plant Layout
General Arrangement of Nuclear Island



Effective dose due to inhalation and direct radiation from the cloud

