



Juni 1973

KFK 1763

Institut für Experimentelle Kernphysik

Economic Studies of Superconducting Magnets and their Refrigeration for the CERN II North Experimental Area

M. A. Green



Als Manuskript vervielfältigt ·

Für diesen Bericht behalten wir uns alle Rechte vor

GESELLSCHAFT FÜR KERNFORSCHUNG M.B.H. KARLSRUHE

KERNFORSCHUNGSZENTRUM KARLSRUHE

KFK 1763

Institut für Experimentelle Kernphysik

ECONOMIC STUDIES OF SUPERCONDUCTING MAGNETS AND THEIR REFRIGERATION FOR THE CERN II NORTH EXPERIMENTAL AREA

Michael A. Green

Gesellschaft für Kernforschung m.b.H. Karlsruhe

.

Abstract

Experimental areas for large proton-synchrotrons may be designed by using either normally conducting or superconducting magnets. The superconducting alternative is studied for both, primary and secondary beams in the proposed North Experimental Area of the CERN 300-GeV synchrotron. The requirements for helium refrigeration systems are specified in both cases. The refrigeration for the secondary beams may be quite different from the one used in the beam line magnets. Cost estimates are given for the refrigeration system and the magnets themselves in dependence on field level and magnet aperture.

Ökonomie supraleitender Magnete und ihres Kühlsystems für die Nord-Experimentierfläche des CERN II-Beschleunigers

Zusammenfassung

Experimentierflächen für große Protonen-Synchrotrone können alternativ mit normalleitenden oder supraleitenden Magneten zur Strahlführung ausgestattet werden. Für die vorgesehene nördliche Experimentierfläche am 300 GeV-Synchrotron in CERN wird die supraleitende Alternative für den primären Protonenstrahl und sekundäre Strahlen untersucht. Die Anforderungen an die Kältesysteme werden in beiden Fällen spezifiziert; dabei zeigt sich, daß die Eigenschaften der Kühlung in Sekundärstrahlen erheblich von denen des Primärstrahls abweichen können. Kostenabschätzungen für die Kühlung und die Magnete selbst werden mit der Feldstärke und der Magnetapertur als Parameter durchgeführt.

eingreicht am: 15.5.73

·

Refrigeration for Superconducting Magnets in the CERN II Experimental Area

by Michael A. Green 5 May 1972

This report discusses the refrigeration of superconducting magnets in the north experimental area of CERN II. This report describes the equipment necessary to cooldown, and keep cold superconducting dipoles and quadrupoles operating in various primary and secondary beams. A primary beam is a proton beam from the machine which has not been targeted. The definition of a primary beam is further restricted to those proton beams which are in tunnels located between the SPS ejection system and the target stations. The secondary beam is defined as those beams which have been targeted (usually not protons) and lie in the experimental area between the target and the last piece of experimental detection equipment. The refrigeration system for the superconducting magnets in the secondary beams may be quite different from the refrigeration used in the beam line magnets.

1. Other studies on refrigeration for superconducting magnets

A number of studies have been made on refrigeration systems for superconducting magnets in accelerator experimental areas. The National Bureau of Standards study of 1966 pointed out a number of difficulties which could occur in a system of refrigeration involving a large number of magnets. This report studied bulk liquid transfer systems, systems using a large central refrigerator, and systems using individual refrigerators. The report presented a great deal of important data which is still useful today.

A 1968 study by LRL Berkeley and 500 Incorporated^{2,3} (now Crogenic Technology Incorporated) was based on three experimental areas which had 10 different beams. The beam lines came from LRL⁴ and CERN⁵ experimental area studies in 1966 and 1967. The LRL-500 Incorporated report only considered refrigeration of superconducting magnets in secondary beams. That report came to the conclusion that a system which consisted of a number of small refrigerators supplied from a central compressor station was best from a technical and economic standpoint. This study has one major flaw; the refrigeration required for a pair of magnet leads was improperly estimated.

A 1969 paper by Strobridge⁶ further updated cost estimates for cryogenic refrigeration plants. In 1970, Green⁷ showed that the small unit concept was still valid for a spread out secondary beam system. This paper corrected the estimate given for electrical lead refrigeration which was given in the LRL-500 Incorporated paper. The paper also related some of the difficulties that can be encountered in the operation of a system of small refrigerators. A really cheap flexible transfer line for refrigeration was presented also.

The author is also aware of a study that was made either at CERN or by the French. This report suggested that periodic liquid transfers could be made through long transfer lines from a bulk liquid storage system and liquifier to various magnets. The gas was to be recovered cold from the magnets and used in the liquifier. The author sees little difference between this system and a central refrigerator.

Previous studies have shown that the operation of a superconducting magnet on a closed cycle refrigerator is quite different from the operation of the same magnet on transferred liquid⁶. The use of direct closed cycle refrigeration has an important effect on cryostat design ⁹ and the design of the magnet itself. The density of magnets in a given area has an important effect on the type of cryogenics system that should be employed. In general, an area that is densely packed with magnets, whose position is considered permanent, will use a few large refrigerators to supply cooling. However, if the magnets are widely spaced and the magnets may be moved, then small refrigerators are attractive. These refrigerators may be connected to central helium compression system for improved reliability.

- 2 -

2. Refrigeration for the Primary Beam Transport System

In the absence of definitive data, certain assumptions have been made:

- 1) The primary beam transport system is assumed to transport beams which have an energy of 1000 GeV or less.
- 2) The primary beam transport system consists of a beam dump splitter magnet, bending magnets to transport the beam to the earth's surface (two sets, one to bend the beam up and a second to bend the beam level), and a beam splitting system which supplies primary beam to three target stations (see figure 1).
- 3) Most of the transport quadrupoles are assumed to be conventional because adequate space is available for conventional quadrupoles.
- 4) The dipole magnets are assumed to be superconducting when the primary beam energy is 1000 GeV. Only the beam switch yard dipole magnets are superconducting when the maximum primary beam energy is 400 GeV.

The preceding assumptions may not be valid, though they provide a basis for making a determination of the type of refrigeration system needed to supply superconducting magnets which may lie between the north area extraction points and the targets.

The vertical bends in the tunnel from the extraction point to the target will be determined by the use of conventional (1.8T) magnets at 400 GeV. Therefore, when a conversion of the machine to 1000 GeV is made, superconducting (4.5T) magnets will be used for the vertical bends. In the absence of other data, an angle of 85 mrad has been assumed for each of the vertical bends. This is the equivalent of 10 main ring magnets or their superconducting replacements. These magnets are assumed to be pulsable at the same rate as the superconducting ring.

At 1000 GeV, the refigeration for the first vertical bend can be supplied by the refrigeration system used to feed the superconducting synchrotron. The additional refrigeration required, including transfer lines, is about 400 to 500 watts at 4.5°K. The

- 3 -

second vertical bend located about 450 m downstream from the first vertical bend has about the same refrigeration requirement (without long transfer lines). The refrigeration of the second vertical bend comes from the same source as the refrigeration for the primary beam switch yard. The beam switch yard is assumed to switch the beam to three different targets. The system is assumed to consist of 14 dipoles and 12 quadrupoles; pulsibility, while not required, is desirable. Two sets of leads are required for the dipole magnets and three sets of leads are required for the quadrupole magnets. The total estimated refrigeration requirement for the beam switch yard area is about 650 watts. This refrigeration is needed in a length of about 60 meters. The second vertical bend is located within 100 meters of the switch yard. Therefore, it is reasonable to put the switch yard and the second vertical bend on the single refrigerator with a capacity of about 1100 watts. Α transfer line from the first vertical bend to the second vertical bend would require an additional 300 to 400 watts of cooling plus the transfer line itself. As a result, one gains economically by using a separate refrigerator for cooling the switch yard and the second vertical bend.

The 400 GeV machine may have superconducting magnets in the primary beam line. Because of the additional problems encountered when one tries to refrigerate the first vertical bend, both vertical bends are assumed to consist conventional magnets. The beam switch yard is assumed to be superconducting; the number of dipoles in the switch yard is reduced to 6, the number of quadrupoles remains at 12. The estimated refrigeration for the 400 GeV beam switch yard is about 500 watts, which would be supplied by a single refrigerator located outside the shielding.

The preceding remarks on primary beam line refrigeration requirements take into consideration the fact that the quadrupoles are conventional and that the magnets within the target station are also conventional. Table 1 gives an estimate of the refrigeration required in the primary beam lines of the north area, if the energy of the machine is 1000 GeV or 400 GeV. A more accurate estimate of refrigeration requirements will require more detailed information. 3. Refrigeration of the Secondary Beam Transport System

This section of the report describes the refrigeration problems associated with a system of magnets which has the following characteristics:

1) The magnets or groups of magnets are often separated by distances of 40 meters or more.

- 2) Clumping of bending magnets will be common, pairing of quadrupoles is also common.
- 3) The magnet position is not to be considered permanent, even though some experimental setups are expected to remain in place for many months (even years).
- 4) Beam transport magnets, their power supplies, and their equipment should be standardized for maximum flexibility and economy in the experimental area.
- 5) In many areas, the required shielding is not very thick. As a result, the operation of the refrigeration system near the magnets may be seriously considered.

The LRL-500 Incorporated reports of 1968 favor the small refrigerator concept in the secondary beams of an experimental area. That concept is still valid today (1972), but with some modifications:

- 1) Selection of the lead currents is important; on one hand, the lead current can't be too low because of the high winding cost of the magnet and the high inductance of the magnet; on the other hand, the lead current can't be too high because of the increased refrigeration required for leads (this refrigeration is 10 to 15 watts per 1000 Amps per lead pair. This number includes the refrigeration required because the lead gas doesn't return through the refrigerator heat exchanger).
- It makes a great deal of sense to put quadrupole doublets in a single cryostat.
- 3) Large groups of bending magnets and quadrupoles can be run off of one or more large refrigerators, if they are close together.

- 5 -

This report recommends that magnets in the secondary beam lines be run off of refrigerators capable of delivering from 40 to 100 watts. Reliable refrigerators which can operate unattended over this range are well within today's technology. It should be noted that a refrigerator meeting the above criteria, which is sufficiently reliable for experimental area use, is available today from at least one manufacturer. The refrigerators should, in most instances, be run from a central compressor system. Gas to and from these compressors could be delivered along a beam line through rather conventional room temperature piping. It should be noted that the size of this piping is not greatly different from what might be required to transport cooling water to a system of conventional magnets with the same bending and focusing strength.

The central compressor station is a source of compressed gas for the refrigerators. Helium gas repurification and recovery also take place at the compressor station. The compressor stations can be located some distance from the experiments, just as cooling towers for conventional magnets are today. The largest source of failure of helium refrigerators in the size range suggested here has been compressor failure. Consolidation of compression facilities permits one to provide the redundancy necessary for reliable operation. It should be noted that the odd magnet or two which are located long distances from the central compressors can be cooled by refrigerators which have portable trailer mounted compressors.

In absence of data on the layout of the CERN II experimental area, we must make a number of assumptions in order to make a rough cost estimate of the secondary beam line refrigeration system. Let us assume the following:

- The secondary beam lines consists of 100 200 quadrupole and dipole magnets of various strengths scattered over an area which is 1.5 km long and 150 m wide. About two-thirds of these magnets are quadrupoles.
- 2) Large spectrometer magnets, spark chamber magnets, and bubble chamber magnets will have their own refrigerators; hence, they are not considered a part of the beam transport refrigeration

- 6 -

system.

- 3) Quadrupoles are assumed to occur in doublets (two quadrupoles per cryostat). The dipoles are built one to a cryostat or are at least with segmented cryostats with one dipole per segment.
- 4) The refrigerators are separated from the magnets by no more than 30 meters of flexible or semi-flexible transfer line (this system has been used with good success at LRL Berkeley. Flexible transfer lines will also form an integral part of the Karlsruhe refrigeration transfer system.).
- 5) Two quadrupole doublets (about 90 watts) or two dipole magnets (90 - 100 watts) can be cooled from one refrigerator. The number of magnets to be cooled is a function of the transfer line length and the number of magnets located close to the refrigerator.
- 6) The warm compressed gas piping is assumed to run next to the beam line.
- 7) The refrigerator cold boxes are located outside the shielding in high radiation areas.

Table 2 presents an estimate of the refrigeration required for a quadrupole doublet and a dipole section. The stated heat loss estimate is rough, but from it a reasonable cost estimate can be obtained.

For a 1000 GeV experimental area, let us assume that all of the quadrupoles are in 67 doublets; the 66 dipole magnets are often grouped. One can make the assumption that 80 refrigerators (including spares) are required for an experimental area consisting of 200 magnets. One may also assume that the average length of flexible transfer line required is about 15 meters per magnet. Let us assume that one purchases 150 such lengths including spares. The compressed gas for the 80 refrigerators is assumed to be supplied by two compressor stations; each capable of delivering enough helium gas to run 2500 watts worth of small refrigerators (500 grams/ sec if today's machines are used). In addition, 4 helium compressor trailers are assumed to supply the refrigerator used for the odd magnets. Each trailer is assumed to have enough gas capacity to run one refrigerator at a rating of 100 watts (20g/sec).

The 400 GeV experimental area is assumed to have 50 quadrupole doublets and 35 dipole magnets. I assume that 60 refrigerators are required including spares. I assume that there ible transfer line sections with an average length of 15 meters. I assume that only one compressor station exists in the 400 GeV experimental area. This compressor station supplies enough gas to run 3500 watts worth of small refrigerators. In addition, I assume that the 4 helium compressor trailers used in the 1000 case are used in the 400 GeV area as well. The number of magnets does not go down linearly with energy because a certain number of focusing and bending elements are requred just to perform an experiment.

Three helium pipes must be run in the experimental area. One pipe supplies warm compressed helium to the refrigerator; a second returns the gas to the compressor. This pipe also carries warm gas from the magnet leads and gas expelled from the magnet during cooldown. The third pipe recovers impure helium gas from the experimental floor.

4. Preliminary Cost Estimate

Preliminary cost estimates of beam transport systems made a number of years ago by Meuser¹⁰ indicated that the capital cost per Tm of bending was the same or lower for a system of superconducting magnets as compared to a system of conventional magnets; this is still true today. The operating cost of the superconducting magnet system can be expected to be substantially lower than for the conventional **magnet** system. The a.c. magnets being developed at the three GESSS laboratories can be used as models for d.c. beam transport magnets because the technical requirements for a good d.c. beam transport magnet are not greatly different from a pulsable magnet, (the primary difference is the magnet current).

The cost of the refrigeration system for the primary beam transport system is shown in Table 3. The refrigeration cost for the first vertical bend in the 1000 GeV case is an extension of the supercon-

- 8 -

ducting synchrotron refrigeration system. It represents the cost of extending a 10 to 20 $_{\rm kW}$ refrigerator by 500 watts. The cost of the beam switch yard and second vertical bend refrigeration is based on costs quoted in reference 6. These costs are high by today's standards. The 400 GeV primary beam transport system refrigeration cost is only for the switch yard refrigeration system.

Tables 4 and 5 give a cost estimate for refrigeration in a 400 GeV and a 1000 GeV beam transport area. It should be noted that one could supply each refrigerator with its own compressor and purification. The total cost of such a system for the experimental area would be about 22 Million Sw Fr for the 1000 GeV system and about 17 Million Sw Fr for the 400 GeV system. One, however, would increase the operating cost because the central compressors would be cheaper to maintain than many small compressors scattered about the site. Table 6 presents a rough estimate of the yearly operating cost of refrigeration in the primary and secondary beam transport systems.

5. Conclusions

Refrigeration can be supplied to the primary and secondary beams of the north area of the SPS for from 14 Million Sw Fr (400 GeV peak beam energy) to 20 Million Sw Fr (1000 GeV peak beam energy). The yearly operating cost of system varies from 2.5 to 3.0 Million Sw Fr depending on the primary beam energy. These numbers apply to a system of magnets which generates 530 to 1000 Tm of bending and 1.5 $1.5 - 2 \times 10^5$ Tm/m of focusing. The average capital cost of refrigeration per dipole or per quadrupole doublet is around 150000 Sw Fr (about 0.8 - 1.2×10^4 Sw Fr / Tm of bending). One should compare this cost with the power supply and cooling system cost for a like amount of conventional bending or focusing.

The unit cooling cost, 150000 Sw Fr per cryostat, is relatively independent of the magnet useful aperture over a range of aperture diameters from 40 to 120 mm. The cost of refrigeration begins to climb as the magnet useful aperture goes above 120 mm. The cost of refrigeration does not vary a great deal over a range of magnet de-

- 9 -

sign fields from 3.5 to 5.5 T. As one increases the design dipole or quadrupole pole field beyond 6 T, The magnet size grows rapidly. This will increase the unit cost of refrigeration.

·



| | Table 1 | Estimated | Refrigeration | Requirements | for | the | Primary | Beam | Transport | System |
|--|---------|-----------|---------------|--------------|-----|-----|---------|------|-----------|--------|
|--|---------|-----------|---------------|--------------|-----|-----|---------|------|-----------|--------|

| | 400 GeV | 1000 GeV | | |
|---|-------------------------|--------------------------------|----------------------|-----------------------------------|
| | Beam Switch Yard | 1st Vertical Bend | 2nd Vertical Bend | Beam Switch Yard |
| Heat Leaks through the Supports 2.5W/magnet | 45 W | 25 W | 25 W | 65 W |
| Heat Leaks through the Superinsulation ⁺ | 100 W | 100 W | 95 W | 160 W |
| Electrical Lead Refrigeration 12W/1000A pair | 50-125 W | 5000A leads 120 W | 5000A leads 60 W | depends on current 50-125 W |
| Transfer Line Heat Leak 1W/meter | 75-100 W | 50 W | 75-100 W | 75-100 W |
| A.C. Loss and Cooldown | 80-100 W | 100-150 W | 100-150 W | 100-150 W |
| Total Load | 350-470 W | 395-445 W | 355-435 W | 450-600 W |
| Installed Refrigeration Capacity | 500 W | 475 W | 450 W | 650 W |
| Installed Capacity f | or the 2nd Vertical Ben | d plus the Beam Switch Yard | 110 | DO W |

+ No nitrogen temperature shields are assumed

- 12 -

| Table 2 | Estimate | ed | Неа | t Lo | ads | for | Var | ious |
|---------|----------|----|-----|------|---------------------|-------|-----|--------|
| | Element | in | a | Beam | Tr | anspo | ort | System |

| | 2-3 meter long Quadrupole doublet | Single Dipole Section 4 meter long |
|---|--------------------------------------|---------------------------------------|
| | 500A leads for each quadrupole | Room Temperature leads 1000A |
| Heat Leaks through the Supports | 5 watts | 3 watts |
| Heat Leaks down the Necks and through the Superinsulation ⁺ | 3-6 watts | 6-10 watts |
| Electrical Lead Cooling | 12-14 watts | 12-15 watts |
| Loss during Charging and Cooldown Allowance | 10 watts | 10 watts |
| Total Heat Load | 30-35 watts | 31-38 watts |
| Purchased Refrigeration Required | 40 watts | 40 watts |

+ No nitrogen temperature shields are assumed

Table 3 Refrigeration Cost for the Primary Beam Transport System

a) 400 GeV Primary Beam Transport System

Component

Cost of the Refrigeration

| | 1st Vertical Bend | 2nd Vertical Bend and Beam Switch Yard |
|---|--|---|
| | | |
| Refrigerator and Compressor | | 740 000 Sw Fr |
| Transfer Lines | | 40 000 Sw Fr |
| J-T Valves and Control System | | 20 000 Sw Fr |
| Total for Component s | | 800 000 Sw Fr |
| Total for 400 GeV Pri | .mary Beam Transport Area | 800 000 Sw Fr |
| ىرى بىرى كۆككەرمىيەن يېچىكە خىرىنى بەرخى _{لىكى} ت بىر بىرى يېچىنى خاكىرىمىرى بىرىچى بىرچىزىك خاخكى ي | ۵٬۰۰۰ ک <u>ې د مېرمې مې مې مې مې مې مې مېرونې د ده د مې </u> | |

b) 1000 GeV Primary Beam Transport System

| Component | Cost of the Refrigeration | | | | |
|----------------------------------|---------------------------|---|--|--|--|
| | 1st Vertical Bend | 2nd Vertical Bend and Beam Switch Yard | | | |
| | | | | | |
| Refrigerator and Compressor | 280 000 Sw Fr | 1 140 000 Sw Fr | | | |
| Transfer Lines | 20 000 Sw Fr | 80 000 Sw Fr | | | |
| J-T Valves and Control System | 40 000 Sw Fr | 80 000 Sw Fr | | | |
| Total for Components | 340 000 Sw Fr | 1 300 000 Sw Fr | | | |
| Total for 1000 GeV Pr | imary Beam Transport Area | 1 640 000 Sw Fr | | | |

Table 4Refrigeration Cost for the 400 GeVSecondary Beam Transport System

| Component | Cost (Thousands of Sw Fr) | | | | |
|--|---|------|--|--|--|
| Compressor Stations | | | | | |
| Compressors | 2000 | | | | |
| Purification | 420 | | | | |
| Gas Storage | 300 | | | | |
| Cooling and Power Distribution | 560 | | | | |
| 4 km Distribution Piping | 1520 | | | | |
| Total per Station | 4800 1 Station | 4800 | | | |
| Portable Compressors Trailer-mounted | 140 000 Sw Fr / Trailer | 560 | | | |
| 60 Refrigerators | 125 000 Sw Fr / Refrigerator ⁺ | 7500 | | | |
| 110 Tran sf er Lines (average 15 m long) | 4 000 Sw Fr / Transfer Line ⁺⁺ | 440 | | | |
| Total for the Secondary Beam System | | | | | |

- + Today a refrigerator meeting the above specification costs 170 000 Sw Fr without compressors or 270 000 Sw Fr with compressors and purification. The price above is based on quantity buying.
- ++ LRL made a transfer line of this type for less than 140 Sw Fr/meter. Vacuum Barrier quotes a price of 5 000 Sw Fr for a 15 m long flexible transfer line¹².

Table 5Refrigeration Cost for the 1000 GeVSecondary Beam Transport System

| Component | Cost (Thousands of Sw Fr) | |
|---|--|--------|
| Compressor Stations | | |
| Compressors | 1 440 | |
| Purification | 420 | |
| Gas Storage | 250 | |
| Cooling and Power Distribution | 400 | |
| 3 km Distribution Piping | 1 140 | |
| Total per station | 3 650 2 Stations | 7 300 |
| Portable Compressors Trailer-mounted | 140 000 Sw Fr / Trailer | 560 |
| 80 Refrigerators | 125 000 Sw Fr / Refrigerator ⁺ | 10 000 |
| 150 Transfer Lines (average 15 m long) | 260 Sw Fr / m or 4 000 Sw Fr / line ⁺⁺ | 600 |
| Total for the Seconda | ry Beam System | 18 460 |

- + Today a refrigerator meeting the above specification costs 170 000 Sw Fr without compressors or 270 000 Sw Fr with compressors and purification. The price above is based on quantity buying.
- ++ LRL made a transfer line of this type for less than 140 Sw Fr/meter. Vacuum Barrier quotes a price of 5 000 Sw Fr for a 15 m long flexible transfer line¹².

Table 6 Yearly Operating Cost for Refrigeration for the Primary and Secondary Beam Transport Systems at 400 GeV and at 1000 GeV

| | Yearly Operating Cost (Thousands of Sw Fr) | | |
|--|---|-------------|--|
| | 400 GeV | 1000 GeV | |
| Electric Power 0.04 Sw Fr/kw hr 400 GeV 2500 kw 1000 GeV 3400 kw | 900 | 1200 | |
| Labor for Normal Operation (5 shifts, including Holidays and Weekends) 50 000 Sw Fr/Man yr. 400 GeV 3 men/shift 1000 GeV 4 men/shift | 750 | 1000 | |
| Labor for Maintenance (day shift only) 400 GeV 3 men 1000 GeV 4 men | 150 | 200 | |
| Replacement Parts | 300 | 400 | |
| Helium Gas Makeup | 100 | 100 | |
| Liquid Nitrogen, other Materials | 100 | 100 | |
| Total Operating Cost | 2300 | 3000 | |
| Operating Cost based on Reference 2 | 2700 | 3600 | |
| Operating Cost Range given in Reference 9 | 1900 - 5600 | 2600 - 7600 | |

15 May 1972

Cost of Superconducting Dipole Magnets for an Experimental Area Michael A. Green

The five tables which are attached explain the process for calculating the cost of a superconducting magnet system for the experimental area. The details of how the costs presented in Tables 2 through 5 were calculated is discussed in a full report which will come out later. Tables 1 through 4 compare the parameters and costs for nine different 4 meter long dipole magnets. The central induction varies in steps of 3.6, 4.5, and 5.4 T; the magnet coil aperture varies in steps of 50, 100, and 150.mm.

Table 1 shows the parameters of the nine magnets. Table 2 explains the process for calculating superconductor cost. Table 3 tabulates the major cost components which make up the magnet cost. Table 4 tabulates the cost of the major components of a superconducting magnet system. These include the magnet, the magnet cryostat, the magnet power supply, and the magnet refrigeration system. The last column in Table 4 shows the cost per Tm of bending. One should build magnets which have a central induction of around 4.0 to 4.5 T, if the magnet system is to be of minimum cost.

Table 5 compares the capital and operating cost of conventional and superconducting experimental area magnet systems. The conventional system must include the magnet, the magnet power supply, and the magnet cooling system.

- 18 -

REFERENCES

- T. R. Strobridge, D. B. Chelton, and D. B. Mann;
 "A Preliminary Analysis of Refrigeration Requirements for Superconducting Magnets in the Experimental Area of the 200 BeV Accelerator" US National Bureau of Standards Report 9259, October 31, 1966.
- 2. M. A. Green, G. P. Coombs, and J. L. Perry, <u>Refrigeration for</u> <u>Superconducting Magnets in the 200 BeV Accelerator, Weston,</u> <u>Illinois</u>, published and copywrited by 500 Incorporated, Cambridge Massachusetts USA, June 1, 1968.
- 3. M. A. Green, G. P. Coombs, and J. L. Perry; "An Examination of a Liquid Helium Refrigeration System for Superconducting Magnets in the 200 BeV Experimental Area" in the <u>Proceedings of the 1968</u> <u>Summer Study on Superconducting Devices and Accelerators</u>, Part 1, P. 293, BNL-50155, July 1968
- 4. <u>200 BeV Experimental Use</u>, Vols. 1 and 2 (April 1966) and 3 (Feb. 1967), Lawrence Radiation Laboratory Report UCRL-16830
- 5. <u>Utilization Studies for the 300 GeV Proton Synchrotron</u>, Vols. 1 and 3, CERN/ECFA 67/6
- T. R. Strobridge; "Refrigeration for Superconducting and Cryogenic Systems" <u>IEEE Transactions</u>, Nuclear Science NS-16 (3), June 1969
- 7. M. A. Green, "Refrigeration of Superconducting Magnets", Particle Accelerator 1 (3), P. 213, 1970
- 8. M. A. Green, "Operating Procedure for the LRL Liquifier", Section 4, pp. 39-55, UCID 3428, Dec. 1969

- 9. M. A. Green; "Simplified Helium Cryostats for Superconducting Dipoles and Quadrupole Magnet" Lawrence Radiation Laboratory Report UCRL-19764, UC 38 Eng. and Equip. TID-4500 (56th Edition) July 29, 1970
- 10. R. B. Meuser, "Secondary Beam Magnets for the 200 BeV Accelerator Conventional or Superconducting" UCRL-17269 Feb. 1967, published in the <u>IEEE Transaction</u> NS-14 (3) June 1967
- 11. Private Communication with G. P. Coombs and M. Streeter of Cryogenic Technology Incorporated Waltham Mass. USA or CTI Cryogenic AG, CH 8008 Zürich, Seefeldstraße 224
- 12. Private Communication with Norman E. Weare of Vacuum Barrier Corporation, 4 Barten Lane Woburn, Massachusetts 01901, USA represented in Europe by Kabelmetal, D 3000 Hannover, Postfach 260.

| Coil Central Induction (T) | Coil Aperture Diameter (mm) | Useful Aperture Diameter (mm) | Peak Induction in Coil (T) | Overall Coil Current Density * (A/cm ²) | Coil Thickness ⁺ (cm) | Ampere Turns of Conductor | Ampere Meters of Conductor++ | |
|-------------------------------------|--------------------------------------|--|-------------------------------------|---|--|---------------------------------|------------------------------------|---|
| | 50 | 35 | 4.0 | 2.4×10 ⁴ | 1.72 | 3.26×10 ⁵ | 2.68×10 ⁶ | |
| 3.6 | 100 | 80 | 4.0 | 2.4×10 ⁴ | 1.72 | 4.85×10 ⁵ | 4.07×10 ⁶ | |
| | 150 | 120 | 4.0 | 2.4×10 ⁴ | 1.72 | 6.90×10 ⁵ | 5.81×10 ⁶ | 1 |
| | 50 | 35 | 5.0 | 2.0×10 ⁴ | 2.79 | 4.32×10 ⁵ | 3.57×10 ⁶ | |
| 4.5 | 100 | 80 | 5.0 | 2.0×10 ⁴ | 2.79 | 7.12×10 ⁵ | 6.01×10 ⁶ | ſ |
| | 150 | 120 | 5.0 | 2.0×10 ⁴ | 2.79 | 9.92×10 ⁵ | 8.55×10 ⁶ | |
| | 50 | 35 | 6.0 | 1.7×10 ⁴ | 4.13 | 6.40×10 ⁵ | 5.31×10 ⁶ | |
| 5.4 | 100 | 80 | 6.0 | 1.7×10 ⁴ | 4.13 | 9.90×10 ⁵ | 8.38×10 ⁶ | |
| | 150 | 120 | 6.0 | 1.7×10 ⁴ | 4.13 | 13.42×10 ⁵ | 11.58×10 ⁶ | |
| | 1 | 1 | 1 | 1 | l l | | | 1 |

Table 1 Coil Ampere Turns and Ampere Meters for 4 Meter Long Dipole Magnets with Central Inductions of 3.6, 4.5, and 5.4 T and Coil Aperture Diameters of 50, 100, and 150 mm

* A cos θ coil is assumed; current density applies at $\theta=0$; the change in current density with field is correct when IMI, Airco, or Supercon materials are used.

+ A $\cos \theta$ coil has a uniform coil thickness.

++ The dipole length is 4 meters; round ends are assumed.

| Table 2 | Super conductor Cost for 4 Meter Long |
|---------|---|
| | Dipole Magnets with Central Inductions |
| | of 3.6, 4.5, and 5.4 T and Coil Apertures |
| | of 50, 100, and 150 mm |

S. 16. 1

| Dipole Central Induction (T) | Dipole Coil Aperture (mm) | Ampere Meters of Conductor | Superconductor ⁺ Cost Factor (Sw Fr/Am) | Coil Superconductor Cost (Sw Fr) |
|---------------------------------------|------------------------------------|----------------------------------|---|---|
| 3.6 | 50 | 2.68×10 ⁶ | 2.0×10 ⁻² | 0.54×10 ⁵ |
| | 100 | 4.07×10 ⁶ | 2.0×10 ⁻² | 0.81×10 ⁵ |
| | 150 | 5.81×10 ⁶ | 2.0×10 ⁻² | 1.16×10 ⁵ |
| 4.5 | 50 | 3.57×10 ⁶ | 2.4×10 ⁻² | 0.86×10 ⁵ |
| | 100 | 6.01×10 ⁶ | 2.4×10 ⁻² | 1.44×10 ⁵ |
| | 150 | 8.55×10 ⁶ | 2.4×10 ⁻² | 2.06×10 ⁵ |
| 5.4 | 50 | 5.31×10 ⁶ | 2.8×10 ⁻² | 1.49×10 ⁵ |
| | 100 | 8.38×10 ⁶ | 2.8×10 ⁻² | 2.35×10 ⁵ |
| | 150 | 11.58×10 ⁶ | 2.8×10 ⁻² | 3.25×10 ⁵ |

+ The price of fine filamented $(8-12 \ \mu \text{ filaments})$ NbTi superconductors is from 4×10^{-3} US \$ /Am to 1.3×10^{-2} US \$/Am $(1.5 \times 10^{-2} - 5 \times 10^{-2} \text{Sw Fr/Am})$ at a wire induction of 5 T. It should be noted that the price from IMI consistantly falls at the upper end of this scale 8×10^{-3} to 1.3×10^{-2} US \$/Am and the Airco and Cryomagnetics falls at the lower end of the scale. All prices are based on small lots, say 10^{6} to 3×10^{6} ampere meter of superconductor. The price per ampere meter of a given conductor is inversely proportional to it's critical current.

| Table 3 | The Cost of a 4 Meter Long Superconducting Dipole Magnet | |
|---------|--|--|
| | as a Function of Central Induction (3.6, 4.5, and 5.4 T) | |
| | and Magnet Coil Aperture (50, 100, and 150 mm) | |

| Magnet | Magnet | Magnet | Magnet Conductor | Magnet Bore | Magnet | Total |
|-----------|----------|----------------------|----------------------|----------------------|-----------------------|----------------------|
| Central | Coil | Superconductor | Winding and Potting | Tube Assembly | Iron | Magnet |
| Induction | Aperture | Cost | Cost | and Test | Cost | Cost |
| (T) | (mm) | (Sw Fr) | (Sw Fr) | (Sw Fr) ⁺ | (Sw Fr) ⁺⁺ | (Sw Fr) |
| 3.6 | 50 | 0.54×10 ⁵ | 0.27×10 ⁵ | 0.2×10 ⁵ | 0.2×10 ⁵ | 1.21×10 ⁵ |
| | 100 | 0.81×10 ⁵ | 0.41×10 ⁵ | 0.25×10 ⁵ | 0.4×10 ⁵ | 1.87×10 ⁵ |
| | 150 | 1.16×10 ⁵ | 0.58×10 ⁵ | 0.3×10 ⁵ | 0.8×10 ⁵ | 2.84×10 ⁵ |
| 4.5 | 50 | 0.86×10 ⁵ | 0.43×10 ⁵ | 0.2×10 ⁵ | 0.3×10 ⁵ | 1.79×10 ⁵ |
| | 100 | 1.44×10 ⁵ | 0.72×10 ⁵ | 0.25×10 ⁵ | 0.6×10 ⁵ | 3.01×10 ⁵ |
| | 150 | 2.06×10 ⁵ | 1.03×10 ⁵ | 0.3×10 ⁵ | 1.2×10 ⁵ | 3.79×10 ⁵ |
| 5.4 | 50 | 1.49×10 ⁵ | 0.75×10 ⁵ | 0.2×10 ⁵ | 0.5×10 ⁵ | 2.94×10 ⁵ |
| | 100 | 2.35×10 ⁵ | 1.18×10 ⁵ | 0.25×10 ⁵ | 0.9×10 ⁵ | 4.68×10 ⁵ |
| | 150 | 3.25×10 ⁵ | 1.63×10 ⁵ | 0.3×10 ⁵ | 1.7×10 ⁵ | 6.88×10 ⁵ |

* This cost estimate is based on the winding cost of two large Berkeley magnets. The average winding cost was 1-1.3×10⁻²Sw Fr/Am; production magnet cost should be much lower.

+ This cost is based on Berkeley experience, a cost of \$5000 to \$10,000 per magnet for bore tube and assembly. If the magnet is mass produced, these costs will be substantially lower.

++ This cost is based on a price of 8 Sw Fr/Kg for finished iron cores.

** The total price does not include engineering and development. Add a contingency allowance of 40%.

| Magnet Central Induction (T) | Coil Aperture (mm) | Magnet Cost (Sw Fr) | Magnet Cryostat Cost ** (Sw Fr) | Magnet Power Supply Cost + (Sw Fr) | Refrigeration System Cost ++ (Sw Fr) | Total Magnet System Cost (Sw Fr) | Superconducting Magnet System Cost per Tm (Sw Fr) |
|---------------------------------------|--------------------------|--|--|---|---|--|--|
| 3.6 | 50 100 | 1.21×10 ⁵ 1.87×10 ⁵ | 0.8×10 ⁵ 0.9×10 ⁵ | 0.2×10 ⁵ 0.2×10 ⁵ | 1.5×10 ⁵ 1.5×10 ⁵ | 3.71×10 ⁵ 4.47×10 ⁵ | 2.58×10 ⁴ 3.11×10 ⁴ |
| | 150 | 2.84×10 ⁵ | 1.0×10 ^{5*} | 0.2×10 ⁵ | 1.5×10 ⁵ | 5.54×10 ⁵ | 3.85×10 ⁴ |
| | 50 | 1.79×10 ⁵ | 0.8×10 ⁵ | 0.2×10 ⁵ | 1.5×10 ⁵ | 4.29×10 ⁵ | 2.38×10 ⁴ |
| 4.5 | 100 | 3.01×10 ⁵ | 0.9×10 ⁵ | 0.2×10 ⁵ | 1.5×10 ⁵ | 5.61×10 ⁵ | 3.11×10 ⁴ |
| | 150 | 3.79×10 ⁵ | 1.0×10 ^{5*} | 0.24×10 ⁵ | 1.5×10 ⁵ | 6.53×10 ⁵ | 3.63×10 ⁴ |
| | 50 | 2.94×10 ⁵ | 0.9×10 ⁵ | 0.2×10 ⁵ | 1.5×10 ⁵ | 5.54×10 ⁵ | 2.56×10 ⁴ |
| 5.4 | 100 | 4.68×10 ⁵ | 1.0×10 ⁵ | 0.2×10 ⁵ | 1.5×10 ⁵ | 7.38×10 ⁵ | 3.42×10 ⁴ |
| | 150 | 6.88×10 ⁵ | 1.0×10 ^{5*} | 0.38×10 ⁵ | 1.5×10 ⁵ | 9.76×10 ⁵ | 4.52×10 ⁴ |

Table 4 The Cost of the Magnet System for a 4 Meter Long Superconducting Dipole Magnet as a Function of Central Induction (3.6, 4.5, and 5.4 T)

* It is probable that the iron will lie outside the cryostat.

** Based on cryostat cost quoted to the KFK, some allowance has been made for quantity production.

 Cost based on a minimum price of 5000 US \$ or 0.25 US\$/watt whichever is higher; this is based on Berkeley experience. Ripple requirement < 2×10⁻⁴. Mass produced power supplies could be less expensive.

++ Unit refrigeration system cost given in the refrigeration system report BSG Notiz 72/7.

- 24 -

| | Superconducting Magnet | Conventional Magnet |
|---|---------------------------|--------------------------|
| a) Magnet Parameters | | |
| Number of Magnets | 1 | 2 |
| Magnet Induction | 4.5 Т | 1.8 Т |
| Length of Magnet | 4.0 m | 5.0 m |
| Aperture of Magnet | 100 mm Ф | 100×240 between |
| Type of Magnet | cos θ | Window Frame |
| Iron Weight | | 19.6 Tons* |
| Copper Weight | | 5.2 Tons** |
| Power Requirements to Produce 1.8 T | 44 kw | 440 kw |
| b) Magnet System Capital Cost (Sw Fr) | | |
| Magnet | 3.01×10 ⁵ | 2.98×10 ⁵ |
| Magnet Cryostat | 0.9×10 ⁵ | |
| Magnet Power Supply | 0.2×10 ⁵ | 4.4×10 ⁵⁺ |
| Refrigeration System | 1.5×10 ⁵ | |
| Water Cooling System | | 1.68×10 ⁵⁺⁺ |
| Total Capital Cost for 18 Tm | 5.61×10 ⁵ | 9.06×10 ⁵ |
| Capital Cost per Tm | 3.11×10 ⁴ | 5.03×10 ⁴ |
| Cost Range for 18 Tm of bending | 4.0-8.0×10 ⁵ | 7.7×10.5×10 ⁵ |
| c) Magnet Yearly Operating Cost (Sw Fr) | | |
| Power Cost | 0.15×10 ⁴ § | 1.5×10 ⁵ |
| Labor Cost | 0.15×10 ⁴ | 0.1×10 ⁵ |
| Total Yearly Cost | 0.3×10 ⁴ | 1.6×10 ⁵ |

* Iron cost is 0.50 US \$/1b (4.2 Sw Fr/kg) including assembly.

** Copper current density 600 A/cm²(the optimum for minimum capital cost is 400 A/cm². Beam transport magnets which run at lower induction much of the time have higher than optimum current densities); copper cost is 5.00 US \$/1b (42 Sw Fr/kg)

+ Power supply cost 1000 Sw/Fr/kw based on German costs.

++ Cooling system cost complete is 380 Sw Fr/kw installed. This is based on Berkeley costs.

§ Power cost 0.01 US \$/kw hr (0.038 Sw Fr/kw hr).

. . . .