

KfK 4087
Juni 1986

**Double Blind Post-Test
Prediction for LOBI-MOD 2
Small Break Experiment A 2-81
Using RELAP 5 / MOD 1/19
Computer Code as Contribution
to International CSNI-
Standardproblem No. 18**

**G. Jacobs, S. H. Mansoor
Institut für Neutronenphysik und Reaktortechnik
Projekt Nukleare Sicherheit**

Kernforschungszentrum Karlsruhe

KERNFORSCHUNGSZENTRUM KARLSRUHE

Institut für Neutronenphysik und Reaktortechnik
Projekt Nukleare Sicherheit

KfK 4087

Double Blind Post-Test Prediction for LOBI-MOD2 Small Break
Experiment A2-81 Using RELAP5/MOD1/19 Computer Code as
Contribution to International CSNI-Standardproblem No. 18

Günter Jacobs
Syed Hasan Mansoor*)

*) Chashma Nuclear Power Project,
Pakistan Atomic Energy Commission, Islamabad

Kernforschungszentrum Karlsruhe GmbH, Karlsruhe

Als Manuskript vervielfältigt
Für diesen Bericht behalten wir uns alle Rechte vor

Kernforschungszentrum Karlsruhe GmbH
Postfach 3640, 7500 Karlsruhe 1

ISSN 0303-4003


ABSTRACT

The first small break experiment A2-81 performed in the LOBI-MOD2 test facility was the base of the 18th international CSNI standard problem (ISP 18). Taking part in this exercise, a blind post-test prediction was performed using the light water reactor transient analysis code RELAP5/MOD1. This paper describes the input model preparation and summarizes the findings of the pre-calculation comparing the calculational results with the experimental data. The results show that there was a good agreement between prediction and experiment in the initial stage (up to 250 sec) of the transient and an adequate prediction of the global behaviour (thermal response of the core), which is important for safety related considerations. However, the prediction confirmed some deficiencies of the models in the code concerning vertical and horizontal stratification resulting in a high break mass flow and an erroneous distribution of mass over the primary loops.

Doppelblinde Posttest-Vorausrechnung des LOBI-MOD2 Kleinleck-Experimentes A2-81 mit Hilfe des Rechenprogramms RELAP5/MOD1/19 als Beitrag zum internationalen CSNI-Standardproblems Nr. 18

ZUSAMMENFASSUNG

Das erste Kleinleck-Experiment A2-81, welches an der LOBI-MOD2 Versuchsanlage gefahren wurde, war die Basis des 18-ten internationalen CSNI-Standardproblems (ISP18). Hierfür wurde eine blinde Vorhersage nach Versuch mit Hilfe des Leichtwasserreaktor-Transientenanalyse-Programms RELAP5/MOD1 durchgeführt. Dieses Papier beschreibt die Erstellung des Eingabemodells und faßt die Befunde der Vorausrechnung zusammen, indem die Rechenergebnisse mit den experimentellen Daten verglichen werden. Die Ergebnisse zeigen eine gute Übereinstimmung zwischen Vorhersage und Experiment in der Anfangsphase (bis 250 s) der Transiente und eine noch genügende Vorhersage des globalen Verhaltens (thermische Reaktion des Kerns), welches bedeutsam ist für sicherheitsbezogene Betrachtungen. Allerdings erhärtete die Vorhersage einige Modellschwächen des Programms hinsichtlich vertikaler und horizontaler Schichtung, die sich in einem zu hohen Leckmassenstrom und einer unrichtigen Massenverteilung über die Primärkreise auswirkte.



ACKNOWLEDGEMENTS


The authors wish to express their gratitude to Prof. G. Keßler and Prof. K. Rehme for providing encouragement all the time in carrying out this exercise. We would also like to thank Mr. E. Mensinger and Mr. G. Wörner for preparing the drawings for this report and Mrs. G. Bunz for typing the manuscript.

CONTENTS

Page	Title
3	Abstract
5	Acknowledgements
7	Table of Contents
9	List of Tables
11	List of Figures
15	1. Introduction
17	2. LOBI-MOD2 Configuration and Test Specification
20	3. RELAP5 Input Model
26	4. Initialization of the Problem
35	5. Comparison of Results
41	6. Conclusions
45	Tables
89	Figures
141	References

Appendix A: LOBI-MOD2, Description of Test Facility


Appendix B: Complete Listing of Input Data for ISP 18



LIST OF TABLES

Page Table

46	1.1	List of ISP 18 Participants
48	2.1	List of Most Important Trips/Events for ISP18
49	2.2	Heating Power for ISP 18
50	2.3	Main Coolant Pump Speed for ISP18
50	2.4	HPIIS Flow as Function of Primary Pressure
51	3.1	Geometrical Data for LOBI-MOD2 Facility
60	3.2	RELAP5/MOD1 Volume-related Input Data for Test A2-81
70	3.3	RELAP5/MOD1 Junction-related Input Data for Test A2-81
80	4.1	Measured/Calculated Pressure Drop Data for the Reactor Pressure Vessel Model of Test A2-81
81	4.2	Measured/Calculated Pressure Drop Data for the Intact/Broken Loop of Test A2-81
82	4.3	Measured/Calculated Pressure Drop Data for the Steam Generators SG1/SG2 of Test A2-81
83	4.4	Measured and Calculated Environmental Heat Loss for ISP18
84	4.5	Estimated and Calculated Bypass Flow Rates
84	4.6	Measured and Calculated Pump Speed and Core Heatup Values at Steady State
85	4.7	Seal Water Injection into Primary Coolant Pumps
86	4.8	Specified, Measured and Calculated Initial Conditions
87	5.1	ISP18 Post-Test Prediction Performance
87	5.2	ISP18 Sequence of Events



LIST OF FIGURES

Page Figure

- 90 2.1 LOBI-MOD2 Geometrical Configuration for Test A2-81
- 91 3.1 LOBI-MOD2 Nodalization for RELAP5/MOD1
- 92 3.2 LOBI-MOD2 Intact Loop (schematic)
- 93 3.3 LOBI-MOD2 Broken Loop (schematic)
- 94 3.4 LOBI-MOD2 Reactor Pressure Vessel Model (schematic)
- 95 3.5 LOBI-MOD2 Steam Generator(s) (schematic)
- 96 3.6 LOBI-MOD2 Steam Lines and Header (schematic)
- 97 3.7 Nodalization of RPVM
- 98 3.8 Modelling of Core Bypass Flow Paths in RPVM
- 99 3.9 Sections and Power distribution of LOBI-MOD2 Heater Rods
- 100 3.10 Modelling of Break
- 101 3.11 Nodalization of I.L Steam Generator
- 102 3.12 Nodalization of B.L Steam Generator
- 103 4.1 Pressure Difference Measurements Sections for Loops
- 104 4.2 Pressure Difference Measurements Sections for RPVM
- 105 4.3 Pressure Difference Measurements Sections for SG I
- 106 4.4 Pressure Difference Measurements Sections for SG II
- 107 5.1 Pressure in Upper Plenum, PA38
- 107 5.2 Pressurizer Pressure, PA40
- 107 5.2a Pressurizer Pressure, PA40 (first 500 sec into trans.)
- 108 5.3 Core Power, WH-POWER
- 108 5.4 Intact Loop Pump Speed, RP71
- 109 5.5 HPIS Flow, QM55
- 109 5.6 Fluid Temp. at Intact Loop Vessel Outlet at Top, TF11T
- 110 5.7 Fluid Temp. at Intact Loop Vessel Outlet at Bott., TF11B
- 110 5.8 Fluid Temp. at Intact Loop Vessel Inlet at Top, TF16T
- 111 5.9 Fluid Temp. at Intact Loop Vessel Inlet at Bott., TF16B
- 111 5.10 Fluid Temp. at Broken Loop Vessel Outlet at Top, TF21T
- 112 5.11 Fluid Temp. at Broken Loop Vessel Outlet at Bott., TF21B

LIST OF FIGURES (cont.)


Page Figure

112	5.12	Fluid Temp. at Broken Loop Vessel Inlet at Top, TF26T
113	5.13	Fluid Temp. at Broken Loop Vessel Inlet at Bott., TF26B
113	5.14	Fluid Temp. at Core Inlet, TF35
114	5.15	Fluid Density at Intact Loop Vessel Outlet, DD11
114	5.16	Fluid Density at Intact Loop Pump Inlet, DD14
115	5.17	Fluid Density at Intact Loop Cold Leg Vessel Inlet, DD16
115	5.18	Fluid Density at Broken Loop Hot Leg Vessel Outlet, DD21
116	5.19	Fluid Density at Broken Loop Pump Inlet, DD24
116	5.20	Fluid Density at Broken Loop B/W Pump & Brek, DD25
117	5.21	Fluid Density at Broken Loop B/W Break & Vessel, DD26
117	5.22	Fluid Density at Near Core Inlet, DS35
117	5.21a	Fluid Density at Broken Loop B/W Break & Vessel, DD26
118	5.23	Differential Pressure Intact Loop Seal Desc. Leg, PD9217
118	5.24	Differential Pressure Intact Loop Seal Asc. Leg, PD1714
119	5.25	Differential Pressure Broken Loop Seal Desc. Leg, PD8227
119	5.26	Differential Pressure Broken Loop Seal Asc. Leg, PD2724
120	5.27	Differential Pressure Vessel Downcomer, PD3DBT
120	5.28	Differential Pressure Core Heated Length, PD3RTK
121	5.29	Differential Pressure Upper Plenum, PD3RKA
121	5.30	Differential Pressure Intact Loop Asc. U-Tubes, PD90BN
122	5.31	Differential Pressure Broken Loop Asc. U-Tubes, PD80BN
122	5.32	Differential Pressure Upper Head Upper Plenum, PD3R39
123	5.33	Heater Rod Surface Temp. Level 4, TH04
123	5.34	Heater Rod Surface Temp. Level 7, TH07
124	5.35	Heater Rod Surface Temp. Level 9, TH09
124	5.36	Heater Rod Surface Temp. Level 11, TH11
125	5.37	Heater Rod Surface Temp. Level 13, TH13
125	5.38	Heater Rod Surface Temp. Level 14, TH14
126	5.39	Steam Generator I, Press. in Steam Dome, PA97S
126	5.40	Steam Generator I, Temp. at Bottom of Riser, TF95B
127	5.41	Steam Generator I, Temp. at Top of Riser, TF95N
127	5.42	Steam Generator I, Temp. in Steam Dome, TF97T

LIST OF FIGURES (cont.)

Page Figure

- | | | |
|-----|-------|---|
| 128 | 5.43 | Steam Generator II, Temp. at Bottom of Riser, TF85B |
| 128 | 5.44 | Steam Generator II, Temp. at Top of Riser, TF85K |
| 129 | 5.45 | Steam Generator II, Temp. in Steam Dome, TF87T |
| 129 | 5.46 | Collapsed Water Level in Pressurizer, CL4340 |
| 130 | 5.47 | Collapsed Water Level in SG II Downcomer, CL83BT |
| 130 | 5.48 | Collapsed Water Level in SG I Downcomer, CL93BT |
| 131 | 5.49 | Mass Flow in SG II Lower Downcomer, CM83G |
| 131 | 5.50 | Mass Flow in SG I Lower Downcomer, CM93G |
| 132 | 5.51 | Mass Flow in SG I Steam Line, CM65 |
| 132 | 5.52 | Mass Flow in SG II Steam Line, CM66 |
| 133 | 5.53 | Net Pump Seal Water Injection Flow Pump I, QS71 |
| 133 | 5.54 | Net Pump Seal Water Injection Flow Pump II, QS72 |
| 134 | 5.55 | Primary and Secondary Pressure (Data), PA38 & PA97S |
| 134 | 5.56 | Primary and Secondary Pressure (RELAP5), PA38 & PA97S |
| 135 | 5.57 | Break Mass Flow, CM05 |
| 135 | 5.57a | Break Mass Flow, CM05 (first 500 s) |
| 136 | 5.58 | Primary System Mass Inventory |
| 137 | 5.59 | Location of Heater Rod Thermocouples (TC) in Test A2-81 |
| 138 | 5.60 | Beam Geometry of LOBI-MOD2 Densitometer |
| 139 | 5.61 | Azimuthal Locations of Bypass Flow Paths in RPVM |
| 140 | 5.62 | Horizontal Flow Regime Map Used in RELAP5 Code |



1. INTRODUCTION

Since the occurrence of the TMI accident in 1979, the emphasis in light water reactor safety experiments such as Semiscale, LOFT and LOBI have shifted from large break loss-of-coolant experiments (LOCE) to consideration of small break LOCE phenomena. Several OECD member states showed their keen interest in the analysis of small break loss-of-coolant accidents. Based on their request the "OECD-CSNI Principal Working Group No. 2 on Transient and Breaks" during its meeting in October 1982, proposed one of the LOBI-MOD2 small break tests for the International Standard Problem No. 18 (ISP18). This proposal was approved by the CSNI during its plenary meeting in November 1982.

The objective of ISP18 was to perform LWR safety system computer code calculations for the post-test prediction of the results from a small break LOBI-MOD2 integral system loss-of-coolant experiment. The LOBI-MOD2 test facility is a 1:712 scaled model of a 1300 MWe pressurized water reactor of the KWU type.

The LOBI test A2-81 a 1 % cold leg break test, proposed for ISP18 was successfully performed in September 1984. The LOBI project is being executed in the Euratom Joint Research Centre, Ispra Establishment, Italy, in the framework of an R&D contract between the Commission of the European Communities, Brussels, Belgium and the Bundesminister für Forschung und Technologie, Bonn, F. R. Germany.

Using one of the first tests with the new LOBI-MOD2 facility for the ISP18 offered a rare opportunity to perform a "double-blind" exercise. For this purpose, not only the results of ISP18 test, but also the results of all LOBI-MOD2 tests preceding it, were withheld until after the completion of the prediction calculations. As a consequence, no particular code adaptation to the specific transient behaviour characteristics of the test facility could be performed by the ISP18 participants for this prediction calculation, which made ISP18 a "double-blind" exercise.

In order to further increase the challenge to the participants, the participants were provided with the original design drawings of the test facility components and systems instead of appropriately prepared excerpts

from those drawings. As a consequence, it was up to the code user to make his own excerpts as he considered most appropriate for the purpose of preparing the nodalization of the test facility and the input data set for the code calculations.

A total of 26 participants from 12 different countries took part in this exercise. 9 different computer codes were used for ISP18 predictions. The various participants used not only different codes, but even different versions of the same code. Table 1.1 shows the list of participants along with the code and computer facility used by them. The Karlsruhe Nuclear Research Centre as one of the participants completed in time the post-test prediction of the experiment using the RELAP5/MOD1/19 computer code. As proposed for ISP18, a total of 53 parameters of interest were predicted and results sent to LOBI project on transmittal tape in desired format.

This report describes the input model for RELAP5 used for ISP18 prediction and the steady state calculations and discusses the prediction results in comparison with experimental data. Furthermore, a summary of the LOBI-MOD2 facility description and a complete listing of input data cards are included.

2. FACILITY CONFIGURATION AND TEST SPECIFICATION

2.1 LOBI-MOD2 Test Facility

The LOBI facility /0/ is a high pressure integral system blowdown-refill test facility designed, constructed and operated in the Joint Research Centre of the European Communities, Ispra Establishment. It was commissioned in December 1979 and was operated until June 1982 in the MOD1 configuration. It was then extensively modified to accommodate new program requirements leading to the present MOD2 configuration.

Only a short description of the LOBI facility is given here. More details of the test facility are provided in Appendix A and can be found of course in the original LOBI publications /0/ to /15/.

The LOBI two loop test facility simulates the cooling system of a four loop 1300 MW(e) PWR of the Kraftwerk-Union design. One test loop, having three times the capacity in water volume and mass flow of the other, represents the three intact reactor loops. Pipe rupture of different sizes can be simulated at different locations within the broken loop.

Emergency core cooling water may be supplied by the high pressure injection system and the intermediate pressure accumulator injection. Provisions are made for cold leg or combined cold and hot leg ECC injection into both primary loops.

The power input, the primary circuit coolant mass flow and volume are scaled down from the reactor values by a factor of 712, leading to a 5.3 MW heating power and 28 kg/s core mass flow. All other most relevant quantities such as operating temperature, pressure and pressure drops along the flow paths have been maintained as closely as technically possible equal to the value of the reference plant. Also, the absolute heights and relative elevations of the individual system components have been kept at reactor values thus preserving the gravitational heads.

Both primary loops are active loops, each containing a main coolant pump and a steam generator (coolant mass flow rates are 21 kg/s and 7 kg/s for the intact and broken loop respectively resulting in 28 kg/s core mass

flow). An active secondary loop system contains two condensers simulating the reactor turbines, a cooler, the feedwater pump, and the auxiliary feedwater system. The normal operating conditions of the secondary cooling system are approximately 210 degree C feedwater temperature and 54 bar pressure (mass flow rates are 2.0 kg/s and 0.67 kg/s for the intact and broken loop respectively).

The MOD2 steam generators are designed especially to meet the requirements of small break tests and of special transients experiments. They contain major components such as inverted U-tubes, an annular downcomer and coarse and fine separators to model the geometry of the reference plant. The intact and broken loop steam generators contain 24 and 8 U-tubes respectively with corresponding 3.96 MW and 1.32 MW heat exchange power.

2.2 Test Configuration

For the small break test, designated as A2-81, the break position was located in the cold leg between main coolant pump and pressure vessel inlet. To simulate a 1 % break (equivalent to about 50 sq. cm rupture in the main coolant loop of the reference PWR), a break orifice of 3 mm dia was used. The break device installed at LOBI test facility consisted of a T-shaped insert connected across the main coolant pipe at the break location, a break orifice, a quick opening valve installed downstream of the break orifice and a discharge line which was heavily instrumented to provide the required information (e.g. density, velocity, etc.) for break flow calculations. The break was initiated by a quick opening, ball-type, valve flanged to the break insert on one side and to the discharge line on the other side.

In this test, the high pressure injection system was connected to intact loop cold leg simulating 2 out of 4 HPIS pumps. No accumulator was used. The pump seal water was continuously drained from upper plenum up to initiation of break. Thereafter the draining system was isolated. A pump locked rotor resistance in the broken loop was simulated by orifice plates inserted in a two-way valve located at the discharge side of the pump. The geometrical configuration for test A2-81 is shown in Fig. 2.1.

2.3 Initial Conditions

The test A2-81 was started from normal operation conditions. The initial conditions for the test were specified as follows /4/:

Primary side:

15.8 MPa	- pressure in the upper plenum
21.0/7.0 kg/	- coolant mass flow rates for the intact and broken loop respectively
294.0 C	- coolant temperature at the vessel inlet for the intact and broken loop respectively
5.28 MW	- core power
4.8 m	- collapsed liquid level in the pressurizer
346 C	- temperature of the pressurizer

Secondary side:

6.45 MPa	- pressure in the steam dome of both steam generators
2.0/0.67 kg/s	- feedwater mass flow rates for the intact and broken loop steam generator respectively
210 C	- feedwater temperature for both steam generators
3.6	- recirculation ratio (mass flow in downcomer / feedwater mass flow) for the intact and broken loop respectively

The instant of break opening start defined the test time "zero". The boundary conditions of the test were given by the sequence of events (see Table 2.1), and as functions of time

- the power drop, simulating the decay heat of the nuclear core (Table 2.2),
- the pump coast-down of the main coolant pumps (Table 2.3),
- the secondary pressure drop starting from 83 MPa according to the cooling down rate of 100 K/h.

Furthermore, as a function of primary pressure

- the mass flow of high pressure injection system (Table 2.4).

3. RELAP5 INPUT MODEL

3.1 RELAP5/MOD1 Computer Code

The light water reactor safety analysis computer code RELAP5/MOD1 is based on a one-dimensional, two-fluid, nonequilibrium hydrodynamic model. The major simplification of the two-phase flow model assumes the least massive phase within a control volume to be at saturation, which would be the case if that phase were just appearing or disappearing. This assumption allows the use of one overall energy equation. The overall energy equation contains a source term which couples the hydrodynamic model to the heat conduction model by convective heat transfer boundary conditions. The code contains special process models for choking, abrupt area changes, branching, pumps, accumulators, valves, annuli, and steam separators.

The code uses a one-dimensional finite difference formulation for both fluid path and heat path modelling. In the code, fluid paths are divided into a series of central control volumes connected by junctions. Mass and energy conservation relations are used over the central control volumes. The vector quantities such as liquid and vapor velocity are evaluated at the junctions or boundaries of the central control volumes. This discrete model is used to build up flow paths representative of the physical flow paths.

Heat conductors are divided axially into heat structures representative of the physical conductor geometry. Heat structures are then radially subdivided into mesh intervals according to the resolution required for the solution. The model uses a generalized one-dimensional conduction solution. The boundaries of the conductors can be adiabatic or coupled through convective heat transfer correlations to control volumes.

A comprehensive description of the computational models in the code and the input requirements as well as a users guide and checkout problems are included in the three volumes code manual /19,20,21/.

For the ISP18 prediction an IBM-version of cycle 19 of RELAP5/MOD1 was used. The IBM-version originated from a FACOM-version of RELAP5/MOD1 (cycle 1), which was introduced to KfK from the Japan Atomic Energy

Research Institute (JAERI) in 1982. Cycle 19 has been achieved as an update work consisting of conversion and application of the original update cards supplied by the code developers for the CYBER-176 version of RELAP5. More details of the code conversion work to IBM can be found in /28,29/.

3.2 General of Nodalization

A layout of the nodalization scheme for LOBI-MOD2 used for the ISPI8 prediction is shown in Figure 3.1, on which the various component numbers are identified and the relative elevations approximately are maintained. The nodalization was based on the geometrical data compiled in Table 3.1, which were developed from as-built blueprints enclosed in /1/. The node numbers in columns 2A/2B of Table 3.1 refer to the schematic view of the facility in Figures 3.2 to 3.6, which are simplified excerpts from the as-built drawings. The volume-related and junction-related data of the nodalization can be found in Tables 3.2 and 3.3, which detail the correspondence between the nodalization and the geometrical setting-up of Table 3.1.

The input data were organized in several groups according to component numbers:

- 100 series: Reactor pressure vessel model (RPVM) and upper head simulator (UHS)
- 200 series: Intact loop pipework (IL) and main coolant pump (MCP)
- 300 series: Broken loop pipework (BL), main coolant pump, and break assembly
- 400 series: Pressurizer with surge line
- 500 series: Secondary side of steam generator of intact loop (SG I)
- 600 series: Secondary side of steam generator of steam generator of broken loop (SG II)
- 700 series: Steam line with steam header
- 800 series: Injection and drainage systems of primary loops

The model consisted of 263 volumes, 272 junctions, and 297 heat structures. The nodalization was straightforward, however as close as possible

to the geometrical configuration of the facility. Through this detailed nodalization we hoped to ensure reliable results, without being forced to perform lengthy sensitivity studies required to validate coarser nodalizations.

Because of the influence of environmental heat losses and structural heat exchange on slow transients, a rather large number of heat structures have been included in the input model.

RELAP5 trip logic and control variables were used extensively to simulate the required boundary conditions, and to achieve by the help of special controllers the specified initial conditions.

A complete listing of the input data deck is enclosed (Appendix B).

3.3 Modelling of Reactor Pressure Vessel Model

The reactor pressure vessel model (RPVM) together with the upper head simulator (UHS) was modelled with 49 volumes and 67 heat structures as shown in Fig. 3.7.

The downcomer upper inlet annulus, represented by a branch (#100), connects to the downcomer, modelled as an annulus (#110) with 12 stacked volumes. The lower plenum was represented by a branch (#120) and connects to a single volume (#130), which describes the lower part of the core inlet box. The upper part of the core inlet box, modelled by a branch (#140), connects to the core, modelled by a pipe comprising 8 stacked volumes (#150). The upper plenum was modelled in three parts. The lower is a branch (#170) connected to the core channel, and the middle is a pipe with three volumes (#180) reaching the elevation of the centerline of the hot legs. The uppermost part is a branch (#190) with junctions to the outlet nozzles of the loop pipework.

In Fig. 3.8 the various core bypass flow paths are identified with 1 to 5. The 1.5 mm gap between the inner surface of the core barrel and the ceramics filler segments was modelled by a pipe with 6 stacked volumes (1). The two 5 mm dia holes in the core barrel in the upper section of the

vessel (3) were represented by a junction connecting the top of the inlet annular (#100) and the top of the upper plenum (#190). The hot leg nozzle clearance gaps were represented by two junctions (4 & 5) connecting the inlet annulus (#100) with the hot legs (#200, #300). The bypass flow paths through the upper head simulator(2) were modelled as follows.

The upper head vessel, modelled with 4 stacked pipe volumes, connects through a pipe component with two volumes (#195) to the upper plenum. It also connects upstream of the shut-off valve, represented by a motor valve (#197), through two single volumes (#193 and #192) to the downcomer upper annulus. The tube between the shut-off valve and top of the vessel was represented by a pipe component comprising 6 volumes (#194).

The electrically heated tube bundle was modelled by 8 heat structures representing the 5-step axial power profile shown in Fig. 3.9. Additional 8 heat slabs were included to represent the upper and lower extensions of the heater rod bundle outside the core section, which produce 13.6 % of the total power.

To account for the mass of metal and ceramics in RPVM and UHS further 51 heat structures have been included for the pressure vessel, the ceramics filler blocks, the core barrel, the lower and upper current connection plates, the UHS vessel, and the tubing walls. To model properly the honeycomb structure of the core barrel a pseudo-material was introduced. The number of nodes in the heat structures varied from 3 to 10.

3.4 Nodalization of Loops

17 volumes were used to represent the intact loop piping with pump, and 24 volumes for the broken loop including pump and break assembly. The pressurizer system was modelled by 12 volumes for the vessel and 13 for the surge line.

The single-phase homogeneous head and torque curves for the primary system coolant pumps, which are identical for both loops, and difference curves were taken from the LOBI-furnished data /14,15/ as well as the two-phase multiplier /5/. The locked rotor simulators in resistance position were

modelled by replacing the pump components by branch components (#250, #350) after the pumps have reached zero speed. The branch assumes smooth area change junctions with form loss coefficients of 20.0 for IL, and 55.0 for BL on each side, to account for the pump resistance and additionally the reduction of flow area to approximately 20 % due to orifice plates in the simulator of broken loop.

The break assembly was originally modelled by two junctions connecting the discharge volume to the volumes downstream and upstream of the break. Each junction was assigned one-half the total break flow area. A third junction with a flow area equal to that of the broken loop piping connected the upstream and downstream volumes, modelling the communicative nature of the break assembly. A motor valve, opening to full open position within 4 seconds as specified, connected the discharge volume to a time-dependent volume representing the boundary. This nodalization is identified by A in Figure 3.10. During steady state calculations nodalization A caused troubles due to heavy flow oscillations and unphysical conditions in the discharge volume. Therefore we used a simplified modelling identified by nodalization B in Figure 3.10. The only difference between the two nodalizations is that in nodalization B the break orifice is modelled by one junction having the full orifice flow area and connecting the volume downstream the break to the discharge volume. The discharge coefficients applied to the critical flow model at the break were chosen to be 1.0 for both, the discharge of subcooled water and two-phase mixture.

3.5 Steam Generator Nodalization

The steam generator nodalizations are shown in Figures 3.11 and 3.12. 32 volumes were used for the primary side lumping together all the U-tubes into a single flow path. 32 volumes also were used for the secondary side with a somewhat artificial nodalization in the upper riser and separator region. To model phase separation a separator component was used with junction assignments as recommended in /25/. Besides the 22 heat slabs modelling the U-tubes further 44 heat structures representing the tube sheet, the shroud, the filler tube, the separator housing, and the external wall are included in the model. The steam line connecting both steam generators and the steam header were modelled by 10 volumes.

3.6 System boundary

11 time-dependent volumes defined the boundary of the model representing the containment, main feedwater, condenser, pump seal water, seal water drainage, high pressure injection system (HPIS), atmosphere, and pressurizer.

The High Pressure Injection System (HPIS) was modelled by a time-dependent junction connected to the cold leg in the intact loop. The time-dependent junction used the upper plenum pressure as the independent search variable to model the flow versus pressure curve given earlier in Table 2.3.

The pump seal water injections into the main coolant pumps were modelled by time-dependent junctions connected to the discharge volumes of the pumps (#255, #355). The time-dependent junction used the primary pressure as the independent search variable to model the flow versus pressure curve given in Tab. 4.7. A time-dependent junction (#835) connects the upper plenum volume to a time-dependent volume (#840) to compensate for the pump seal water injection flow during steady state operation.

4. INITIALIZATION OF THE PROBLEM

4.1 General

The initial conditions for the test A2-81 were the normal operation conditions as for the reference plant. Specific RELAP5 calculations were performed to match these initial conditions, the measured pressure drops, environmental heat losses and bypass mass flows being a part of it. To achieve steady state conditions several "controllers" were used. They are not controllers in the sense of control theory; they are merely methods to control the values of specified parameters with the help of the RELAP5 control system capability.

First the initialization calculations were performed for the main components of the LOBI-MOD2 test facility separately, namely reactor pressure vessel model, the intact loop and broken loop steam generators. Subsequently, the intact loop and broken loop with main coolant pumps including steam generators and finally the complete system were initialized. It proved rather difficult to match simultaneously the primary and secondary side initial conditions. Because of lack of experience with RELAP5, a substantial effort was required to get the desired initial conditions measured during the test.

4.2 Pressure Differentials

In RELAP5 code, the pressure drop due to wall friction effects are computed from pipe roughness and hydraulic diameter data entered as input for each volume. These wall friction losses contribute significantly to system pressure drops.

Another significant contributor to the system pressure drops is the loss associated with pipe elbows, bends, obstructions (due to measurement inserts for instance) etc. The form loss coefficient is defined by the ratio of pressure drop (due to form loss) to the dynamic pressure in the flow area considered:

$$K = \Delta P / \left(\frac{\rho}{2} |v|^2 \right) \quad v: \text{average velocity}, \rho: \text{average fluid density}$$

We estimated these form losses carefully from /16/ based on the geometrical shape information given in the as-built drawings of the test facility. We usually divided the estimated loss coefficients equally to the nearest two junctions.

The final portion of system drop is due to area changes (e.g. expansion, contractions, orifices etc.). Besides hydraulic diameter, roughness and user-input loss coefficient, any change in flow area are modelled explicitly by using the option for abrupt area change model. The code then automatically calculates additional form losses in the direction of flow at these junctions using expansion and contraction formulas. Changes in piping sizes are usually modelled as abrupt area changes if the change occurs over a relatively short distances. For example, we have used abrupt area change model at steam generator plena and U-tubes. Another example where we have used the option of abrupt area change model is at the junctions between the vessel and the hot and cold legs.

The abrupt area change model mentioned above has been reported /25/ to cause unphysical behaviour under two phase flow conditions for large contraction/expansion ratios (throat ratios of the order of 0.01 or smaller) and also for branched flows where large differences in the flow area are involved. The symptoms of this trouble are flow oscillations and/or excessive pressure drop across the junction. These problems have most often been experienced in the modelling of leak paths where the flows are small, but merge with large flows in branch volume. An example is the leakage from the downcomer to the hot legs fo the LOBI test facility. The recommended approach for such cases is to use the smooth option for the junction and let the junction area default (the minimum area of the adjoining volume areas). With this specification it is necessary to enter user inputted form loss coefficient to give the proper flow rate and pressure drop relationship. The user inputted loss factor in terms of the nominal pressure drop ΔP , fluid density ρ , junction area A , and nominal mass flow rate \dot{m} is:

$$K = \Delta P / (\dot{m}^2 / 2 \rho A^2)$$

The value computed for K in this way has been found to be very large because the reference area is much larger than the actual flow area. To

simulate the bypass flows between the downcomer and hot legs in LOBI facility, we have used the above recommended approach and found no problems like flow oscillations etc.

We attempted to model all the flow area changes and local flow resistances very carefully. However, during steady state calculations at many locations the numbers have been adjusted in order to achieve the measured pressure drops.

In spite of careful estimation of form losses, as mentioned before, it was not possible to match the measured pressure drops in all flow paths. Thus we had to adjust these form loss coefficients and in some cases the values for hydraulic diameter and roughness to get the measured pressure drops. After substantial effort, we were able to achieve reasonable values for pressure drops. Tables 4.1 through 4.3 show the measured and calculated pressure drops for the reactor pressure vessel model and for intact/broken loop including the primary side of steam generators. In Figures 4.1 to 4.4 the various measurement locations and sections are shown.

On the steam generator secondary side, we tried hard to match simultaneously the pressure differentials and recirculation ratio (mass flow rate of downcomer / mass flow rate of feedwater). We were unsuccessful in getting measured recirculation ratio for the two steam generators properly. Our calculated recirculation ratio is 7.2 and 7.1 for the intact loop and broken loop steam generator respectively. The corresponding measured recirculation ratio is 6.5 and 4.5. The secondary side measured and calculated pressure differentials at different locations is shown in Table 4.8. As may be seen from this table, it was not possible to match all pressure differentials on the secondary side exactly.

4.3 Environmental Heat Loss

For long transients such as in small break tests, the environmental heat loss is quite important. The heat losses for the LOBI test facility were determined by heat loss tests and the results were documented and supplied to all participants /3/. The data provided to us were mostly based on estimates with a high degree of uncertainty in measurements and in the assump-

tions in calculating the conduction losses. Due to the importance of environmental heat losses, we tried to match the heat losses for the complete system by adjusting the heat transfer coefficients with the assumed boundary temperature of transfer coefficients with the assumed boundary temperature of 22 degree C. Table 4.4 shows the measured/estimated and calculated heat losses of the complete system. As may be seen from this table, our calculated heat loss is in good agreement with data. Estimates of heat losses provided by LOBI /32/ after the prediction calculation were different from the values given in /3/.

4.4 Bypass Flow Rates

Specific measurements were undertaken merely for an estimation of the bypass flows through the two 5 mm diameter holes and the hot leg nozzle clearance gaps in downcomer. Based on these measurements, which were performed with air at nearly atmospheric pressure, this bypass portion was estimated to be 2.4 to 3.7 % of nominal total mass flow of 28 kg/s. For the other bypass flow paths no estimates were available. Therefore the assumptions on additional bypass flows were somewhat uncertain. Table 4.5 shows the final bypass flows assumed in the steady state calculation.

After completion of the prediction the LOBI-team provided some information on probable bypass flows. It was considered that random misalignments of the ceramics fillers in the core barrel probably had the effect of reducing any flow in the 1.5 mm gap in the core barrel to a negligible amount. Then it was stated that the penetration gaps through the hot nozzles into downcomer had a tendency to close during the transient. 1 % bypass flow was considered as a reasonable value for the bypass via upper head pipework after closing the shut off valve before starting the transient. Thus our calculated value of 9.5 % for total core bypass flow used in the prediction (steady state) seems to be too high.

4.5 Primary Side Steady State

A small number of standardized parameters are normally used to determine primary side steady state conditions. These variables may include:

- core power
- primary side pressure
- hot leg temperature(s)
- cold leg temperature(s)
- core ΔT
- core flow
- loop mass flow(s)
- bypass flows
- pressurizer level or inventory
- pump speed(s)

According to the ISP18 specifications, the following quantities were actually used:

- core power (power input of heater rod bundle)
- pressure in upper plenum
- vessel inlet temperature in both loops
- mass flow rates in both loops
- water level in pressurizer
- fluid temperature in pressurizer

4.5.1 Core Power

Because in the LOBI test facility, the power generated by an electrically heated tube bundle in RPVM is very well known and simple to input, we did not use the core power as an adjustable parameter. The power input was kept fixed as specified.

4.5.2 Pressure

The absolute value of primary pressure was controlled with the help of a liquid filled, time-dependent volume in place of the vapor region of the pressurizer. This time-dependent volume provides the pressurizer pressure and supplies or absorbs water from the primary system as needed. (However, this time-dependent volume has been replaced by the normal vapor volumes at the initiation of the transient). We experienced no difficulty in getting the measured value of absolute pressure at the upper plenum of reactor vessel model.

4.5.3 Mass Flow Rates

To achieve the actual mass flows in the intact and broken loop, the pump speed was controlled with an integral function of the offset from desired loop flow. This pump speed controller was of the form:

$$\text{new speed} = \text{initial speed} + \text{constant} * \int (\text{desired mass flow} - \text{actual mass flow}) dt$$

The constant is an adjustable parameter chosen by trial and error to prevent the pump from overreacting to small system perturbations, but still allow convergence on the desired setpoint value in a reasonable length of time. The constant in our case has assumed the value of 20 and 60 for intact and broken loop respectively.

This pump speed controller worked smoothly and quickly. However, at the same time it was not possible to match exactly the pump speed measured during the test. Nevertheless, calculated values agreed very well with the measured pump speeds (Table 4.6).

4.5.4 Temperature

The absolute values of primary loop temperature is determined by the secondary side saturation temperature and by the temperature profile across the steam generator U-tube walls. Our first steady state calculations produced primary side temperatures that were significantly higher (5K) than specified (measured) values. These primary side temperatures were lowered somewhat by reducing the secondary side pressure from 6.54 MPa to 6.52 MPa.

However, the remaining discrepancy i.e. a high overall temperature difference between primary and secondary side was eliminated by increasing artificially the heat transfer area of the heat structure representing the steam generator tube bundle by approximately 10 % which is clearly unphysical. But the problem of matching primary and secondary side conditions simultaneously, encountered with RELAP5, is well known and has been addressed elsewhere /22/.

Regarding the temperature differentials between the hot and cold legs in both loops, there is small discrepancy which is probably within the experimental uncertainty (see Table 4.6).

4.6 Secondary Side Steady State

Just as in the primary system, discussed above, a small number of standardized parameters which are not all mutually independent normally determine secondary side steady state operating conditions. These variables may include:

- steam dome pressure
- saturation temperature
- feedwater temperature
- feedwater flow
- recirculation ratio
- liquid level
- liquid inventory

The variables we used for each steam generator included:

- steam dome pressure
- collapsed water level
- recirculation ratio
- feedwater flow
- feedwater temperature

We spent considerable time to get steady state and we were not able to satisfy all the specified conditions. The steady state controllers we have used for secondary side were:

- a steam flow controller to control the steam dome pressure;
- and
- a feedwater flow controller to control the liquid level/inventory


These two controllers helped us to control the values of specified parameters on the secondary side.

4.6.1 Secondary Pressure

As already mentioned, the secondary side pressure and associated saturation temperature directly determine the absolute value of the primary side temperature. The secondary side pressure may be controlled by adjusting the steam outflow, either by using a steam flow control valve or by connecting the steam dome to a large steam-filled time-dependent volume at the desired pressure and allowing the steam outlet junction mass flow to vary as required. We have used the latter controller for the two steam generators when initialized them separately as component and found this controller easy to use. However, we had to use the former controller when we tried to get steady state conditions for the complete system. This controller controls the stem position of the steam outlet valves (#705 & #715) according to the function (simplified):

$$\text{stem position} = \text{init. val.} + c1 \cdot f(\Delta P) + c2 \cdot f(\Delta P) \cdot dt$$

where ΔP is the deviation from desired steam pressure and f is a deadband function as shown in the Figure below:




As constants the values $c1 = 0.014$ and $c2 = 0.0015$ have been chosen.

4.6.2 Liquid Level

The feedwater flow into the secondary side balances the steam outflow in normal steady state operation. In addition, during steady state the liquid level / liquid inventory remains constant. The liquid level/inventory can be increased or decreased by altering the feedwater flow relative to the steam outflow until the desired values are reached. In our steady state calculations, we have used a feed flow controller of the form:

$$\text{feed flow rate} = f(\Delta L) * \text{steam flow}$$

where f is an amplifier function as shown in the Figure below.



This controller worked very well to achieve the desired liquid level and hence the liquid inventory in the secondary side of steam generators. At the same time, however, it was not possible to match the measured feed-water mass flow / steam outflow in the steam generators. The result of the effort achieving the desired initial conditions of the test is documented in Table 4.8.

5. COMPARISON OF RESULTS

5.1 Performance of Calculation

The RELAP5-precalculation of the ISP18 transient was performed without major problems. The code applied an average time step size of 0.02 sec. Several times during calculation excessive errors occurred at minimum time step size (10^{-10} sec). However, the calculation proceeded in a reasonable way; so we abstained from any action (renodalization or reduction of minimum time step size). Another problem caused termination of the calculation due to temperature outside the range of a thermal property table. After a minor modification of the code we successfully restarted the problem at point of failure. After a prologue of 440 sec steady state the transient calculation was started with the renodalization of the pressurizer and deactivation of the steady state controllers. At the instant of zero speed of main coolant pumps the pump components were replaced by branch components (compare Table 5.1).

The ratio of computing time to problem time was 37 using the 15 MIPS machine Siemens 7890 (synonymous with FUJITSU FACOM M380). For this rather high consumption of computing time not only the fine nodalization was responsible but also the code itself. The used IBM-version of RELAP5 is at least three times slower than the original CDC-version because of downgraded speed efficiency due to code conversion from CDC- to IBM-compatibility.

For completeness all of the requested prediction quantities are presented in overlay plots compared with experimental data curves. However the discussion of results will be confined to the major points.

5.2 Thermal Response of the Core

To start with the most important question in small break investigations, as far as safety margins are concerned, is to ask, whether the core was covered or not. In the experiment the core remained covered, and the heater rod surface temperatures followed the fluid temperature, which were at saturation. The same behaviour was predicted by RELAP5 (see Figures 5.33 to 5.38).

The calculated saturation temperature was lower than in the experiment, since saturation pressure was predicted to be lower than data after 600 s (see section 5.3). In the calculation temporary dryout occurred in the uppermost section of the heater rods, which results from high void fraction in upper plenum (see section 5.5).

5.3 Depressurization in Primary System

Due to a slightly faster initial depressurization in the calculation as in the experiment (Figure 5.2a), the core heating power starts to drop and the HPIS starts to operate slightly earlier than in the test. However, after these events the calculated depressurization decreases slightly and results in excellent agreement with the primary system pressure measured during the test upto around 600 seconds into the transient. The code, therefore, calculated the timings of coastdown and stoppage of the main coolant pumps quite accurately. See Table 5.2 of chronology of significant events.

In the test the pressure in the primary system remained always above the pressure of the secondary system. After the initial phase of blowdown the primary pressure was controlled by the cooldown conditions (100 K/h) on the secondary side (see Figure 5.55). Up to about 600 seconds the RELAP5 calculation predicted the primary pressure very well, however after this time up to 1200 seconds into transient the code calculated a higher system depressurization rate as compared to data (Figures 5.1 & 5.2). The calculated primary system pressure dropped even below the secondary side pressure at about 850 transient time (Figure 5.56). The crossing of the pressure curves strongly affected the behaviour of the steam generators. From this instant on the steam generators changed from heat sinks to heat sources. In the case of broken loop steam generator this reversed behaviour led to a stagnant liquid level on secondary side (Fig. 5.47). After 1200 seconds transient time the calculated depressurization rate was in good agreement with data decreasing somewhat after 2500 seconds, and the calculated primary pressure remained approximately 5 bars below the data through the rest of the transient.

In the experiment the calculated lower pressure throughout the transient implies the end of test event (system pressure 10 bar) earlier than experiment (Table 5.1). The predicted HPIS flow is also higher as compared to data (Fig. 5.5) because of HPIS flow dependence on primary system pressure.

5.4 Primary Mass Inventory

The break mass flow (Fig. 5.57) is one of the key parameters of the prediction. Unfortunately just this quantity could not be compared with experimental data, because the flow measurement data in the discharge line did not represent an average flow velocity due to phase separation. In exchange for break flow data the LOBI team determined the mass inventory in the primary side on the base of density and differential pressure measurements /31/.

On the basis of Figure 5.58, which was taken from /31/, we have roughly estimated the total cumulative mass loss through the break in the test. We assumed average values of 0.012 kg/s, 0.013 kg/s, and 0.16 kg/s for net pump seal water flow in intact and broken loop as well as HPIS flow respectively, and gathered from Fig. 5.58 a mass inventory deficiency of approximately 122 kg at 4000 s. Hence follows a break mass loss of 862 kg upto 4000 s in the test. The prediction yielded an average break mass flow of 0.25 kg/s (Fig. 5.57) and hence a loss of 1000 kg, which is 16 % higher than the estimated value from experimental data. As can be seen from Fig. 5.58 the predicted mass inventory development in time considerably deviated from the experimentally obtained curves. The calculation overpredicted the break flow within the period from 300 sec to 900 sec, which led to an early mass inventory minimum of 175 kg at 900 sec against 250 kg at 2400 sec in the experiment.

With the LOBI two-beam γ -densitometer two different fluid densities in horizontal pipes were measured. The special beam geometry is illustrated in Fig. 5.61. The data identified by DIA were recorded using the diametrically penetrating beam and PER identifies the data obtained from the peripherically crossing beam.

Considering the beam geometry of the LOBI-MOD2 γ -densitometer (Fig. 5.60) from the two-beam fluid density data (Fig. 5.21) in measurement position 26 between vessel and break the assumption can be made that the flow in the cold leg became stratified early after the end of the forced convection period (120 s). After 250 s the leak was first uncovered. From this instant high quality steam was discharged through the break. In the calculation, on the other hand, strong density oscillations in this period indicated that the code did not recognize stratification. Therefore in the calculation a uniform two-phase mixture was discharged, leading to a larger mass loss after break recovery than occurred in the experiment. Examination of the pressure responses in Figure 5.1 gives supporting evidence. The experiment showed a faster increase of depressurization rate starting at 100 seconds due to higher steam discharge. The calculation, on the other hand, showed an increase in depressurization rate from 750 up to 1200 seconds transient time corresponding to a temporary uncovering of the orifice during that period in the calculation.

5.5 Mass Distribution

There are several symptoms for an incorrect mass distribution in primary system predicted by the code, which can be derived from the plotted differential pressures and densities at different locations.

The U-tubes of the steam generator of intact loop were completely voided at about 1500 sec while the code calculated early (750 sec) complete voiding (Fig. 5.30). Similarly in steam generator II, the complete voiding occurred at about 2000 sec while the code calculated early (500 sec) complete voiding in the U-tubes (Fig. 5.31). Furthermore the differential pressure data indicate that both steam generators U-tubes started filling at about 3500 sec while the code predicted no refilling.

The hot leg densities for the two loops are shown in Figures 5.15 and 5.18. After 750 s in broken loop and 1000 s in the intact loop into transient time the code calculated completely draining of the hot legs and high densities in the cold legs (Fig. 5.17). The case is quite the reverse as the data show. Figure 5.29 indicates a calculated high vapor fraction in the upper plenum developing at a very early stage of the transient,

resulting in dryout or the heater rod surfaces at top levels above the heated section (Figure 5.37, 5.38), where still 8.4 % of total power is generated (compare Fig. 5.59).

A cause for the incorrectly calculated high densities in the cold legs especially in the broken loop might be a higher condensation rate of steam bypassed from the upper plenum to cold legs. The steam generated in the core and bypassed to upper downcomer was condensed to a large extent in inlet annulus.

Obviously in the calculation there was not enough steam flow via the broken loop cold leg directly to the break as in the experiment.

After the erroneously predicted loop seal clearance of the broken loop (Fig. 5.25 & 5.26) at 750 sec the steam accumulated in upper plenum could escape through hot leg of broken loop to the leak.

To understand why RELAP5 did not predict stratification in the cold leg of broken loop we consider Fig. 5.61, which is a schematic cross section of the vessel in the level of the hot and cold leg nozzles with identified azimuthal locations of the bypass flow paths. One can imagine that the flow regime in the downcomer was two-dimensional and asymmetrical in nature. Subcooled water entering the downcomer via the cold leg of intact loop established a cold stream downward filling the downcomer with subcooled water (Fig. 5.14).

As can be seen from Fig. 5.61 the bypass connections to downcomer lay mainly on the broken loop side. Therefore it can be assumed that the amount of steam bypassed from upper plenum to upper downcomer and arrived at the cold leg nozzle of broken loop was rather high because of reduced mixing with subcooled water stemming from HPIS and consequently low condensation rate. Therefore a continual stratified flow was formed with steam flow area large enough to supply the leak with high quality steam.

In contrast to physical reality the modelling with RELAP5 was one-dimensional as illustrated in Fig. 3.8. The inlet annulus was represented by a single, vertical oriented volume (branch component #100). Considering the period after 250 s into the transient the mass flow in cold leg between

RPVM and Break was determined by the discharge rate through the break, which was 0.45 kg/s yielding a mass flux of $265 \text{ kg/m}^2\text{-s}$. Looking into the horizontal flow regime map (Fig. 5.62) RELAP5 marked the flow regime as bubbly or slug flow, in any case not as stratified flow.

As a consequence the corresponding modifications of the momentum equation and of the choked flow model to account for vapour pull through and entrainment under stratified flow conditions was not active. Thus subcooled water or a two-phase mixture flowed out through the leak interrupted by temporary steam escapes. Probably this was the main reason for high break mass flow in the period from 250 s to 850 s resulting in a significant deviation of the precalculated system behaviour from the experimental findings.

6. CONCLUSIONS

The participation in the double blind prediction ISP18 proved to be a very useful exercise for us. The understanding of computer simulation of small break transients and the experience in using the RELAP5 code have increased considerably.

The RELAP5 input model used for the prediction was based on a straight-forward nodalization. The LOBI-MOD2 test facility geometry was modelled as closely as possible using a rather large number of control volumes and heat structures. The preparation of the input data set from the as-built drawings was very time consuming.

A substantial effort was needed in numerous steady state calculations to achieve acceptable initial conditions for the test. Various special controllers were used to bring it about. However we were not able to meet all the measured initial conditions simultaneously.

No specific major problems were encountered in performing the transient calculations, and with the handling of the code. However, excessive computer time was required to complete the ISP18 calculations.

The KfK prediction has predicted a covered core and corresponding heater rod surface temperatures following fluid saturation temperature throughout the transient similar as in experiment. In this respect, most important for safety related considerations, the prediction was acceptable. However, most of the local parameters like fluid densities were in good agreement with experimental data only up to 250 sec into the transient. Later on in the calculated transient the predicted mass distribution in the primary system drifted away from the experimental facts. Here and there the calculation just showed the opposite of the experimental behaviour.

The overall comparison of measured and predicted parameters clearly indicated that the code predicted a far too homogeneous system behaviour and that the gravity-dominated phase separation processes which are important in small break were not correctly modelled in the code. In most of the cases, the code has failed to predict properly the mass distribution during the transient.

There were several facts in the calculation which sharply contrasted with the experiment:

- 1) Drop of primary pressure below secondary pressure and resulting reversal of heat transfer in steam generators.
- 2) High break mass flow resulting in too low primary side mass inventory.
- 3) Complete draining of hot legs.
- 4) Clearance of broken loop seal.
- 5) Saturation conditions in pressure vessel downcomer and core entrance.

In our judgement all these discrepancies originated from the thermal-hydraulic phenomena in the upper region of the RPVM and cold leg nozzles, which RELAP5 could not properly conceive.

In the calculation the steam generated in the core section reached via various bypass flow paths the upper downcomer and was largely condensed there. The code was unable to develop a stable stratified flow in the broken loop cold leg between vessel and break with steam flow area large enough to supply the break orifice continuously with steam. As a consequence steam was accumulated in the upper plenum and could not escape before loop seal clearance of broken loop. As a consequence of the erroneously described flow regime upstream the leak the mass discharge was overpredicted.

To conclude, a one-dimensional modelling of an obvious two-dimensional flow behaviour in the downcomer was not adequate. The concerted acting of the following three special model features of RELAP5 was not satisfactory in the ISPI8 prediction.

the flow regime maps, especially the limiting condition for stratified flow,

the condensation model, especially under phase separation and stratification conditions,

the choked flow model, especially under stratified flow conditions in front of the throat.

The above conclusions are supplemented by the fact that, for ISP18, LOBI Project has also found similar results when using the same, unmodified version of RELAP5 code with a different input deck than ours /30/.

On the other hand it cannot be ruled out that the model discrepancies of RELAP5, mentioned above, can be mitigated using a quasi two-dimensional nodalization (splitted downcomer) and/or by taking a hand in the models itself tuning some influential model parameters.



T A B L E S

Table 1.1: List of ISP18 Participants

COUNTRY	ORGANISATION	DIRECTORY DESCRIPTOR	CODE	ORIG. CODE	COMPUTER	POWER (MIPS)
Austria	IRS, Seibersdorf	IRSA	RELAP4/MOD6	no	IBM 3081	10
Canada	AECL, Whiteshell	AECL	ATHENA MOD0.1	no	VAX 11-750	0.7
Belgium	Univ. Louvain, Tractionel Brussels	LTB-	RELAP5/MOD1/19	yes	CYBER 176	15
Finland	TRC, Helsinki	TRCF	RELAP5/MOD2/36	yes	CYBER 173	2.0
France	CEA, Fontenay CEA, Grenoble Framatome	CEAT CEAC FRAM	TRAC-PF1/MOD0/7 CATHARE FRACAS	no yes yes	CRAY-XMP CRAY-XMP CRAY-XMP	30 30 30
Germany	GRS, Garching KFK, Karlsruhe Rhein. Westf. TÜV, IKE-Stuttgart TÜV Bayern, TÜV Hannover TÜV Nord-D, Baden, Stuttgart TÜV Rheinland	GRS- KFK- RWIK TBYH TNBS TRHL	DRUFAN-M2A RELAP5/MOD1/19 RELAP5/MOD1/18 DRUFAN-M2 RELAP5/MOD1/18 DRUFAN-M2	yes yes no yes no yes	AMDAHL 470/V8 SIEMENS 7890 CRAY 1M AMDAHL 470/V8 CRAY 1M AMDAHL 470/V8	6.5 15 15 6.5 15 6.5
Italy	Università Pisa Università Pisa Ansaldo-NIRA, Genova	PIS4 PIS5 NIRA	RELAP4/MOD6 RELAP5/MOD1/19 RELAP5/MOD1/19	yes no yes	IBM 3081 IBM 3081 CYBER 170/845	10 10 5
Netherlands	ECN, Petten	ECN-	RELAP5/MOD2/21	yes	CYBER 855	8
Sweden	Studsvik, Nyköping	STUD	RELAP5/MOD2/36	yes	CYBER 180/835	3.8
Switzerland	EIR, Würenlingen	EIR-	RELAP5/MOD1/25	yes	CYBER 174	2.8

Table 1.1: List of ISP18 Participants (cont.)

COUNTRY	ORGANISATION	DIRECTORY DESCRIPTOR	CODE	ORIG.	COMPUTER CODE	POWER (MIPS)
United Kingdom	CEGB, Leatherhead	CEGB	RELAP5/MOD1/19	no	IBM 4341	1.2
	NII, Univ. Strathclyde	NII-	RELAP5/MOD1/19	yes	CDC 7600	15
	NNC, Whetstone	NNC-	NOTRUMP-ER	yes	CDC 7600	15
	UKAEA, Culcheth	UKC-	RELAP5/MOD1/19	no	CYBER 176	15
	UKAEA, Winfrith	UKW-	TRAC-PF1/MOD1	no	CRAY 1S	20
United States	INEL, Idaho Falls	INEL	RELAP5/MOD2/36	yes	CYBER 176	15
	LANL, Los Alamos	LANL	TRAC-PF1/MOD1	no		

Table 2.1 List of Most Important Trips/Events of LOBI-MOD2
Test A2-81 (ISP18)

No.	Time or Primary Pressure /other Trip Signal	Trip/Event
1	Sufficient time before time zero	Pressurizer cooling and pressurizer additional heating off (the loop is put in steady state conditions without both)
2	-240 sec	Start closure of shut-off valve in tube to top of upper head (closure time 8 sec)
3	-5 sec	Start closure of drain valve in upper plenum (closure time 8 sec)
4	0 sec	Normal pressurizer heating off
5	0 sec	Leak starts to open
6	4 sec	Leak is fully open
7	132 bar	Shut off valves in feed water lines and the shut-off valve in the steam line before the condenser starts to close (closure time 1.5 sec)
8	132 bar	Cooling down curve becomes active (at the rate of 100 K/hr)
9	132 bar + delay 0.5 s	Heating power starts to drop (Table 2.2)
10	117 bar + delay 35 s	HPIS starts (Table 2.4)
11	110 bar	Main coolant pumps (MCP) speed start to drop (Table 2.3)
12	Time at which MCP speed reaches zero	MCP speed zero
13	2 sec after 12	Mechanical brakes MCP in brake position
14	2 sec after 13	Locked rotor resistance simulator in broken loop in position "resistance"
15	10 bar	End of Test

Table 2.2 Heating Power of LOBI-MOD2 test A2-81 (ISP18)

After initiation of rupture, t=0 :
-power remains 100 % until power trip on low primary
pressure (132 bar) , with a delay of 0.5 sec
-after this heating powers drop according to following

Trip time (sec)	Heating power (%)
0	100.0
1	90.0
2	73.0
3	65.0
5	51.0
7	40.0
9	32.0
13	20.0
15	16.1
16	15.0
17	14.0
18	13.0
20	12.0
24	10.0
30	8.0
40	6.5
68	4.8
110	4.0
170	3.5
270	2.8
470	2.3
870	2.0
1000	1.9
2000	1.6
4000	1.3
6000	1.1
10000	1.0

Table 2.3 Main Coolant Pump Speed for LOBI-MOD2 test A2-81 (ISP18)

After initiation of rupture, t=0
-speed for both pumps remains constant 100% until
trip on low primary pressure (110 bar)
-thereafter both pumps coast down according to

Trip time (sec)	Normalized speed (%)
0	100
5	78
10	60
15	46
20	36
25	30
30	25
40	18
65	10
70	0

Table 2.4 HPIS Mass Flow as Function of Primary Pressure

Primary system Pressure (bar)	HPIS Flow ¹ (kg/s)
117	0.0000
111	0.0218
101	0.0520
91	0.0770
81	0.0980
71	0.1164
61	0.1320
51	0.1470
41	0.1600
31	0.1720
21	0.1830
11	0.1920
1	0.2010

¹ corresponds to 2 out of 4 pumps,
temperature of HPIS water: 30° C

TABLE 3.1

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO. 1	NODE NO. FROM 2A	NODE NO. TO 2B	DESCRIPTION 3	FLOW AREA ENTRY 4A	FLOW AREA EXIT 4B	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
PRIMARY COOLANT SYSTEM:												
INTACT LOOP HOT LEG												
001	001	002	VESSEL OUTLET NOZZLE WITH ECC INJECTION POINT	0.004266	0.233	0.000994	+3.520			0.0737		440
002	002	003	MEASUREMENT INSERT 11H	0.004223	0.600	0.0025338	+3.520			0.0737		415
003	003	004	HORIZ. PIPE BEND (30D, R=0.5) WITH SURGE LINE CONNECTION	0.004266	0.262	0.0011177	+3.520			0.0737		99% VOL. 415
004	004	005	PIPE	0.004266	1.730	0.0073802	+3.520			0.0737		415
005	005	006	PIPE BEND(90D,R=.115)	0.004266	0.181	0.0007721	+3.520	+3.635	0.0737		415	
006	006	007	MEASUREMENT INSERT 12V	0.004223	0.83	0.0035051	+3.635	+4.465	0.0737		373, 415	
STEAM GENERATOR I												
007	007	008	S.G.I INLET PIPE EXPANSION	0.004266	0.01088	0.082	0.0006010	+4.465	+4.547	0.0737	0.1177	373
008	008	009	S.G.I INLET PIPE	0.01088		1.334	0.0145139	+4.547	+5.881	0.1177		372, 373, COMM.1, FIG 372
009	009	010	S.G.I INLET PIPE BEND (35D, R=0.4)	0.009852		0.244	0.0024039	+5.881	+6.1105	0.1120		
010	010	011	S.G.I INLET CHAMBER			0.333	0.0095736	+6.1105	+6.415	0.112	0.156	372
011	011	012	S.G.I TUBE BUNDLE HOT SIDE (24 #)	0.007241		6.807	0.04929	+6.415	+13.222	0.0196		372
012	012	013	S.G.I TUBE BUNDLE TOP REGION	0.007241		0.5054	0.0036589	+13.222	+13.575	0.0196		372
013	013	014	S.G.I TUBE BUNDLE COLD SIDE	0.007241		6.807	0.04929	+13.215	+6.415	0.0196		372
014	014	015	S.G.I OUTLET CHAMBER			0.333	0.0095736	+6.415	+6.1105	0.156	0.112	372
015	015	016	S.G.I OUTLET PIPE BEND	0.009852		0.244	0.0024039	+6.1105	+5.881	0.1120		372
016	016	017	S.G.I OUTLET PIPE	0.01088		1.334	0.0145139	+5.881	+4.547	0.1177		372, 373

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO. 1	NODE NO. FROM 2A	NODE NO. TO 2B	DESCRIPTION 3	FLOW AREA ENTRY 4A	FLOW AREA EXIT 4B	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
017	017	018	S.G. I OUTLET PIPE CONTRACTION	0.01088	0.004266	0.082	0.0006010	+4.547	+4.465	0.1177	0.0737	373
INTACT LOOP COLD LEG												
018	018	019	MEASUREMENT INSERT 13V	0.004223		0.83	0.0035051	+4.465	+3.635	0.0737		373, 415 99% VOL. 415
019	019	020	PIPE	0.004266		2.4125	0.0102917	+3.635	+1.120	0.0737		
020	020	021	PIPE BEND(90D,R=0.115)	0.004266		0.1810	0.0007721	+1.120	+1.005	0.0737		415
021	021	022	PIPE	0.004266		0.6250	0.002666	+1.005		0.0737		415
022	022	023	PIPE BEND(90D,R=0.115)	0.004266		0.1810	0.0007721	+1.005	+1.120	0.0737		415
023	023	024	PIPE	0.004266		1.4310	0.0061046	+1.120	+2.551	0.0737		415
024	024	025	MEASUREMENT INSERT 14V WITH ADAPTOR	0.004223	0.003318	0.7690	0.0032201	+2.551	+3.320	0.0737	0.0650	415 99% VOL.
025	025	026	PUMP ONE	0.003318	0.003318	0.7142	0.00237	+3.320	+3.520	0.0650		415, COMM.1 (FIG.8)
026	026	027	MEASUREMENT INSERT 15H WITH ADAPTOR	0.003318	0.004223	0.7410	0.0031019	+3.520		0.0650	0.0737	415 99% VOL.
027	027	028	PIPE	0.004266		1.9670	0.0083912	+3.520		0.0737		415
028	028	029	HORIZ.BEND (48D24M,R=0.5) (ECC INJECTION POINT)	0.004266		0.4220	0.0018003	+3.520		0.0737		415
029	029	030	MEASUREMENT INSERT 16H	0.004223		0.6070	0.0025634	+3.520		0.0737		415 99% VOL.
VESSEL SIMULATOR												
030	030	031	VESSEL INLET NOZZLE	0.004266		0.1660	0.0007082	+3.520		0.0737		415, 440
031	031	032	INLET ANNULUS	0.011310		0.315	0.0035626	+3.520	+3.835	0.024		440
032	032A	041A	BYPASS BORES	0.000020				+3.835	+3.835	0.005		440
033	031	033	DOWNCOMER	0.011310		7.1170	0.08049	+3.520	-3.597	0.024		440

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO. 1	NODE NO. FROM 2A	NODE NO. TO 2B	DESCRIPTION 3	FLOW AREA ENTRY 4A	FLOW LENGTH 4B	VOLUME 5	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
034	033	034	LOWER PLENUM	0.06593	0.3730	0.0245926	-3.597	-3.970	0.3120		441
035	035	036	CORE BARREL TUBE UP TO CONNECTING PLATE	0.02946	0.5260	0.015614	-3.597	-3.063	0.1980		441
036	036	037	CORE BARREL TUBE UP TO HEATER RODS	0.02142	0.4760	0.0101122	-3.063	-2.595	0.1300		441
037	037	038	CORE	0.0081150	4.428	0.0359341	-2.595	+1.833	0.01347		441
038	037A	038A	CORE BYPASS	0.0009260	4.428	0.0041003	-2.595	+1.833	0.003		441
039	039	040	UPPER PLENUM LOWER VOLUME	0.025450	1.687	0.0557992	+1.833	+3.520	0.01347		441
040	040	041	UPPER PLENUM UPPER VOLUME	0.025450	0.315	0.0104189	+3.520	+3.835	0.01347		441
UPPER HEAD SIMULATOR											
041	041	042	PIPING FROM UPPER PLENUM TO UPPER HEAD BOTTOM FLANGE	0.000314	1.5	0.000471	+3.835	+4.350	0.02		VOL. IV FIG. 2, 3, 4
042	032	043	PIPING FROM INLET ANNULUS TO PIPING TEE	0.000314	0.8	0.000251	+3.835	+4.015	0.02		"
043	043	044	PIPING FROM TEE TO UPPER HEAD SIMULATOR WITH ORIFICE	0.000314	1.1	0.000220	+4.015	+4.350	0.02		"
044	043	045	PIPING FROM TEE TO UPPER HEAD WITH SHUT-OFF VALVE	0.000314	3.84	0.001178	+4.015	+7.056	0.02		"
045	044	045	UPPER HEAD SIMULATOR	0.011310	2.566	0.029021	+4.350	+7.056	0.120		460
BROKEN LOOP HOT LEG											
051	051	052	VESSEL OUTLET NOZZLE WITH ECC INJECTION POINT	0.001669	0.208	0.0003472	+3.520		0.0461		440
052	052	053	MEASUREMENT INSERT 21H WITH SURGE LINE CONNECTION	0.001652	1.150	0.0019002	+3.520		0.0461		415 99% VOL.
053	053	054	HORIZ. PIPE BEND (75D, R=0.15)	0.001669	0.1964	0.0003278	+3.520		0.0461		415
054	054	055	PIPE	0.001669	0.5805	0.0009689	+3.520		0.0461		415

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO.	NODE NO. FROM 1	NODE NO. TO 2A	DESCRIPTION 3	FLOW ENTRY 4A	AREA EXIT 4B	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
055	055	056	HORIZ. PIPE BEND (45D, R=0.15)	0.001669		0.1178	0.0001966	+3.520		0.0461		415
056	056	057	PIPE	0.001669		0.5008	0.0008358	+3.520		0.0461		415
057	057	058	PIPE BEND (90D, R=0.076)	0.001669		0.1194	0.0001993	0+3.52	0+3.596	0.0461		415
058	058	059	MEASUREMENT INSERT 22V	0.001652		0.8670	0.001423	+3.596	+4.4631	0.0461		370, 415
STEAM GENERATOR II												
059	059	060	S.G.II INLET PIPE EXPANSION	0.001669	0.003664	0.0415	0.0001078	+4.4631	+4.5045	0.0461	0.0683	99% VOL. 370, 371
060	060	061	S.G.II INLET PIPE	0.003664		1.6045	0.0058789	+4.5045	+6.1095	0.0683		370
061	061	062	S.G.II INLET PIPE BEND (35D, R=0.242)	0.003675		0.148	0.0005439	+6.1090	+6.248	0.0684		370
062	062	063	S.G.II INLET CHAMBER			0.2160	0.0025784	+6.248	+6.4455	0.0684	0.102	370
063	063	064	S.G.II TUBE BUNDLE HOT SIDE	0.002414		6.831	0.016488	+6.4455	+13.277	0.0196		370
064	064	065	S.G.II TUBE BUNDLE (TOP REGION)	0.002414		0.483	0.001166	+13.277	+13.5755	0.0196		370
065	065	066	S.G.II TUBE BUNDLE COLD SIDE	0.002414		6.831	0.01646	+13.277	+6.4455	0.0196		370
066	066	067	S.G.II OUTLET CHAMBER			0.2165	0.0025784	+6.4455	+6.248	0.102	0.0684	370
067	067	068	S.G.II OUTLET PIPE BEND (35D, R=0.242)	0.00366		0.148	0.00061	+6.248	+6.1090	0.0684	0.0684	370
068	068	069	S.G.II OUTLET PIPE	0.00366		1.6045	0.00570	+6.1090	+4.5045	0.0684		370
069	069	070	S.G.II OUTLET PIPE CONTRACTION	0.00366	0.001652	0.0415	0.0001078	+4.5045	+4.4631	0.0684	0.0461	370, 371

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO.	NODE NO.	FROM 2A	TO 2B	DESCRIPTION	FLOW AREA ENTRY 4A	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9	
1	2	3			4B	5	6	7A	7B	8A	8B		
BROKEN LOOP COLD LEG													
070	070	071		MEASUREMENT INSERT 23V	0.001652	0.8670	0.0014323	+4.4631	+3.596	0.0461		370	
071	071	072		PIPE	0.001669	2.0040	0.0034248	+3.596	+1.544	0.0461		99% VOL. 415	
072	072	073		BEND(90D,R=0.076)	0.001669	0.1194	0.0001993	+1.544	+1.468	0.0461		415	
073	073	074		PIPE	0.001669	0.7320	0.0012217	+1.468	+1.468	0.0461		415	
074	074	075		BEND(90D,R=0.076)	0.001669	0.1194	0.0001993	+1.468	+1.544	0.0461		415	
075	075	076		PIPE AND MEASUREMENT INSERT 24H WITH ADAPTOR	0.001652	0.003318	1.7280	0.002934	+1.544	+3.320	0.0461	0.0650	415
076	076	077		PUMP TWO	0.003318	0.7142	0.00237	+3.320	+3.520	0.0650	0.0650	415, COMM. 1 (FIG. 8)	
077	077	078		MEASUREMENT INSERT 25H WITH RESISTANCE SIMULATOR	0.003318	0.001652	1.2830	0.0021195	+3.520	+3.520	0.0650	0.0461	415
078	078	079		PIPE BEND(90D,R=0.076)	0.001669	0.1194	0.0001993	+3.520	+3.520	0.0461		99% VOL. 415	
079	079	080		PIPE	0.001669	0.3580	0.0005975	+3.520	+3.520	0.0461		302, 415	
080	080	081		PIPE BEND(90D,R=0.076)	0.001669	0.1194	0.0001993	+3.520	+3.520	0.0461		302	
081	081	082		LEAK ASSEMBLY	0.001669	0.4500	0.0007511	+3.520	+3.520	0.0461		302	
082	082	083		PIPE BEND(30D,R=0.076)	0.001669	0.0398	0.000066	+3.520	+3.520	0.0461		302	
083	083	084		MEASUREMENT INSERT 26H	0.001652	1.190	0.0019659	+3.520	+3.520	0.0461		415	
084	084	031		VESSEL INLET NOZZLE	0.001669	0.151	0.000252	+3.520	+3.520	0.0461		99% VOL. 415	
085	085	086		LEAK DISCHARGE LINE WITH MEASUREMENT INSERT 05H	0.001652	1.452		+3.52	+3.401	0.0461		433, 434 99% VOL.	

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO.	NODE NO. FROM 2A	NODE NO. TO 2B	DESCRIPTION	FLOW AREA ENTRY 4A	FLOW AREA EXIT 4B	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
PRESSURIZATION SYSTEM												
090	090	092	SURGE LINE I.L. TO PIPING TEE	0.000137		2.7535	0.000377	+3.520	+1.020	0.0132		MINUT.,APP
091	091	092	SURGE LINE B.L. TO PIPING TEE	0.000137		5.196	0.000711	+3.520	+1.020	0.0132		MINUT.,APP
092	092	093	SURGE LINE FROM TEE TO PRESSURIZER	0.000137		4.2505	0.000582	+1.020	+3.790	0.0132		MINUT.,APP
093	093	094	PRESSURIZER VESSEL LOWER VOLUME	0.006346		0.790	0.0050131	+3.000	+3.790	0.0260		5521
094	094	095	PRESS.VESSEL VOLUME UP TO END OF HEATERS	0.008227		0.585	0.004813	+3.790	+4.375	0.032		5521
095	095	096	PRESS. VESSEL UPPER VOLUME	0.011962		6.355	0.0760237	+4.375	+10.730	0.124		5521
SECONDARY COOLANT SYSTEM:												
STEAM GENERATOR I (I.L.)												
100	100	101	FEEDWATER INLET ANNULUS	0.00275		2.0577	0.00565	+13.8565		0.0532		373
101	101	102A	DISTRIBUTION TUBES(32)	0.00161		0.2200	0.0003539	+13.8565	+13.907	0.008		373
102	102	103	DOWNCOMER NARROW REGION	0.01195		7.4020	0.088448	+6.505	+13.907	0.024		372
103	103	104	BOILER LOWER VOLUME	0.02946		6.720	0.19800	+6.505	+13.225	0.022		372
104	104	105	BOILER TUBE BEND REGION	0.049425		0.361	0.0178424	+13.225	+13.586	0.022		372
105	105	106	BOILER UP TO CONTRACTION	0.07116	0.03398	0.172	0.00885	+14.148	+14.320	0.301	0.208	372
106	106	107	TOP OF BOILER	0.07116		1.290	0.05000	+14.320	+15.610			372
107	107	108	COARSE SEPARATOR	0.0387								

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO.	NODE NO. FROM 1 2A	NODE NO. TO 2B	DESCRIPTION 3	FLOW ENTRY 4A	AREA EXIT 4B	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
108	108A	109	FINE SEPARATOR	0.05024		0.3	0.01507	+15.981	+16.281	0.02		372
109	102	110	DOWNCOMER	0.0589		0.241	0.01421	+13.907	+14.148	0.105		372
110	110	111	DOWNCOMER UPPER VOLUME	0.05896	0.09673	0.172	0.01339	+14.148	+14.320	0.410		372
111	111	112	ANNULAR VOLUME OUTSIDE COARSE SEPARATOR	0.115721		1.29	0.14928	+14.320	+15.610	0.237		372
112	112	113	VOLUME OUTSIDE FINE SEPARATOR	0.1387		0.671	0.09307	+15.610	+16.281	0.419		372
113	113	114	STEAM DOME LOWER VOLUME	0.17129		0.114	0.0195271	+16.281	+16.395	0.467		372
114	114	115	STEAM DOME UPPER VOLUME	0.147638		0.315	0.0465059	+16.395	+16.710	0.461		372
STEAM GENERATOR II (B.L.)												
120	120	121	FEEDWATER INLET ANNULUS	0.001319		1.3352	0.0017612	+13.780		0.035		371
121	121	122	DISTRIBUTION TUBES(20)	0.00066		0.145	0.00010	+13.780	+13.810	0.0065		371
122	122	123	DOWNCOMER NARROW REGION	0.00396		7.304	0.0289122	+6.506	+13.810	0.0120		371
123	123	124	BOILER UP TO UPPER BORDER OF FILLER TUBE	0.009364		6.720	0.0629309	+6.506	+13.226			370
124	124	125	BOILER UP TO HIGHEST TUBE	0.025797		0.361	0.0092868	+13.226	+13.587			370
125	125	126	BOILER UP TO CONTRACTION	0.03173		0.424	0.0134835	+13.587	+14.011	0.201		370
126	126	127	TOP OF BOILER	0.03173	0.01287	0.137	0.00296	+14.011	+14.148	0.201	0.128	370
127	127	128	COARSE SEPARATOR	0.01441		1.388	0.02000	+14.148	+15.536			370
128	128	129	FINE SEPARATOR	0.01529		0.370	0.00565	+16.121	+16.491			370

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO. 1	NODE NO. FROM 2A	NODE NO. TO 2B	DESCRIPTION 3	FLOW AREA ENTRY 4A	FLOW AREA EXIT 4B	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
129	129	130	DOWNCOMER ABOVE NARROW REGION	0.01218		0.201	0.002448	+13.810	+14.011	0.035		370
130	131	132	DOWNCOMER UPPER VOLUME	0.01218	0.03138	0.137	0.00298	+14.011	+14.148	0.035		370
132	132	133	ANNULUS OUTSIDE COARSE SEPARATOR	0.03285		1.388	0.04560	+14.148	+15.536	0.130		370
133	133	134	VOLUME OUTSIDE FINE SEPARATOR	0.04145		0.955	0.039584	+15.536	+16.491	0.120		370
134	134	135	STEAM DOME LOWER VOLUME	0.0572		0.041	0.0023475	+16.491	+16.532	0.270		370
135	135	136	STEAM DOME UPPER VOLUME	0.051695		0.190	0.009822	+16.532	+16.722	0.270		370
STEAM LINE WITH HEADER												
140	140	141	S.G.I STEAM NOZZLE	0.003728		0.129	0.0004809	+16.395		0.0689		372
141	141	142	STRAIGHT PIPE	0.003728		0.645	0.0024096	+16.359		0.0689		407
142	142	143	PIPE BEND	0.003728		0.181	0.006748	+16.359	+16.398	0.0689		407
143	143	144	STRAIGHT PIPE WITH COMPENSATORS AND RELIEF LINE CONNECTION	0.003728		1.245	0.0046414	+16.398	+16.425	0.0689		407
144	144	145	PIPE BEND	0.003728		0.181	0.0006748	+16.425	+16.428	0.0689		407
145	145	146	STRAIGHT PIPE	0.003728		0.585	0.0021809	+16.428		0.0689		407
146	146	147	MEASUREMENT INSERT 65H	0.004560		2.684	0.0149158	+16.428		0.0762		407
147	147	147	VALVE	0.002290		0.420	0.0009618	+16.428		0.054		407
148	148	149	CURVED PIPE	0.003728		0.250	0.0009320	+16.425	+16.290	0.0689		407
150	150	151	S.G.II STEAM NOZZLE	0.001459		0.117	0.0001707	+16.532		0.0431		370
151	151	152	STRAIGHT PIPE WITH COMPENSATORS AND RELIEF LINE CONNECTION	0.001459		1.578	0.0023023	+16.532	+16.556	0.0431		407
152	152	153	PIPE BEND	0.001459		0.113	0.0001649	+16.556	+16.558	0.0431		407

TABLE 3.1 (CONTINUED)

GEOMETRICAL DATA FOR LOBI-MOD2 FACILITY
(DIMENSIONS IN m)

PIECE NO.	NODE NO. FROM 1	NODE NO. TO 2A	DESCRIPTION 3	FLOW AREA ENTRY 4A	FLOW LENGTH 5	VOLUME 6	ELEVATION ENTRY 7A	ELEVATION EXIT 7B	DIAMETER ENTRY 8A	DIAMETER EXIT 8B	DRAWING N COMMENTS 9
153	153	154	STRAIGHT PIPE	0.001459	0.356	0.0005194	+16.558		0.0431		407
154	154	155	PIPE BEND	0.001459	0.113	0.0001649	+16.558	+16.560	0.0431		407
155	155	156	STRAIGHT PIPE	0.001459	0.196	0.0002860	+16.560	+16.563	0.0431		407
156	156	157	PIPE BEND	0.001459	0.113	0.0001649	+16.563	+16.565	0.0431		407
157	157	158	STRAIGHT PIPE	0.001459	0.578	0.0008433	+16.565				
158	158	159	MEASUREMENT INSERT 66H	0.001787	1.977	0.0041941	+16.565		0.0477		407
159	159	160	VALVE	0.001439	0.370	0.0005324	+16.565		0.0428		407
160	160	161	PIPE BEND	0.001459	0.320	0.0004669	+16.565	+16.290	0.0431		407
170	170	171	HEADER	0.004608	1.660	0.0076493	+16.290		0.0766		428

TABLE 3.2

 RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
 (DIMENSIONS IN m)

COMPONENT 1A	NUMBER 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
REACTOR PRESSURE VESSEL MODEL (RPVM)										
100		B	INLET ANNULUS		0.3150	0.0035626	+90.000	+0.3150		
110	01	A	DOWNCOMER	0.011310	0.4218		-90.000	-0.4218		
	T0									
	04									
05				0.011310	0.7400		-90.000	-0.7400		
06				0.011310	0.6630		-90.000	-0.6630		
07				0.011310	0.8750		-90.000	-0.8750		
08										
09				0.011310	0.6630		-90.000	-0.6630		
10				0.011310	0.6120		-90.000	-0.6120		
11				0.011310	0.4720		-90.000	-0.4720		
12				0.011310	0.5300		-90.000	-0.5300		
120		B	LOWER PLENUM		0.3730	0.0245926	+90.000	+0.3730		
130		SV	CORE INLET(LOWER VOL)		0.5300	0.015614	+90.000	+0.5300		
140		B	CORE INLET(UPPER VOL)		0.4720	0.0101112	+90.000	+0.4720		
150	01	P	CORE (HEATED TUBE BUNDLES)	0.008115	0.6120		+90.000	+0.6120		
	02			0.008115	0.6630		+90.000	+0.6630		
	T0									
	06									
03				0.008115	0.4375		+90.000	+0.4375		
06										
07				0.008115	0.6630		+90.000	+0.6630		
08				0.008115	0.7400		+90.000	+0.7400		

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
160	01	P	CORE BYPASS	0.000926	0.6120		+90.000	+0.6120	0.0030	038
	02			0.000926	0.6630		+90.000	+0.6630	0.0030	038
	03			0.000926	0.8750		+90.000	+0.8750	0.0030	038
	TO 04									
	05			0.000926	0.6630		+90.000	+0.6630	0.0030	038
	06			0.000926	0.7400		+90.000	+0.7400	0.0030	038
170		B	UPPER PLENUM	0.025450	0.4218		+90.000	+0.4218	0.0440	039
180	01 TO 03	P	LOWER VOLUME	0.025500	0.4218		+90.000	+0.4218	0.0350	039
			UPPER PLENUM							
190		B	MIDDLE VOLUMES	0.025450	0.3150		+90.000	+0.3150	0.0350	040
			UPPER HEAD SIMULATOR WITH PIPEWORK							
192		SV	UPPER HEAD INLET TUBE UPTO TEE	0.000314	0.9554		+06.008	+0.1000	0.0200	
193		B	UPPER HEAD BYPASS WITH ORIFICE	0.000314	0.8600		-22.926	-0.3350	0.0200	
194	01 TO 05	P	UPPER HEAD INLET TUBE FROM TEE	0.000314	0.6400		+90.000	+0.6400	0.0200	044
195	01 02	P	PIPING FROM UPPER PLENUM TO UPPER HEAD	0.000314	0.7013		-38.336	-0.4350	0.0200	041
					0.7000		+00.000	+0.0000	0.0200	041
196	01 02 TO 04	P	UPPER HEAD VESSEL	0.011310	0.7660		-90.000	-0.7660	0.1200	045
					0.6466		-90.000	-0.6466	0.1200	045

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
INTACT LOOP PIPEWORK										
200	B		VESSEL OUTLET NOZZLE		0.8330	0.0035278	+00.275	+0.0040		0.0737 001,002
210	B		CONNECTION WITH PRESSURISER	0.004266	1.9920		+00.201	+0.0070		0.0737 003,004
220	SV		PIPE INLET TO STEAM/G		1.0110	0.0042772	+67.494	+0.9340		0.0737 005,006
230	01 T0 03	P	STEAM GENERATOR		0.4150	0.0043797	+90.000	+0.4150	0.1120	007
	04				0.4150	0.0043797	+74.038	+0.3990	0.1120	009
	05				0.3330	0.0095736	+66.336	+0.3050	0.1560	010
	06 T0 15				0.6190	0.0044823	+90.000	+0.6190	0.0196	011
	16				0.8697	0.0062977	+90.000	+0.8697	0.0196	011,012
	17				0.8697	0.0062977	-90.000	-0.8697	0.0196	012,013
	18 T0 27				0.6190	0.0044823	-90.000	-0.6190	0.0196	013
	28				0.3330	0.0095736	-66.336	-0.3050	0.1560	014
	29				0.4150	0.0043797	-74.038	-0.3990	0.1120	015
	30 T0 32				0.4150	0.0043797	-90.000	-0.4150	0.1120	017

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
240	01	P	PIPE UPTO PUMP INLET		0.8300	0.0035051	-90.000	-0.8300	0.0737	018
	02				0.8040	0.0034299	-90.000	-0.8040	0.0737	019
	T0									
	03									
	04				1.0880	0.0046414	-69.941	-1.0220	0.0737	019,020
	05				0.6250	0.0026663	+00.000	+0.0000	0.0737	021
	06				0.8970	0.0038244	+67.884	+0.8310	0.0737	022
	07				0.7160	0.0030523	+90.000	+0.7160	0.0737	023
	08				0.7681	0.0032201	+90.000	+0.7681	0.0737	024
250		PP	PUMP	0.003318		0.0023700	+17.140	+0.2105	0.0650	025
255		B	PIPE		0.7410	0.0031019	-00.348	-0.0045	0.0737	026
260	01	P	PIPE		0.7960	0.0033972	-00.048	-0.00067	0.0737	027,028
	T0									
	03									
270		B	VESSEL INLET NOZZLE		0.7730	0.0032715	-00.297	-0.0040	0.0737	029,030

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

COMPONENT 1A	NUMBER 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
BROKEN LOOP PIPEWORK WITH BREAK ASSEMBLY										
300	01	P	VESSEL OUTLET		0.6790	0.0011237	-00.190	-0.0023	0.0461	
	T0									
	02									
	03		HOT LEG PIPING		0.7770	0.0012967	+00.369	+0.0050	0.0461	051-058
	04				0.7380	0.0012207	+05.911	+0.0760		
	05		PIPE INLET TO STEAM/G		0.8675	0.0014341	+90.000	+0.8675	0.0461	
330	01	P	STEAM GENERATOR		0.4490	0.0016057	+90.000	+0.4490	0.0684	059
	T0									
	03									
	04				0.4490	0.0016057	+77.291	+0.4380	0.0684	061
	05				0.2160	0.0025784	+66.444	+0.1980	0.1020	062
	06				0.6210	0.0014989	+90.000	+0.6210	0.0196	063
	T0									
	15									
	16				0.8625	0.0020819	+90.000	+0.8625	0.0196	063,064
	17				0.8625	0.0020819	-90.000	-0.8625	0.0196	064,065
	18				0.6210	0.0014989	-90.000	-0.6210	0.0196	065
	T0									
	27									
	28				0.2160	0.0025784	-66.444	-0.1980	0.1020	066
	29				0.4490	0.0016057	-77.291	-0.4380	0.0684	067
	30				0.4490	0.0016057	-90.000	-0.4490	0.0684	069
	T0									
	32									

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
340	01 TO 03	P	PIPE UPTO PUMP INLET		0.7300	0.0012143	-90.000	-0.7300	0.0461	070,071
	04				0.8010	0.0014135	-71.147	-0.7580	0.0461	071,072
	05			0.001669	0.7320		+00.000	+0.0000	0.0461	073
	06				0.6630	0.0011773	+69.251	+0.6200	0.0461	074
	07 TO 08				0.5920	0.0009780	+90.000	+0.5920	0.0461	075
	350 355	PP B	PUMP PIPE	0.003318 0.001669	0.6415	0.0023700	+15.260 -00.134	+0.1880 -0.0015	0.0650 0.0461	076 077-080
360	01	P	PIPE WITH MEASUREMENT INSERT & RESISTANCE SIMULATOR	0.001669	0.6415		-00.134	-0.0015	0.0461	
	02 TO 03				0.2984		+00.288	+0.0015		
370	B		LEAK ASSEMBLY I	0.001669	0.2250	0.0003755	+00.000	+0.0000	0.0461	081
*80	01 TO 04	P	LEAK DISCHARGE LINE WITH MEASUREMENT INSERT		0.3400	0.0005617	-05.062	-0.0300	0.0461	085
390	B		LEAK ASSEMBLY II	0.001669	0.2250	0.0003755	+00.000	+0.0000	0.0461	081
395	01 TO 02	P	MEASUREMENT INSERT		0.3170	0.0005247	+00.499	+0.0028	0.0461	
	03		VESSEL INLET		0.7467	0.0012350	+00.499	+0.0065	0.0461	082-084

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
PRESSURIZER WITH SURGE LINE										
400	01	P	SURGE LINE	0.000137	0.7000		-45.585	-0.5000	0.0132	090
	02				0.5000		-90.000	-0.5000		092
	T0									
	04									
	05									
	06									
	07									
	T0									
	11									
	12									
	13									
410		B	PRESSURISER VESSEL LOWER VOLUME	0.006346	0.7900		+90.000	+0.7900	0.0260	093
420	01	P	PRESSURISER VESSEL UPTO END OF HEATERS	0.008227	0.5850		+90.000	+0.5850	0.0320	094
	02		PRESSURISER VESSEL UPTO WATER LEVEL	0.011962	0.6375		+90.000	+0.6375	0.1240	
	T0									
	07									
	08									
	T0		PRESSURISER VESSEL UPPER VOLUME (STEAM REGION)		0.6325		+90.000	+0.6325	0.1240	
	11									

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
STEAM GENERATOR I (I. L) SECONDARY SIDE										
505		SV	FEED WATER INLET RING	0.011698	0.5140	0.0060126	+00.000	+0.0000	0.0532	100, 101
510	01	A	DOWNCOMER	0.011950	0.8697		-90.000	-0.8697	0.0240	102
02 TO 10					0.6190		-90.000	-0.6190	0.0240	102
11					0.5290		-90.000	-0.5290	0.0240	102
520	01	P	BOILER	0.029460	0.5290		+90.000	+0.5290	0.0220	103
02 TO 10				0.029460	0.6190		+90.000	+0.6190	0.0220	
11				0.0351860	0.8697		+90.000	+0.8697	0.0220	
12					0.4327	0.0321193	+90.000	+0.4327	0.3010	
13					0.8430	0.0388078	+90.000	+0.8430	0.2080	
14				0.038760	0.8600		+90.000	+0.8600	0.3840	
15				0.084842	0.6710		+90.000	+0.6710	0.1870	112
530		S	SEPARATOR	0.086445	0.6710		+90.000	+0.6710	0.0200	
540	01	A	DOWNCOMER	0.115721	0.8600		-90.000	-0.8600	0.0830	108, 112
02										
550		B	DOWNCOMER	0.091767	0.8430		-90.000	-0.8430	0.1050	
				0.011950	0.4327		-90.000	-0.4327	0.0240	102
560		B	STEAM DOME		0.4290	0.0660335	+90.000	+0.4290	0.4610	113, 114

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

NUMBER COMPONENT 1A	VOL. 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
STEAM GENERATOR II (B. L) SECONDARY SIDE										
605		SV	FEED WATER INLET RING	0.002788	0.6676	0.0018612	+00.000	+0.0000	0.0350	120, 121
610	01	A	DOWNCOMER	0.003960	0.5773		-90.000	-0.5773	0.0120	122
	02			0.003960	0.6210		-90.000	-0.6210	0.0120	122
	T0									
	10									
	11			0.003960	0.5605		-90.000	-0.5605	0.0120	122
620	01	P	BOILER	0.009364	0.5605		+90.000	+0.5605	0.0220	123
	02			0.009364	0.6210		+90.000	+0.6210	0.0220	
	T0									
	10									
	11			0.0188043	0.5773		+90.000	+0.5773	0.0220	124
	T0									
	12									
	13			0.0133512	0.8006		+90.000	+0.8006	0.1280	125, 126
	14			0.01444080	0.9254	0.0133333	+90.000	+0.9254	0.2050	132
	15			0.0312170	0.9550		+90.000	+0.9550	0.1200	133
630		S	SEPARATOR	0.026020	0.9550		+90.000	+0.9550	0.0100	128
640	01	A	DOWNCOMER	0.032850	0.9254		-90.000	-0.9254	0.0650	133
	02			0.025761	0.8006		-90.000	-0.8006	0.0350	129, 130
650		B	DOWNCOMER	0.003960	0.5773		-90.000	-0.5773		
660		B	STEAM DOME		0.2300	0.0121690	+90.000	+0.2300	0.2640	134, 135

TABLE 3.2 (CONTINUED)

RELAP5/MOD1 VOLUME RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81.
(DIMENSIONS IN m)

COMPONENT 1A	NUMBER 1B	TYPE 2	DESCRIPTION 3	AREA 4	LENGTH 5	VOLUME 6	VERT. ANGLE 7	ELEVAT. CHANGE 8	HYDR. DIA. 9	PIECE NO. 10
STEAM LINES AND HEADER										
700	01	P	S.G. I STEAMLINE	0.003728	1.4870		+00.000	+0.000	0.0689	140, 141
	02			0.003728	1.4790				0.0689	142
	03			0.004778	1.2020				0.0780	143
	04			0.004778	0.9770				0.0780	146
701		B	HEADER INLET	0.0037286	1.1730		-09.016	-0.105	0.0689	147, 148
710	01	P	S.G. II STEAM LINE	0.001459	1.6955		+00.000	+0.000	0.0431	
	02			0.001459	1.4690		+00.000	+0.000	0.0431	150-158
	03			0.001459	1.4970		+00.000	+0.000	0.0431	
711		B	HEADER INLET	0.001459	1.0130		-20.532	-0.242	0.0428	154, 155 159, 160
720		B	HEADER	0.004608	1.6600		+00.000	+0.000	0.0766	170

TABLE 3.3

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
REACTOR PRESSURE VESSEL MODEL											
100	B	01	INLET ANNULUS TO DOWNCOMER	10000	11000	0.009240	00.00	00.00	0100	031	
		02	INLET ANNULUS TO UPPER HEAD	10001	19200	0.0	01.93	02.43	0000	032	
		03	INTACT LOOP TO INLET ANNULUS	27001	10000	0.002253	00.00	00.00	0100	031	3-4, 11-6, \$
		04	BROKEN LOOP TO INLET ANNULUS	39501	10000	0.000796	00.00	00.00	0100	031	3-4, 11-6, \$
		05	INLET ANNULUS TO INTACT LOOP	10000	20000	0.0		20000.00	0000		
		06	INLET ANNULUS TO BROKEN LOOP	10000	30000	0.0		16000.00	0000		
110	A	01 TO 11	DOWNCOMER			0.0	00.00	00.00	0000		
120	B	01	DOWNCOMER TO LOWER PLENUM	11001	12001	0.0	01.24	00.65	0000	033	
		02	LOWER PLENUM TO CORE INLET	12001	13000	0.0	00.63	01.20	0000	035	
140	B	01	CORE INLET	13001	14000	0.0	05.52	05.50	0000	036	4-14
		02	CORE INLET TO CORE	14001	15000	0.0	05.52	05.50	0000	037	4-14
		03	CORE INLET TO BYPASS	14001	16000	0.0	50.00	50.00	0000	037A	
150	P	01 TO 07	CORE			0.007350	00.00	00.00	0100		
160	P	01 TO 05	CORE BYPASS			0.0	00.00	00.00	0000		
170	B	01	CORE TO UPPER PLENUM(LOWER VOL)	15001	17000	0.007350	00.00	00.00	0100	038	
		02	CORE BYPASS TO UPPER PLENUM (LOWER VOL)	16001	17000	0.0	50.00	50.00	0000	038A	
		03	UPPER PLENUM (LOWER VOL)	17001	18000	0.020000	00.00	00.00	0100		
180	P	01 TO 02	UPPER PLENUM (LOWER VOL)			0.020000	00.00	00.00	0100		

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
190	B	01	INLET ANNULUS TO UPPER PLENUM (UPPER VOL)	10001	19001	0.0	3.00+5	3.00+5	0000	032- 041	
		02	UPPER HEAD TO UPPER PLENUM	19501	19001	0.020000	02.43	01.93	0000	041	
		03	UPPER PLENUM (LOWER VOL) TO UPPER PLENUM (UPPER VOL)	18001	19000	0.0	00.00	00.00	0100	040	
		04	UPPER PLENUM (UPPER VOL) TO INTACT LOOP	19000	20000	0.003324	00.00	00.00	0100	001	
		05	UPPER PLENUM (UPPER VOL) TO BROKEN LOOP	19000	30000	0.001078	00.00	00.00	0100	051	
			UPPER HEAD SIMULATOR (UPS)								
193	B	01	UPPER HEAD TO U.H BYPASS	19601	19300	0.0	00.51	00.95	0000	044	
		02	U.H INLET TUBE U.H BYPASS	19201	19301	0.0	72.00	72.90	0000	043	
		03	U.H BYPASS TO U.H OUTLET TUBE	19300	19500	0.0	03.00	03.10	0000	042	6-7,7-21
194	P	01 TO 04 05	PIPE TO U.H. VESSEL UPPER FLANGE			0.0	00.00	00.00	0000		
						0.0	00.34	00.34	0000		
195	P	01	UPPER HEAD OUTLET TUBE			0.0	00.20	00.20	0000		
196		01 TO 03	U.H. VESSEL			0.0	00.00	00.00	0000		
197	V	01	FROM INLET ANNULUS TO TEE (U.H. PIPING)	19201	19400	0.0	00.86	00.86	0000	043A	
198	SJ		U.H. VESSEL UPPER CONNECTION	19401	19600	0.0	01.11	00.28	0000		

1
2
3

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
INTACT LOOP PIPEWORK											
200	B	02	VESSEL OUTLET TO SURGE LINE	20001	40000	0.000068	00.00	00.00	0100	003	
210	B	01	SURGE LINE TO INTACT LOOP	40000	21000	0.000068	00.00	00.00	0100	003	
		02	PIPE TO INLET PIPE OF STEAM/G	21001	22000	0.0	00.27	00.27	0000	005	6-2,\$
		03	PIPE	20001	21000	0.0	00.62	00.62	0000	005	6-2,\$
225	SJ		PIPE TO STEAM GENERATOR (EXPANSION)	22001	23000	0.0	00.00	00.00	0000	007	6-2,\$,5-2,3-7
230	P	01	STEAM GENERATOR INLET PIPE			0.0	00.00	00.00	0000		
		02									
		03	STEAM GENERATOR INLET BEND			0.0	00.61	00.31	0000	009	6-2
230		04	STEAM GENERATOR BEND TO CHAMBER			0.0	00.00	00.00	0100	010	
		05	STEAM GENERATOR BUNDLE INLET			0.0	00.00	00.00	0000	011	
		06									
		T0	STEAM GENERATOR BUNDLE UPWARD			0.0	00.00	00.00	0000		
		15									
		16	STEAM GENERATOR BUNDLE BEND			0.0	00.00	00.00	0000	012,013	6-2
		17									
		T0	STEAM GENERATOR BUNDLE DOWNWARD			0.0	00.00	00.00	0000		
		26									
		27	BUNDLE OUTLET			0.0	00.00	00.00	0000	014	
		28									
		29	CHAMBER TO OUTLET			0.0	00.00	00.00	0100	015	
		30	STEAM GENERATOR OUTLET BEND			0.0	00.31	00.61	0000	016	6-2
		T0									
		31	STEAM GENERATOR OUTLET PIPE			0.0	00.00	00.00	0000		
235	SJ		STEAM/G OUTLET TO PIPING (REDUCTION & MEASUREMENT INSERT)	23001	24000	0.0	00.00	00.00	0000	018	6-2,\$

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
240	P	01				0.0	00.10	00.10	0000	019	\$
		02				0.0	00.00	00.00	0000		
		TO	PIPE								
		03				0.0					
		04									
		TO	PIPE BEND			0.0	00.17	00.17	0000		6-2
		05									
		06									
		TO	PIPE			0.0	00.00	00.00	0000	024	\$
		07									
250	PP	01	PIPE TO PUMP INLET	24001	25000	0.0	00.13	00.13	0000	025	\$, 3-7, 5-2
		02	PUMP TO INTACT LOOP (WITH ADAPTOR & M.I.)	25001	26000	0.0	00.04	00.03	0000	026	3-7, 5-2, \$
255	B		OUTLET OF PUMP	25501	26000	0.0	00.20	00.20	0000		
260	P	01				0.0	00.00	00.00	0000		
		TO									
		03									
270	B	01	PIPE TO VESSEL INLET	26001	27000	0.0	00.15	00.15	0000	030	

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORWARD 7A	LOSS REVERSE 7B	CONTROL CAMS 8	NODE NO. 9	REFERENCE 10
BROKEN LOOP PIPEWORK											
300	P	01	VESSEL OUTLET TO BROKEN LOOP PIPE		0.0		00.05	00.05	0000	052	
		02			0.0		00.11	00.11	0000	053	
		03			0.0		00.07	00.07	0000	054	
		04			0.0		01.38	00.38	0000	059	
315	SJ		PIPE TO S.G EXPANSION	30001	33000	0.0	00.19	00.05	0000	059	
330	P	01	EXPANSION TO INLET PIPE			0.0	00.00	00.00	0000	060	
		02	INLET PIPE			0.0	00.00	00.00	0000		
		03	STEAM GENERATOR PIPE TO BEND			0.0	00.01	00.01	0000	061	
		04	STEAM GENERATOR BEND TO CHAMBER			0.0	00.00	00.00	0100	062	
		05	STEAM GENERATOR BUNDLE INLET			0.0	00.00	00.00	0100	063	
		06									
		T0	STEAM GENERATOR BUNDLE UPWARD			0.0	00.00	00.00	0000		
		11									
		12									
		T0				0.0	00.15	00.15	0000		
		15									
		16	STEAM GENERATOR BUNDLE BEND			0.0	00.00	00.00	0000	064-	
		17								065	
		T0	STEAM GENERATOR BUNDLE DOWNWARD			0.0	00.00	00.00	0000		
		26									
		27	BUNDLE OUTLET			0.0	00.00	00.00	0100	066	
		28	CHAMBER TO OUTLET			0.0	00.00	00.00	0100	067	
		29	STEAM GENERATOR OUTLET BEND			0.0	00.00	00.00	0000	068	
		30									
		T0	STEAM GENERATOR OUTLET PIPE			0.0	00.00	00.00	0000	069	
		31									
335	J		STEAM GENERATOR TO PIPING (REDUCTION & MEASUREMENT INSERT)	33001	34000	0.0	00.05	00.19	0000	070	
340	P	01	PIPE			0.0	00.10	00.10	0000		
		02				0.0	00.00	00.00	0000		
		03				0.0	00.00	00.00	0000		
		04	PIPE BEND			0.0	00.75	00.75	0000	072-	
		05				0.0	00.07	00.07	0000	072-	
		06	PIPE			0.0	00.00	00.00	0000	074-	
		07				0.0	00.24	00.24	0000		

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
350	PP	01	PIPE TO PUMP INLET (WITH ADAPTOR & M.I.)	34001	35000	0.0	00.15	00.15	0000	076	
		02	PUMP OUTLET TO PIPE (WITH ADAPTOR, M.I. AND RESISTANCE SIMULATOR)	35001	36000	0.0	00.85	00.85	0000	077	
355	B	01		35501	36000	0.00000	00.40	00.40	0000	07	
360	P	01	PIPE WITH M.I.			0.0	00.00	00.00	0000	077A	
		02				0.0	00.05	00.05	0000	077B-	
370	B	01		36001	37000	0.0	00.00	00.00	0000		
		02		37001	39000	0.0	00.00	00.00	0000		
390	B	01		39001	39500	0.0	00.00	00.00	0000	082	6-2
395	P	01				0.0	00.00	00.00	0000		\$
		02				0.0	00.05	00.05	0000		

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	VOLUME NUMBER TO 5B	JUNCTION AREA 6	FORWARD 7A	LOSS 7B	REVERSE CAHS 8	CONTROL NODE NO. 9	REFERENCE 10
PRESSURIZER WITH SURGE LINE											
400	P	01	SURGE LINE			0.0	00.16	00.16	0000		
		02				0.0	00.00	00.00	0000		
		T0				0.0	00.32	00.32	0000		
		04				0.0	00.00	00.00	0000		
		05				0.0	00.32	00.32	0000		
		06				0.0	00.00	00.00	0000		
		T0				0.0	00.32	00.32	0000		
		11				0.0	00.00	00.00	0000		
		12				0.0	00.32	00.32	0000		
410	B	01	CONNECTION TO PRESSURIZER	40001	41001	0.0	00.00	00.00	0100		
		02	FROM LOWER VOLUME TO UPPER	41000	42000	0.0	00.00	00.00	0000		
		VOLUMES									
420	P	01	PRESURIZER			0.0	00.00	00.00	0000		
		T0									
		11									

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM LOSS FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10	
STEAM GENERATOR I (I.L) SECONDARY SIDE												
501	TDJ		FEED WATER INLET	50001	50500	0.001698	00.00	00.00	0100	101,102	A	
510	A	01 TO 11	DOWNCOMER			0.0	00.00	00.00	0000			
515	SJ	01	DOWNCOMER TO RISER	51001	52000	0.0	02.00	02.00	0000	103		
520	P	01 TO 10 11 12 13 14	RISER			0.018000	00.00	00.00	0100			
						0.018000	10.00	10.00	0000			
						0.0	00.00	00.00	0100	105		
						0.0	00.00	00.00	0000	106		
											7	
530	S	01 02 03	SEPARATOR TO STEAM DOME RISER TO SEPARATOR SEPARATOR TO DOWNCOMER	53001 52001 53000	56000 53000 54000	0.060000 0.040000 0.0	00.00 00.00 00.00	00.00 00.00 00.00	0100 0100 0000	113 113 108A		
540	A	01	DOWNCOMER			0.0	00.00	00.00	0000			
550	B	01 02 03	FEEDWATER INLET TO DOWNCOMER DOWNCOMER UPPER TO LOWER DOWNCOMER	50501 54001 55001	55000 55000 51000	0.001608	00.00 00.00 00.00	00.00 00.00 00.00	0100 0100 0000	121,122 122 122	A	
560	B	01	STEAM DOME		56000	70000	0.0	00.00	00.00	0100		

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN NO. 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
STEAM GENERATOR II (B.L) SECONDARY SIDE											
601	TDJ		FEED WATER INLET	60001	60500	0.001698	00.00	00.00	0100	101,102	A
610	A	01 TO 11	DOWNCOMER			0.0	00.00	00.00	0000		
615	SJ	01	DOWNCOMER TO RISER	61001	62000	0.0	05.00	05.00	0000		
620	P	TO 11 12 13 TO 14	RISER			0.008000	00.00	00.00	0000		
						0.0	00.00	00.00	0100		
						0.014408	00.00	00.00	0000		
630	S	01 02 03	SEPARATOR TO STEAM DOME RISER TO SEPARATOR SEPARATOR TO DOWNCOMER	63001 62001 63000	66000 63001 64000	0.020000 0.013000 0.0	00.00 00.00 00.00	00.00 00.00 00.00	0100 0100 0000		
650	B	01 02 03	FEEDWATER RING TO DOWNCOMER DOWNCOMER UPPER TO LOWER SECT. DOWNCOMER	60501 64001 65001	65000 65000 61000	0.000664 0.0 0.0	00.00 00.00 00.00	00.00 00.00 00.00	0100 0100 0000	121,122	A 122
660	B		STEAM DOME TO STEAM LINE	66001	71000	0.0	00.00	00.00	0100		

TABLE 3.3 (CONTINUED)

RELAP5/MOD1 JUNCTION RELATED INPUT DATA FOR LOBI-MOD2 TEST A2-81 (ISP18).
(DIMENSIONS IN m)

COMP NO. 1	COMP TYPE NO. 2	JUN 3	DESCRIPTION 4	VOLUME FROM 5A	NUMBER TO 5B	JUNCTION AREA 6	FORM LOSS FORWARD 7A	LOSS REVERSE 7B	CONTROL CAHS 8	NODE NO. 9	REFERENCE 10
STEAM LINES WITH HEADER											
700	P	01	STEAM LINE INTACT LOOP			0.0	06.32	06.32	0000		
		02				0.0	01.79	01.79	0000		
		TO									
		03									
701	B	01	HEADER INLET	70001	70100	0.0	00.00	00.00	0000		
705	V	01		70101	72000	0.003728	00.00	00.00	0100		
710	P	01	STEAM LINE BROKEN LOOP			0.0	06.80	06.80	0000	9-21,6-2 , \$	
		02				0.0	06.96	06.96	0000		
711	B	01	HEADER INLET	71001	71100	0.0	00.00	00.00	0000		
715	V	01	HEADER INLET TO HEADER	71101	72000	0.001459	00.00	00.00	0100		
725	V	01	MAIN STEAM VALVE	72001	73000	0.0	00.00	00.00	0000		

Table 4.1 Measured/Calculated Pressure Drop Data for the Reactor Pressure Vessel Model RPV,
at nominal conditions of Test A2-81

Pressure Drop Section			Static Head		Pressure Difference (kPa)		PD-Identifier
Component	Location see Fig. 4.2	H (mm)	PD(Static)* (kPa)	measured	calculated		
RPV inlet	IL L18	- 170	- 1.2	45.0 0.3	44.5	PD163DB3	
	BL L18	- 170	- 1.2	26.9 0.2	29.5	PD263DB7	
Downcomer							
upper section	V1	- 5405	- 37.2	- 26.9 0.4	- 26.9	PD3DBT	
medium "	V2	- 600	- 4.1	- 3.1 0.2	- 3.2	PD3DTU02	
lower "	V3+V4+V5	0	0	9.4 0.4	9.4	PD3D3RUU	
outlet "							
Riser							
core entrance	V5	+ 1500	+ 10.2	17.8 0.3	17.7	PD3RYU21	
heated length	V6	+ 4605	+ 31.7	117.5 0.5	116.5	PD3RUG11	
upper plenum	V7	+ 1565	+ 10.8	10.0 0.4	11.3	PD3RGF12 PD3RFD24 PD3RDA44	
RPV outlet	IL L11	+ 5	0.1	35.7 0.4	35.0	PD3R11A4	
	BL L21	+ 5	0.1	34.1 0.7	33.5	PD3R21A3	
RPV total	IL L19	over RPV	0	0	188 1.0	186.6	-
	BL L29	sections	0	0	168 1.3	173.8	-

*) evaluated with $\rho = 702 \text{ kg/m}^3$

Table 4.2 Measured/Calculated Pressure Drop Data for the Intact/Broken Loop (IL/BL),
at nominal conditions of Test A2-81

Component	Pressure Drop Section		Static Head		Pressure Difference (kPa)		PD-Identifier
	Location see Fig. 4.1	H (mm)	PD(Static)* (kPa)	measured	calculated		
Hot Leg	IL	L12	+ 1205	+ 8.3	25.5 0.2	28.5	PD1190A
	BL	L22	+ 1055	+ 7.3	29.8 0.3	30.8	PD2180A
Steam Generator	IL	L13	0	0	58 1.2	59.9	PD9092AA
	BL	L23	0	0	64 1.2	63.5	PD8082AA
Pump seal entrance	IL	L14	- 3750	- 25.7	5.8 0.5	3.9	PD9217A
	BL	L24	- 3145	- 21.6	8 1.2	8.5	PD8227A
Pump seal outlet	IL	L15	+ 1735	+ 11.9	18.0 0.3	23.6	PD1714
	BL	L25	+ 1430	+ 9.8	20.0 0.3	21.3	PD2724
Cold leg	IL	L17	- 15	0.1	11 0.2	13.3	PD151653
	BL	L27	- 10	0.1	22 0.2	15.3	PD2526
RPV, total	IL	L19	0	0	186 3.1	186.6	PD161133
	BL	L29	0	0	170 1.3	173.8	PD262133
Pump head	IL	L16	- 805	- 5.5	307 4.3	315.9	PD151456
	BL	L26	- 670	- 4.6	314 8.0	313.1	PD252451

*) evaluated with $\rho = 702 \text{ kg/m}^3$

Table 4.3 Measured/Calculated Pressure Drop Data for the Steam Generators SG1/SG2
at nominal conditions of Test A2-81

Component	Pressure Drop Section		H (mm)	PD(Static)* (kPa)	Pressure Difference (kPa)		PD-Identifier
	Location see Fig. 4.3+4.4				measured	calculated	
SG inlet	SG1	S91	+ 1760	+ 12.2	20.2 0.3	19.8	PD90AB46
	SG2	S81	+ 1905	+ 13.1	21.2 0.3	21.3	PD80AB42
U-tube hot leg	SG1	S92	+ 6900	+ 47.3	73.4 0.7	74.7	PD90BNX1
	SG2	S82	+ 6920	+ 47.5	76.6 0.7	74.6	PD80BNX1
cold leg	SG1	S95	- 6900	- 47.3	- 23.4 0.7	- 22.2	PD92BNX1
	SG2	S85	- 6920	- 47.5	- 22.2 0.7	- 21.9	PD82BNX1
SG outlet	SG1	S98	- 1760	- 12.2	- 12.3 0.3	- 12.4	PD92BA24
	SG2	S88	- 1905	- 13.1	- 11.9 0.3	- 10.5	PD82BA64
SG total	SG1	L13	0	0	57.7 1.2	59.9	PD9092AA
	SG2	L23	0	0	63.6 1.2	63.5	PD8082AA

*) evaluated with $\rho = 702 \text{ kg/m}^3$

Table 4.4 Measured and Calculated Environmental Heat Losses
for LOBI-MOD2 test A2-81 (ISP18)

Component	Heat loss (kW) measured/estimated	calculated
Vessel simulator	18.16	18.26
Intact loop piping	12.19	13.24
Broken loop piping	12.41	12.09
Pressurizer	*	2.26
Steam generator (I.L)	12.00	8.32
Steam generator (B.L)	8.00	5.34
Steam line and header	*	1.27
sub-total	64.52	60.78
Seal water ¹	30.48	30.22
total system	95.00	91.00

* data or estimate not available

¹ seal water temperature: 25° C

Table 4.5 Estimated and Calculated Bypass Flow Rates

Flow Path	measured/estimated	Bypass flow (%) calculated
- from downcomer to I.L hot leg	*	1.43
- from downcomer to B.L hot leg	*	0.65
- from upper downcomer to uppr plenum (through 2 holes of 5mm dia each)	*	0.82
sub-total	2.4 - 3.7	2.9
- from upper downcomer to uppr plenum (through upper head)	*	3.5
- Core bypass flow	*	3.1
total		9.5

* data or estimate not available

Table 4.6 Measured and Calculated Pump Speed and Core Heatup Values at Steady State

Parameter	Measured	Calculated
Pump speed (rev/min): -Intact loop -broken loop	4820 3830	4902 3882
ΔT between vessel inlet and outlet (K): -Intact loop -broken loop	32.8 34.7	32.6 32.7

Table 4.7 Seal Water Injection into Primary Coolant Pumps
as Function of Primary Pressure

Primary Pressure (M Pa)	Total seal water flow (kg/s)
Intact Loop Pump:	
2.5	0.01444
3.0	0.01500
4.0	0.01583
5.0	0.01639
6.0	0.01722
7.0	0.01750
8.0	0.01778
9.0	0.01806
10.0	0.01806
11.0	0.01778
12.0	0.01750
13.0	0.01667
14.0	0.01528
15.0	0.01333
16.0	0.01111
17.0	0.00833
Splitting up ratio (suction/total) appr. 0.2	
Broken Loop Pump:	
2.5	0.00944
3.0	0.01000
4.0	0.01083
5.0	0.01167
6.0	0.01222
7.0	0.01278
8.0	0.01306
9.0	0.01333
10.0	0.01361
11.0	0.01361
12.0	0.01333
13.0	0.01278
14.0	0.01194
15.0	0.01028
16.0	0.00861
17.0	0.00639
Splitting up ratio (suction/total) appr. 0.7	

Table 4.8 Initial Conditions for LOBI-MOD2 Test A2-81 (ISP18)

Primary system	Specified 1)	Measured	Calculated
Mass flow: (kg/s)			
- Intact loop	21.0	21.0	21.0
- Broken loop	7.0	6.7	6.7
Pressure: (MPa)			
- Upper Plenum	15.8	15.8	15.8
Fluid temperatures: (C)			
- Vessel Inlet			
- Intact loop	294.0	293.7	293.9
- Broken loop	294.0	293.3	293.5
- Pressurizer	346.0	346.0	346.0
Core Power: (MW)	5.28	5.206	5.206
Pressurizer Water Level:(m)	4.8	5.2	5.2
Secondary system			
Feedwater mass flows: (kg/s)			
- Intact loop	2.0	2.0	2.09
- Broken loop	0.67	0.72	0.66
Pressure: (MPa)			
- Steam Dome	6.45	6.54	6.52
Main feedwater			
temperature (C):			
- Intact loop	210.0	212.9	212.9
- Broken loop	210.0	212.9	212.9
Recirculation ratio:			
- Intact loop	3.6	6.5	7.2
- Broken loop	3.6	4.5	7.1
Collapsed Liquid Level			
in Downcomer (m):			
- Intact Loop	8.3		8.3
- Broken Loop	9.1		9.1
Pressure Differential			
b/w Level: (MPa)			
- Intact loop			
B and S		0.05475	0.06037
R and S		0.00562	0.00072
S and T		0.00080	0.00237
F and B (Downcomer)		-0.01274	-0.01470
B and F (Riser)		0.01406	0.01328
- Broken loop			
B and S		0.04634	0.04901
R and S		0.01082	0.00865
S and T		0.00222	0.00042
F and B (Downcomer)		-0.01046	-0.00879
B and F (Riser)		0.01119	0.01110

¹ in Reference /4/

Table 5.1: LOBI-MOD2 Test A2-81 (ISP18) Post-Test Prediction Performance

Restart no.	Date	Job no.	Problem time(s) From	to	CPU time@1 (min)	Remarks
1	13.03.85	3193	0.	440.	143.	Steady state
2	15.03.85	6908	440.	555.	194.	Start of transient
3	17.03.85	8863	555.	1600.	504.	Renod. of pumps
4	29.03.85	6460	1600.	1850.	684	
5	31.03.85	3092	1850.	2700.	1284.	
6	01.04.85	7985	2700.	3300.	1757.	
7	03.04.85	6020	3300.	3550.	1937.	
	06.04.85	3562	3550.	4464.8	2516. (=42h)	End of prediction

@1 on Siemens maschine 7-890 (same as Fujitsu FACOM M380)

Table 5.2 LOBI-MOD2 Test A2-81 (ISP18): Post-Test Prediction, Sequence of Events

Event	Time(s)	
	measured	calculated
- Leak starts to open	0	0
- Primary pressure reaches 132 bar Heating Power starts to drop; Cooling down curve becomes active; secondary shutoff valve starts to close;	32	24
- Primary pressure reaches 110 bar Main Coolant Pumps start to coastdown	45	41
- High Pressure Injection starts (117 bar + delay of 35 s)	74	65
- Main Coolant Pumps stop	117	115
- Locked Rotor Resistance Simulator for Broken Loop in position "resistance"	121	115
- Primary pressure reaches 10 bar (specified end of test)	4333	4025

F I G U R E S




Figure 2.1 LOBI-MOD2 Configuration for Test A2-81





Figure 3.1 LOBI-MOD2 Nodalization for RELAP5/MOD1

Figure 3.2 LOEI-MOD2 Intact Loop (Schematic).






Figure 3.3 LOBI-MOD2 Broken Loop (Schematic)




Figure 3.4 LOBI-MOD2 Reactor Pressure Vessel Model (Schematic)





Figure 3.5 LOBI-MOD2 Steam Generator(s), Schematic

Figure 3.6 LOBI-MOD2 Steam Lines and Header (Schematic)






Figure 3.7 Nodalization of RPVM





Figure 3.8 Modelling of Core Bypass Flow Paths in RPVM

Figure 3.9 LOBI-MOD2 Heater Rods, Sections and Power Distribution



dimensions in mm





Figure 3.10 Modelling of Break




Figure 3.11 Nodalization of Steam Generator I




Figure 3.12 Nodalization of Steam Generator II

Figure 4.1: Differential Pressure Measurement Sections for Loops





Figure 4.2: Differential Pressure Measurement Sections for RPVM



(TF 95 : ▽ 10100)





Figure 4.3: Differential Pressure Measurement Sections for SG I

Figure 4.4: Differential Pressure Measurement Sections for SG II






FIG. 5. 2 A PRESSURE IN PRESSURIZER, PA40 (MPA)




FIG. 5. 2 PRESSURE IN PRESSURIZER, PA40 (MPA)




FIG. 5. 1 PRESSURE IN UPPER PLENUM, PA38 (MPA)




FIG. 5. 4 INTACT LOOP PUMP SPEED, RP71 (RPM)




FIG. 5. 3 POWER INPUT, WH-POWER (MW)




FIG. 5. 6 FLUID TEMP. INTACT L. VESSEL OUTLET AT TOP, TF11T (C)




FIG. 5. 5 HIGH PRESSURE INJECTION FLOW, QM55 (KG/S)




FIG. 5.8 FLUID TEMP. INTACT LOOP VESSEL INLET AT TOP, TF16T (C)




FIG. 5.7 FLUID TEMP. INTACT L. VESSEL OUTLET AT BOTTOM, TF11B (C)




FIG. 5.10 FLUID TEMP. BROKEN LOOP VESSEL OUTLET AT TOP, TF21T (C)




FIG. 5.9 FLUID TEMP. INTACT LOOP VESSEL INLET AT BOTTOM, TF16B (C)




FIG. 5.12 FLUID TEMP. BROKEN LOOP VESSEL INLET AT TOP, TF26T (C)




FIG. 5.11 FLUID TEMP. BROKEN LOOP VESSEL OUTLET AT BOTTOM, TF21B (C)




FIG. 5.14 FLUID TEMP. CORE INLET, TF35 (C)




FIG. 5.13 FLUID TEMP. BROKEN LOOP VESSEL INLET AT BOTTOM, TF26B (C)




FIG. 5.16 FLUID DENSITY IN INTACT LOOP SEAL PUMP INLET, DD14 (KG/M³)




FIG. 5.15 FLUID DENSITY INTACT. L. VESSEL OUTLET, DD11 (KG/M³)




FIG. 5.18 FL.DENSITY BROKEN L. HOT LEG VESSEL OUTLET, DD21 (KG/M³)






FIG. 5.17 FLUID DENSITY INTACT L. COLD LEG VESSEL INLET, DD16 (KG/M³)






FIG. 5.22 FL.DENSITY NEAR CORE INLET, DS35 (KG/M³)




FIG. 5.21 A FL.DENSITY BROKEN L. B/W BREAK & VESSEL, DD26 (KG/M³)




FIG. 5.21 FL.DENSITY BROKEN L. B/W BREAK & VESSEL, DD26 (KG/M³)




FIG. 5.24 DIFF.PRESSURE I.LOOP SEAL ASC.LEG. PD1714 (MPA)




FIG. 5.23 DIFF.PRESSURE I.LOOP SEAL DESC.LEG. PD9217 (MPA)




FIG. 5.26 DIFF.PRESS.BROK.LOOP SEAL ASC.LEG, PD2724 (MPA)




FIG. 5.25 DIFF.PRESS.BROK.LOOP SEAL DESC.LEG, PD8227 (MPA)




FIG. 5.28 DIFF.PRESS.CORE HEATED LENGTH, PD3RTK (MPA)




FIG. 5.27 DIFF.PRESS.VESSEL DOWNCOMER, PD3DBT (MPA)




FIG. 5.30 DIFF.PRESS. I.L. U-TUBES ASC.LEG, PD90BN (MPA)




FIG. 5.29 DIFF.PRESS. UPPER PLENUM, PD3RKA (MPA)




FIG. 5.32 DIFF.PRESS.VESSEL U.HEAD TO U.PLENUM, PD3R39 (MPA)




FIG. 5.31 DIFF.PRESS. B.L. U-TUBES ASC.LEG, PD80BN (MPA)




FIG. 5.34 HEATER ROD SURFACE TEMP.LEVEL 7, TH07 (C)




FIG. 5.33 HEATER ROD SURFACE TEMP.LEVEL 4, TH04 (C)




FIG. 5.36 HEATER ROD SURFACE TEMP.LEVEL 11, TH11 (C)




FIG. 5.35 HEATER ROD SURFACE TEMP.LEVEL 9, TH09 (C)




FIG. 5.38 HEATER ROD SURFACE TEMP.LEVEL 14, TH14 (C)




FIG. 5.37 HEATER ROD SURFACE TEMP.LEVEL 13, TH13 (C)




FIG. 5.40 STEAM GEN. I TEMP. BOTTOM OF RISER, TF95B (C)




FIG. 5.39 STEAM GEN. I PRESS. IN STEAM DOME, PA97S (MPa)




FIG. 5.42 STEAM GEN. I TEMP. STEAM DOME, TF97T (C) C)




FIG. 5.41 STEAM GEN. I TEMP. TOP OF RISER, TF95N (C))




FIG. 5.44 STEAM GEN.II TEMP. TOP OF RISER, TF85K (C)




FIG. 5.43 STEAM GEN.II TEMP. BOTTOM OF RISER, TF85B (C)




FIG. 5.46 COLL. WATER LEVEL IN PRESSURIZER, CL4340 (M)




FIG. 5.45 STEAM GEN.II TEMP. STEAM DOME, TF87T (C)




FIG. 5.48 COLL. WATER LEVEL IN SG I DOWNCOMER, CL93BT (M)




FIG. 5.47 COLL. WATER LEVEL IN SG II DOWNCOMER, CL83BT (M)




FIG. 5.50 MASS FLOW SG I DOWNCOMER LOW SECTION, CM93G (KG/S)




FIG. 5.49 MASS FLOW SG II DOWNCOMER LOW SECTION, CM83G (KG/S)




FIG. 5.52 MASS FLOW SG II STEAM LINE, CM66 (KG/S)




FIG. 5.51 MASS FLOW SG I STEAM LINE, CM65 (KG/S)




FIG. 5.54 NET PUMP SEAL WATER INJECTION BROKEN L., QS72 (KG/S)




FIG. 5.53 NET PUMP SEAL WATER INJECTION INTACT L., QS71 (KG/S)




FIG. 5.56 PRIMARY & SECONDARY PRESSURE, PA38 & PA975 (MPA)




FIG. 5.55 PRIMARY & SECONDARY PRESSURE, PA38 & PA975 (MPA)




FIG. 5.57 BREAK MASS FLOW, CM05 (KG/S)




FIG. 5.57 A BREAK MASS FLOW, CM05 (KG/S)




FIG. 5.58 PRIMARY SYSTEM MASS INVENTORY

* Interval of exp. curve not representative

PLOTTED : 05/12/85 08.20.19







Figure 5.59 Location of Heater Rod Thermocouples in Test A2-81



Beam Cross Section



Note: The beam cross section geometry shown is the nominal one; due to scattering effects and finite source size the beam intensity distribution is non uniform and about 10% of the effective beam lies outside the nominal section.

Figure 5.60 Beam Geometry of LOBI-MOD2 γ -Densitometer




Figure 5.61: Azimutal Locations of Bypass Flow Paths in RPVM




Figure 5.62 Horizontal Flow Regime Map Used in RELAP5 Code

REFERENCES

- / 0/ W.L. Riebold et al.:
Specification of LOBI Pre-Prediction Exercise,
Commission of the European Communities, J.R.C., Ispra Establ.,
Tech. Note I.06.01.79.25
- / 1/ LOBI-MOD2: Facility Description and Specification for OECD-CSNI
International Standard Problem No. 18 (ISP18), Vol. I,
C.Addabbo, L.Pipples, W.L.Riebold:
Geometrical Configuration of the Test facility,
Commission of the European Communities, J.R.C., Ispra Establ.,
Communication No. 4010
July 1983
- / 2/ LOBI-MOD2: Facility Description and Specification for OECD-CSNI
International Standard Problem No. 18 (ISP18), Vol. II,
E.Ohlmer, J.Sanders, J.Eder:
Measurement Instrumentation and Data Acquisition System,
Commission of the European Communities, J.R.C., Ispra Establ.,
Communication No. 4011
Sept. 1983
- / 3/ LOBI-MOD2: Facility Description and Specification for OECD-CSNI
International Standard Problem No. 18 (ISP18), Vol. III,
E.Ohlmer, J.Sanders, R.Doering, K.Floegel:
Pressure Drop and Heat Losses,
Commission of the European Communities, J.R.C., Ispra Establ.,
Communication No. 4012
April 1984
- / 4/ LOBI-MOD2: Facility Description and Specification for OECD-CSNI
International Standard Problem No. 18 (ISP18), Vol. IV,
L.Pipples, H.Staedtke, W.Kolar:
Specifications,
Commission of the European Communities, J.R.C., Ispra Establ.,
Communication No. 4013
June 1984
- / 5/ L.Pipples:
Answers to Questions relating to Engineering Details of ISP18
(Communication No. 1),
Commission of the European Communities, J.R.C., Ispra Establ.,
December 1983
- / 6/ L.Pipples:
Answers to Questions relating to Engineering Details of ISP18
(Communication No. 2),
Commission of the European Communities, J.R.C., Ispra Establ.,
February 1984
- / 7/ L.Pipples:
Answers to Questions relating to Engineering Details of ISP18
(Communication No. 3),
Commission of the European Communities, J.R.C., Ispra Establ.,
October 1984

- / 8/ L.Piplies:
Answers to Questions relating to Engineering Details of ISP18
(Communication No. 4),
Commission of the European Communities, J.R.C., Ispra Establ.,
October 1984
- / 9/ L.Piplies:
Answers to Questions relating to Engineering Details of ISP18
(Communication No. 5),
Commission of the European Communities, J.R.C., Ispra Establ.,
December 1984
- /10/ L.Piplies:
Answers to Questions relating to Engineering Details of ISP18
(Communication No. 6),
Commission of the European Communities, J.R.C., Ispra Establ.,
February 1985
- /11/ L.Piplies:
Answers to Questions relating to Engineering Details of ISP18,
Commission of the European Communities, J.R.C., Ispra Establ.,
(Communication No. 7),
March 1985
- /12/ L.Piplies:
Initial and Boundary Conditions for LOBI-MOD2 Test A2-81,
Commission of the European Communities, J.R.C., Ispra Establ.,
1613/588/84/BD - LP/bs (Oct. 84)
- /13/ J.Sanders and E.Ohlmer:
Experimental Data Report - LOBI-MOD2 Test A2-81,
Commission of the European Communities, J.R.C., Ispra Establ.,
Confidential Communication NO. 4019,
November 1984
- /14/ L.Piplies & J.Bachler:
Single Phase Performance Characterstic of the LOBI Pump,
Commission of the European Communities, J.R.C., Ispra Establ.,
Tech. Note No. I.06.01.79.80,
August 1979
- /15/ L.Piplies & W.Kolar:
Preliminary Two Phase Performance Characterstic of the LOBI Pump
(Curves for Fully Degraded Head),
Commission of the European Communities, J.R.C., Ispra Establ.,
Tech. Note No. I.06.01.81.13,
February 1981
- /16/ I.E.Idel'chik:
Handbook of Hydraulic Resistance,
Gosudarstvennoe Energeticheskoe Izdatel'stvo,
Moskva-Leningrad, 1960,
(Translation from Russian, 1966), AEC-tr-6630

- /17/ B.Worth:
Minutes of the 1st Workshop for the ISP international Standard Problem Exercise,
Commission of the European Communities, J.R.C., Ispra Establ.,
Technical Note No. I.06.01.83.137,
November 1983
- /18/ W.Kolar and W.Brewka:
LOBI Experimental Data Tape - Format description,
Commission of the European Communities, J.R.C., Ispra Establ.,
Technical Note No.I.06.C1.85.49,
May 1985
- /19/ V.H. Ransom, et al.,
RELAP5/MOD1 Code Manual (Vol. I),
System Models and Numerical Methods,
Idaho National Engineering Laboratory, USA,
NUREG/CR-1826,EGG-2070,
March 1982
- /20/ V.H. Ransom, et al.,
RELAP5/MOD1 Code Manual (Vol. II),
Users Guide and Input Requirements,
Idaho National Engineering Laboratory, USA,
NUREG/CR-1826,EGG-2070,
March 1982
- /21/ V.H. Ransom, et al.,
RELAP5/MOD1 Code Manual (Vol. III),
Checkout Problems Summary,
Idaho National Engineering Laboratory, USA,
EGG-NSMD-6182
February 1983
- /22/ L.N.Kmetyk:
RELAP5 Assessment:
Conclusions and User Guidelines,
Sandia National Laboratory, USA,
NUREG/CR-3936,
October 1984
- /23/ R.M.Summers:
RELAP5 Assessment:
Semiscale Mod-3 Small Break Tests
Sandia National Laboratory, USA,
NUREG/CR-3277,
July 1983
- /24/ L.N.Kmetyk:
RELAP5 Assessment:
LOFT Small Break L3-6/L8-1
Sandia National Laboratory, USA,
NUREG/CR-3163,
March 1983

- /25/ RELAP5 Newsletter
Idaho National Engineering Laboratory, USA,
EGG-SAAM-6428,
October 1983
- /26/ E.B.Wylie and V.L.Streeter:
Fluid Transients,
MGraw Hill, NewYork ,1978
- /27/ H.Zoebel and J. Kruschik:
Str\$'155'mung durch Rohre und Ventile,
Springer Verlag, Wien, NewYork , 1982
- /28/ G.Jacobs:
Implementing and Updating RELAP/MOD1/001
(JAERI-Version) on IBM-Installation at KfK,
N.E.A. Newsletter No. 31,Paris, 1983
- /29/ G.Jacobs, et al:
Arbeiten an der IBM-Version des Leichtwasser
Reaktor-Primärsystem Programms RELAP5/MOD1
und deren Anwendung, Jahresbericht 1983.
Projekt Nukleare Sicherheit, KfK 3450 (1984)
- /30/ H.Städtk, B.Worth and W.Kolar
RELAP5 Assessment with LOBI Small Break LOCA Test Results,
Proceedings, Vol. II,
Specialists Meeting on Small Break LOCA Analysis
in LWRs , Pisa, Italy, June 1985
- /31/ G.Leva, J.Blogg
Primary System Mass Inventory for LOBI-MOD2 Test A2-81 (ISP18),
Commission of the European Communities, J.R.C., Ispra Establ.,
Tech. Note I.06.C1.85.149 (Nov. 1985)
- /32/ B.Worth, H.Städtk:
Post-Test Calculation Report of LOBI-MOD2 Test A2-81 (ISP18),
Commission of the European Communities, J.R.C., Ispra Establ.,
Confidential Communication No. 4033 (Oct. 1985)

Appendix A

LOBI-MOD2, Description of Test Facility

A - 2 -

1. General Description

The LOBI facility is a high pressure integral system blowdown-refill test facility designed, constructed and operated in the Joint Research Centre of the European Communities, Ispra Establishment, Italy. It was commissioned in December 1979 and was operated until June 1982 in the MOD1 configuration. It was then extensively modified to accommodate new programme requirements leading to the present MOD2 configuration.

The LOBI test facility is an approximately 1:712 scale model of a four-loop 1300 MWe PWR and has two primary loops, the intact loop representing three loops, and the broken loop representing one loop of the reference PWR. Both primary loops are active loops, each containing a coolant circulation pump and a steam generator. The simulated core consists of an electrically heated 64 rod bundle (5.3 MW) housed in the pressure vessel model. Lower plenum, upper plenum and an annular downcomer are additional major components of the reactor model assembly. Pipe ruptures of various sizes, ranging from double-ended breaks to single-ended small leaks, may be simulated at various locations within the primary cooling system. The primary cooling system which is shown schematically in Figures A.1 operates at normal PWR conditions: approximately 155 bar and 290/320°C pressure and temperature.

In the MOD2 system configuration emergency-core-cooling (ECC) water can be supplied by the high pressure injection system (HPIS) and by the accumulator injection system (AIS); for the time being the low pressure injection system (LPIS) is not represented. Provisions are made for cold leg or combined cold and hot leg ECC injection into both primary loops.

Heat is transferred from the primary loops by the secondary cooling circuit containing two condensers and a cooler (simulating the heat sink represented by the turbines and condensers in the real plant), the main feedwater pump, and the auxiliary feedwater system. The normal operating conditions of the secondary cooling circuit are approximately 210°C feedwater temperature and 54 bar pressure. The secondary cooling circuit is, however, designed to withstand pressures and temperatures of up to 100 bar and 310°C respectively. A schematic drawing of the secondary cooling circuit is shown in Fig. A.2.

2. General Design Rationale

The objectives of the LOBI project require a test facility with a thermo-hydraulic behaviour during blowdown which is as closely as possible a reactor typical one.

The scaling factor of 712 has been applied to the power input, coolant mass flow and coolant volume of the primary cooling system leading to the following values:

- 5.3 MW electrical power supplied to the 64 (8 x 8) heater rod bundle of a 1 : 1 PWR design
- 21 kg/s and 7 kg/s coolant mass flow for the intact and broken loop respectively, resulting in 28 kg/s core mass flow
- about 0.6 m³ coolant volume within the primary loop system including the pressurizer.

The design of the experimental primary loops and the individual components was performed such that (1) the ratio of power to volume, (2) the ratio of the volumes of various components and pipework sections to each other and (3) the ratio of the rupture size to primary coolant system volume, as well as (4) the pressure drop and temperature distribution along the flow paths was maintained as closely as technically possible equal to the value of the reference plant.

The height, and relative heights (elevation) of components are scaled 1 : 1, thus preserving gravitational heads. The heat transfer surfaces (core rod bundle, steam generators) are full length.

An exception to these scaling criteria is the annular shaped downcomer. Since no general scaling concept for the downcomer gap size is available at present, the LOBI-MOD2 system is configured with a downcomer of 12 mm gap width (which is a compromise between the volume scaled downcomer, 7 mm gap width, and a pressure drop scaled downcomer, 25 mm gap width).

3. Mechanical Components

In this subsection an introductory description of each major mechanical component of the test facility is presented. Geometrical shape and dimensions and all relevant characteristics of the various components of the test facility are detailed in the as-built drawings.

3.1 Reactor Pressure Vessel Model (RPVM)

The reactor model consists of the pressure vessel (PV), the core barrel tube (CBT) and the heater rod bundle, thus simulating the internal annular downcomer, the core and the lower and upper plenum (Fig. A.3).

The pressure vessel is closed at its upper end by the upper power connecting plate and at its lower end by the lower plenum container.

The annular downcomer formed by both the PV and the CBT together has a downcomer gap width of 12 mm. A honeycomb structure is arranged along the outer wall of the CBT in order to form the 12 mm downcomer gap width. The honeycomb design was adopted to reduce the stored heat in the downcomer inner wall. Two holes of 5 mm diameter in the upper end of the core barrel tube simulate the upper downcomer to hot leg bypass flow path.

The reactor core is simulated by a 64 heater rod bundle (8 x 8) of hollow tubes, uniformly heated over the bundle cross section, with the following dimensions:

- total length	6890	mm
- heated length	3900	mm
- outer tube diameter	10.75	mm
- pitch	14.3	mm
- tube wall thickness (5 steps)	1.2, 1.5, 2.15	mm

The tubes are electrically heated; the tube wall thickness within the heated length is varied in 5 steps such as to allow the simulation of a cosine-shaped axial heat flux distribution.

The upper "unheated" part of the rod bundle is formed by hollow nickel tubes, the lower "unheated" part by nickel rods and flexible nickel strings through which the heater rods are connected to the lower power connecting ring. The heat dissipated within these "unheated" regions amounts to about 14 %.

Nine grid spacers are equidistantly placed throughout the heated length; five further spacers are arranged in the upper "unheated" part of the rod bundle; these are supplied with additional distancing devices to support the rod bundle against the core barrel tube.

Ceramic segments are arranged along the inner wall of the CBT forming a quadratic flow shroud extending for 4428 mm over the heated length of the rod bundle. A core bypass flow is caused by the annular gap of 1.5 mm width remaining between these ceramic fillers and the CBT.

The upper "unheated" part of the heater rod bundle extends entirely in the upper plenum and represents the internal structure of the LOBI upper plenum.

The upper head of the RPVM is simulated by a small container of 1 : 1 height and scaled volume, and is arranged separately to the RPVM at 1 : 1 elevation. It is connected to the upper plenum on one hand and to the upper downcomer region on the other hand.

3.2 Steam Generators

The geometrical configuration of the MOD2 steam generators is, in general, similar to that of the steam generators in the reference plant. They are of the inverted U-tube type. The capacity ratio between the broken loop and the intact loop steam generators is 1:3 with respect to coolant volume and mass flow, to heat transfer surface and, hence, to heat exchanger power.

The general form of the design consists of a single cylindrical pressure vessel with an annular downcomer separated from the riser region by a skirt tube. This tube is supported above the tube plate, and carries the coarse separator at its upper end. The U-tubes are arranged in a circle

within the riser region, around an axially mounted filler tube, with the U-bends crossing over one another above it. This design permits cross flow between co-current and counter current legs of the U-tubes over their entire length, heat transfer between riser and downcomer, and extremely precise volume scaling; at the same time extraneous thermal capacity in the filler elements is minimised. The actual elevation and the dimensions of various components within the two steam generators are shown in Figure A.4.

3.3 Main Coolant Pumps (MCP)

The MCP of both loops are centrifugal type pumps and are equal in size. Therefore, special cross section adapters at the pump inlet and outlet are required for connecting the pump to the different inner tube diameters of the intact and broken loop. The two pumps are operated at two different speeds such as to yield the two different steady-state mass flows of 21 kg/s and 7 kg/s for the intact and the broken loop respectively at the same pressure head. A special control and drive system allows the control of the pump speed during blowdown in forward and backward direction over a range of about 8500 rpm.

3.4 Pressurizer

The LOBI pressurizer design is geometrically similar to that of the reference plant. It is scaled in total and water volume, the height and the elevation are preserved 1:1.

The 20 kW heat source to generate the system pressure is formed by 8 heater rods; the heat sink to regulate the system pressure is represented by 3 cooling tubes placed within the steam region.

The pressurizer normal operating conditions are 155 bar and 345°C pressure and temperature, respectively. The pressurizer is normally connected to the intact loop hot leg. The surge line rises within the pressurizer and leaves it radially. A full flow turbine flow meter installed within the surge line allows the measurement of the surge line fluid flow during blowdown.

3.5 ECC Injection System

The LOBI-MOD2 ECC injection system comprises the high pressure injection system (HPIS) and the accumulator injection system (AIS). The low pressure injection system (LPIS), for the time being, is not represented.

The HPIS and the AIS have common injection points. Each HPIS and the corresponding AIS feed line are piped together at a certain distance from the common connection to the main coolant pipe of the primary circuit. This arrangement enables a variety of HPIS-ECC injection modes; e.g. cold leg, hot leg or combined cold and hot leg ECC injection (KWU design) can be provided. The HPIS water is supplied by a positive displacement pump driven by a variable speed motor. The pump is rated for a maximum flow of 0.39 kg/s at a total head of 200 bars when operated at 150 rpm. A special speed control system provides appropriate head and delivery variation to match the expected performance of the HPIS in the reference plant. Properly designed and calibrated throttling devices are installed in the main injection line to provide the required proportioning (depending on specific simulation needs) of the injection rate between the broken and the intact loop.

The AIS is composed of two accumulators, one for each loop. The accumulator of the intact loop has three times the volume and water capacity of that for the broken loop. The total volume of each accumulator is scaled to that of the reference plant having one accumulator per primary loop. Height and elevation are scaled 1:1.

The accumulators' over-pressure is generated by a nitrogen gas atmosphere. They are both designed for operation at a maximum of 60 bar and 50°C. Each accumulator is connected to both cold and hot leg of the respective primary loop. Depending on specific simulation requirements, cold leg, hot leg or combined cold and hot leg ECC injection can be provided.

The AIS-ECC injection is started by the automatic opening of check valves when the loop pressure has decreased below the accumulator set pressure. The injection mass flow is measured by full flow turbines in each individual branch of the injection lines.

3.6 Connecting Pipes

The main coolant pipes connecting the major individual components of the intact loop and of the broken loop have inner diameters of 73.7 mm and 46.1 mm respectively. Measurement inserts are installed at the inlet and outlet of each major component. Special cross section adapters at the pump inlet and outlet are required for connecting each pump to the main coolant pipes which have a different inner tube diameter.

3.7 Break Device

The break device installed in the LOBI-MOD2 test facility for the small break test series consists of a T-shaped insert connected across the main coolant pipe at the selected break location, a break orifice, a quick-opening valve installed downstream of the break orifice and a discharge line which is heavily instrumented to provide the required information for break flow calculation.

The break orifice is housed in a recess machined in the branch of the insert. Breaks of different size are simulated with break orifices of different diameters. The break is initiated by a quick opening, ball-type, valve flanged to the break insert on one side and to the discharge line on the other side. The discharge line is essentially an instrumented spool piece mounted downstream of the break valve (Fig. A.5).

3.8 Containment


The LOBI break device is situated within a concrete bunker, which encloses the vessel side sections of the cold leg and of the hot leg as well as the bottom part of the loop seal of the broken loop. All these locations are provided with the necessary hardware for simulation of a break. The break device and the main coolant pipe near the break are supported against the hydraulic reaction forces during blowdown by shock arrestors fixed at the bunker wall. The bunker chambers are closed by steel covers and are vented through two open steel pipes of 400 mm inner diameter, 6 mm wall thickness and about 3900 mm length, ending outside the laboratory hall. A condensed water drain pipe of about 4500 mm length, 153 mm inner diameter and 6 mm

wall thickness connects the lower bunker chamber to the atmosphere also outside the laboratory hall.


3.9 Secondary Circuit

The circuit consists of a condenser, a cooler, a feedwater circulation pump and an auxiliary feedwater system comprising two auxiliary feedwater pumps, one for each loop, and a water storage tank. Connecting pipes, valves and control systems are other major functional components of the circuit.


The main feedwater circulation pump is a centrifugal type pump. The intact loop and broken loop auxiliary feedwater pumps are positive displacement type pumps and are rated for respectively 0.208 kg/s and 0.069 kg/s at a delivery pressure of 100 bar when operated at 100 rpm. A speed control device allows variation of delivery head and rate in the corresponding injection lines. The auxiliary feedwater storage tank capacity is sufficient for a period typical of a very small break transient. Isolation valves are installed in both the steam and feedwater lines. Pressure relief valves are installed upstream of the steam line isolation valves. The secondary system can be thus operated to simulate a variety of special transients such as a turbine trip with and without the turbine bypass opening.




A.1 LOBI-MOD2 Primary Cooling Circuits (Schematic)




A.2 LOBI-MOD2 Secondary Cooling Circuit (Schematic)



A.3 LOBI-MOD2 Reactor Pressure Vessel Model (Schematic)



A.4 LOBI-MOD2 Steam Generators (Schematic)



A.5 LOBI-MOD2 Break Insert and Discharge Line

Appendix B

Complete Listing of Input Data for ISP18

601 -505 AND 501 L*
 602 506 AND 513 L*
 603 506 AND 514 L*

*

*

*MINOREDITS * * * * *

*

*PARAMETERS TO BE PREDICTED

*

301	CNTRLVAR	198*	*	PA38
302	CNTRLVAR	401*	*	PA40
303	CNTRLVAR	199*	*	WH-POWER
304	CNTRLVAR	207*	*	RP71
305	CNTRLVAR	301*	*	CM05
306	CNTRLVAR	801*	*	QM55
307	CNTRLVAR	204*	*	TF11T
308	CNTRLVAR	203*	*	TF11B
309	CNTRLVAR	206*	*	TF16T
310	CNTRLVAR	205*	*	TF16B
311	CNTRLVAR	351*	*	TF21T
312	CNTRLVAR	350*	*	TF21B
313	CNTRLVAR	353*	*	TF26T
314	CNTRLVAR	352*	*	TF26B
315	CNTRLVAR	189*	*	TF35
316	CNTRLVAR	201*	*	DD11
317	CNTRLVAR	208*	*	DD14
318	CNTRLVAR	202*	*	DD16
319	CNTRLVAR	354*	*	DD21
320	CNTRLVAR	355*	*	DD24
321	CNTRLVAR	356*	*	DD25
322	CNTRLVAR	357*	*	DD26
323	CNTRLVAR	184*	*	DS35
324	CNTRLVAR	286*	*	PD9217
325	CNTRLVAR	287*	*	PD1714
326	CNTRLVAR	317*	*	PD8227
327	CNTRLVAR	318*	*	PD2724
328	CNTRLVAR	179*	*	PD3DBT
329	CNTRLVAR	178*	*	PD3RTK
330	CNTRLVAR	177*	*	PD3RKA
331	CNTRLVAR	281*	*	PD90BN
332	CNTRLVAR	312*	*	PD80BN
333	CNTRLVAR	176*	*	PD3R39
334	CNTRLVAR	405*	*	CL4340
335	CNTRLVAR	175*	*	TH04
336	CNTRLVAR	174*	*	TH07
337	CNTRLVAR	173*	*	TH09
338	CNTRLVAR	172*	*	TH11
339	CNTRLVAR	171*	*	TH13
340	CNTRLVAR	170*	*	TH14
341	CNTRLVAR	544*	*	PA97S
342	CNTRLVAR	545*	*	TF95B
343	CNTRLVAR	546*	*	TF95N
344	CNTRLVAR	547*	*	TF97T
345	CNTRLVAR	672*	*	TF85B
346	CNTRLVAR	673*	*	TF85K
347	CNTRLVAR	674*	*	TF87T
348	CNTRLVAR	548*	*	CM93G
349	CNTRLVAR	675*	*	CM83G
350	CNTRLVAR	549*	*	CM65

351 CNTRLVAR 676* * CM66
 352 CNTRLVAR 552* * CL93BN
 353 CNTRLVAR 635* * CL83BN

*

* OTHER MINOR EDIT VARIABLES

*

* LIQUID MASS INVENTORY

354 CNTRLVAR 534 * SGI
 355 CNTRLVAR 634 * SGII
 356 CNTRLVAR 190 * WH-POW ALT. DEF.
 357 CNTRLVAR 001 * TOT. HEAT LOSS
 358 CNTRLVAR 031 * VESSEL COLL. LIQUID LEVEL
 359 CNTRLVAR 222 * THTSG1
 360 CNTRLVAR 332 * THTSG2
 361 CNTRLVAR 308 * LEAK MASS LOSS
 362 CNTRLVAR 310 * LEAK HEAT REMOVAL

*

*

* SYSTEM CONTROL VARIABLES

20500100	LOSS-SY	SUM	1.	0.	1		
20500101	0.	1.	CNTRLVAR	124	1.	CNTRLVAR	212
+			CNTRLVAR	345	1.	CNTRLVAR	404
+			CNTRLVAR	543	1.	CNTRLVAR	663
+			CNTRLVAR	701			

*

*VESSEL

*

*

*VS CONTROL VARIABLES

*

20503100	VSLL	SUM	1.000	0	1*	VESSEL	LIQUID	LEVEL
*	A0	LENGTH	VAR.	CODE	LENGTH	VAR.	CODE	
20503101	0.0	0.3730	VOIDF	120010000	0.5300	VOIDF	130010000	
+		0.4720	VOIDF	140010000	0.6120	VOIDF	150010000	
+		0.6630	VOIDF	150020000	0.4375	VOIDF	150030000	
+		0.4375	VOIDF	150040000	0.4375	VOIDF	150050000	
+		0.4375	VOIDF	150060000	0.6630	VOIDF	150070000	
+		0.7400	VOIDF	150080000	0.4218	VOIDF	170010000	
+		0.4218	VOIDF	180010000	0.4218	VOIDF	180020000	
+		0.4218	VOIDF	180030000	0.3150	VOIDF	190010000	

*

*

20510000	DUMMY	SUM	1.	0.	1
20510001	0.	1.0	CPUTIME	0	

*

*

* PRESSURE DROPS

20510100	PD163DB3	SUM	1.-6	0.	1*	L18
20510200	PD263DB7	SUM	1.-6	0.	1*	L28
20510300	PD3DBT	SUM	1.-6	0.	1*	V1
20510400	PD3DTU02	SUM	1.-6	0.	1*	V2
20510500	PD3D3RUU	SUM	1.-6	0.	1*	V3+V4+V5
20510700	PD3RYU21	SUM	1.-6	0.	1*	V5
20510800	PD3RUG11	SUM	1.-6	0.	1*	V6
20510900	PD3RGF12	SUM	1.-6	0.	1*	V7
20511000	PD3R11A4	SUM	1.-6	0.	1*	L11
20511100	PD3R21A3	SUM	1.-6	0.	1*	L21
20511200	PD161133	SUM	1.-6	0.	1*	L19
20511300	PD262133	SUM	1.-6	0.	1*	L29

*
*
20510101 0. 1.0 P 270010000 -1.0 P 110010000 *L18
+ .40207 RHO 110010000
20510201 0. 1.0 P 395010000 -1.0 P 110010000 *L28
+ .40207 RHO 110010000
20510301 0. 1.0 P 110010000 -1.0 P 110100000 *V1
+ -.40207 RHO 110010000 2.29472 RHO 110100000
20510401 0. 1.0 P 110100000 -1.0 P 110110000 *V2
+ -2.29472 RHO 110100000 1.72594 RHO 110110000
20510501 0. 1.0 P 110110000 -1.0 P 140010000 *V3+V4+V5
+ -1.72594 RHO 110110000 1.72594 RHO 140010000
20510701 0. 1.0 P 120010000 -1.0 P 140010000 *V5
+ 3.64802 RHO 120010000 1.72594 RHO 140010000
20510801 0. 1.0 P 140010000 -1.0 P 170010000 *V6
+ -1.72592 RHO 140010000 -.92181 RHO 170010000
20510901 0. 1.0 P 170010000 -1.0 P 180030000 *V7
+ .92181 RHO 170010000 2.02014 RHO 180030000
20511001 0. 1.0 P 180030000 -1.0 P 200010000 *L11
+ -2.02014 RHO 200010000
20511101 0. 1.0 P 180030000 -1.0 P 300010000 *L21
+ -2.02014 RHO 300010000
*
* HEAT LOSSES
*
20511600 L1901 SUM 1. 0. 1* UPPER TUBE SHEET
20511700 L1000 SUM 1. 0. 1* UPPER DOWNCOMER
20511800 L1100 SUM 1. 0. 1* DOWNCOMER
20511900 L1101 SUM 1. 0. 1* LOWER DOWNCOMER
20512000 L1200 SUM 1. 0. 1* LOWER PLENUM
20512100 L1201 SUM 1. 0. 1* BOTTOM
20512200 L1950 SUM 1. 0. 1* UPPER HEAD TUBING
20512300 L1960 SUM 1. 0. 1* UPPER HEAD VESSEL
20512400 LOSS-VS SUM 1.-3 0. 1* RPVM TOTAL
*
*
*
20511601 0. 0.030000 HTRNR 190100101
20511701 0. 0.418520 HTRNR 100000101
20511801 0. 0.600550 HTRNR 110000101 0.600550 HTRNR 110000201
+ 0.600550 HTRNR 110000301 0.600550 HTRNR 110000401
+ 1.053600 HTRNR 110000501 0.943960 HTRNR 110000601
+ 1.245800 HTRNR 110000701 1.245800 HTRNR 110000801
+ 0.943960 HTRNR 110000901 0.871350 HTRNR 110001001
20511901 0. 0.621990 HTRNR 110100101 0.698420 HTRNR 110100201
20512001 0. 0.458440 HTRNR 120000101
20512101 0. 0.072880 HTRNR 120100101
20512201 0. 0.258020 HTRNR 195000101 0.232350 HTRNR 195000201
+ 0.172910 HTRNR 195000301 0.172910 HTRNR 195000401
+ 0.172910 HTRNR 195000501 0.172910 HTRNR 195000601
+ 0.172910 HTRNR 195000701 0.245320 HTRNR 195000801
+ 0.189390 HTRNR 195000901 0.189120 HTRNR 195001001
20512301 0. 0.770070 HTRNR 196000101 0.650440 HTRNR 196000201
+ 0.650440 HTRNR 196000301 0.650440 HTRNR 196000401
20512401 0. 1. CNTRLVAR 116 1. CNTRLVAR 117
+ 1. CNTRLVAR 118 1. CNTRLVAR 119
+ 1. CNTRLVAR 120 1. CNTRLVAR 121

	1.	CNTRLVAR 122	1.	CNTRLVAR 123
*				
20515000	BYPASS	SUM 1.0 0. 1*		
20515100	ILFLOW	SUM 1.0 0. 1*		
20515200	BLFLOW	SUM 1.0 0. 1*		
*	A0 A	VAR CODE	A VAR	CODE
20515001	0. 1.	MFLOWJ 190010000	1. MFLOWJ	100050000 *
+		1. MFLOWJ 100060000		
20515101	0. 1.	MFLOWJ 190040000	1. MFLOWJ	100050000 * I.L
20515201	0. 1.	MFLOWJ 190050000	1. MFLOWJ	100060000 * B.L
*				
* QUANTITIES TO BE PREDICTED				
*				
20517000	TH14	SUM 1.0 0. 1		
20517001	-273.16	1. HTTEMP 170000505		
20517100	TH13	SUM 1.0 0. 1		
20517101	-273.16	1. HTTEMP 170000205		
20517200	TH11	SUM 1.0 0. 1		
20517201	-273.16	1. HTTEMP 150800105		
20517300	TH09	SUM 1.0 0. 1		
20517301	-273.16	1. HTTEMP 150400105		
20517400	TH07	SUM 1.0 0. 1		
20517401	-273.16	1. HTTEMP 150300305		
20517500	TH04	SUM 1.0 0. 1		
20517501	-273.16	1. HTTEMP 150200105		
20517600	PD3R39	SUM 1.-6 0. 1		
20517601	0. 1.	CNTRLVAR 180		
20517602	0.5	P 180030000 0.5 P 190010000		
20517603	-0.5	P 194060000 -0.5 P 195010000		
20517700	PD3RKA	SUM 1.-6 0. 1		
20517701	0. 1.	CNTRLVAR 181		
20517702	1.	P 150080000		
20517703	-0.5	P 180030000 -0.5 P 190010000		
20517800	PD3RTK	SUM 1.-6 0. 1		
20517801	0. 1.	CNTRLVAR 182		
20517802	0.5	P 110090000 0.5 P 110100000		
20517803	-1.	P 150080000		
20517900	PD3DBT	SUM 1.-6 0. 1		
20517901	0. 1.	CNTRLVAR 183		
20517902	1.	P 110010000		
20517903	-0.5	P 110090000 -0.5 P 110100000		
20518000	D4	SUM 9.81 0. 1		
20518001	0. .0025	RHO 180030000 .0025 RHO 190010000		
20518002	-0.0365	RHO 194060000 -.0365 RHO 195010000		
20518100	D3	SUM 9.81 0. 1		
20518101	0. -.157	RHO 150080000		
20518102	-.0025	RHO 180030000 -.0025 RHO 190010000		
20518200	D2	SUM 9.81 0. 1		
20518201	0. .036	RHO 110090000 .036 RHO 110100000		
20518202	.157	RHO 150080000		
20518300	D1	SUM 9.81 0. 1		
20518301	0. -.041	RHO 110010000		
20518302	-.036	RHO 110090000 -.036 RHO 110100000		
20518400	DS35	SUM 1. 0. 1		
20518401	0. 1.	RHO 130010000		
20518500	DD26	SUM 1. 0. 1		
20518501	0. 1.	RHO 395010000		
20518600	DD21	SUM 1. 0. 1		
20518601	0. 1.	RHO 300010000		

20518900	TF35	SUM	1.	0.	1
20518901	-273.16	1.	TEMPF	130010000	

20519000	WH-POWE	SUM	1.-6	0.	0	
20519001	0. .31848	HTRNR	140000101	.43228	HTRNR	150000101
20519002	.89023	HTRNR	150100101	1.4330	HTRNR	150200101
20519003	.94562	HTRNR	150300101	.94562	HTRNR	150300201
20519004	.94562	HTRNR	150300301	.94562	HTRNR	150300401
20519005	1.4330	HTRNR	150400101			
20519006	.89057	HTRNR	150800101	.70888	HTRNR	150900101
20519007	.91168	HTRNR	170000101	.91168	HTRNR	170000201
20519008	.91168	HTRNR	170000301	.91168	HTRNR	170000401
20519009	.68085	HTRNR	170000501			
20519100	TRIPCOND	TRIPUNIT	1.	0.	0	
20519101	507					
20519200	TRIPTIME	TRIPDISPLAY	1.	0.	1	
20519201	507					
20519300	ARGUM	SUM	1.	0.	1	
20519301	0. 1. TIME	0	-1.	CNTRLVAR	192	
20519400	MULTP	MULT	1.	1.	0	
20519401	CNTRLVAR	191		CNTRLVAR	193	
20519900	WH-POWER	FUNCTION	1.-6	0.	0	
20519901	CNTRLVAR	194	900			

20519800	PA38	SUM	.5-6	0.	1
20519801	0.	1.	P	180030000	1. P 190010000

*

*VS VOLUMES

*

1000000 '03-12-84' BRANCH * UPPER DOWNCOMER (INLET ANNULUS)

* NO.J CONTROL

1000001 06 0 *

*	AREA	LENGTH	VOLUME	H.A.	V.ANGLE	ELEVAT.	ROUGH	DIAM.	FE
1000101	.0000000	0.3150	.0035626	0.0	+90.000	+0.3150	8.0-5	.0240	00*

* CONTROL PRESSURE ENERGY QUALITY

1000200 0 15.909+6 1.2826+6 0. *

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS

1001101 100000000 110000000 .009240 00.00 00.00 0100 *

1002101 100010000 192000000 .000000 1.93 2.43 0000 *

1003101 270010000 100000000 .002253 00.00 00.00 0100 *

1004101 395010000 100000000 .000796 00.00 00.00 0100 *

1005101 100000000 200000000 .000000 20000. 20000. 0000 *

1006101 100000000 300000000 .000000 16000. 16000. 0000 *

* LIQUID VEL. VAPOR VEL. INTERFACE VEL

1001201 3.0976 3.0976 0.0*

1002201 4.2399 4.2399 0.0*

1003201 6.7069 6.7069 0.0*

1004201 5.4772 5.4772 0.0*

1005201 0.12689 0.12689 0.0*

1006201 0.14484 0.14484 0.0*

*

*

1100000 '03-12-84' ANNULUS * DOWNCOMER

* VOLUMES

1100001 12 *

* AREA VOL.NO.

1100101 .011310 12 *

* J.AREA JUN.NO.

1100201 .000000 11 *

* LENGTH VOL.NO.

1100301 0.4218 4 *
 1100302 0.7400 5 *
 1100303 0.6630 6 *
 1100304 0.8750 8 *
 1100305 0.6630 9 *
 1100306 0.6120 10 *
 1100307 0.4720 11 *
 1100308 0.5300 12 *

* VOLUME V.NO.

1100401 .0000000 12 *

* H.A V.NO.

1100501 0.0 12 *

* V.ANGLE V.NO.

1100601 -90.000 12 *

* ROUGH. DIAM. V.NO.

1100801 8.00-6 .0260 12 * 27/11/84

* K(FORD) K(REV) J.NO.

1100901 00.00 00.00 11 *

* FE V.NO

1101001 00 12 *

* CAHS J.NO.

1101101 0000 11 *

* CONTROL PRESSURE ENERGY QUALITY VOL NO.

1101201	0	15.907+6	1.2827+6	0.	0.	1 *
1101202	0	15.909+6	1.2828+6	0.	0.	2 *
1101203	0	15.911+6	1.2829+6	0.	0.	3 *
1101204	0	15.913+6	1.2830+6	0.	0.	4 *
1101205	0	15.916+6	1.2830+6	0.	0.	5 *
1101206	0	15.920+6	1.2830+6	0.	0.	6 *
1101207	0	15.924+6	1.2830+6	0.	0.	7 *
1101208	0	15.928+6	1.2831+6	0.	0.	8 *
1101209	0	15.932+6	1.2831+6	0.	0.	9 *
1101210	0	15.935+6	1.2831+6	0.	0.	10 *
1101211	0	15.938+6	1.2829+6	0.	0.	11 *
1101212	0	15.940+6	1.2827+6	0.	0.	12 *

* CONTROL

1101300 0

* LIQUID VEL. VAPOR VEL. 0 JUN NO.

1101301	3.0977	3.0977	0.	1
1101302	3.0978	3.0978	0.	2
1101303	3.0980	3.0980	0.	3
1101304	3.0981	3.0981	0.	4
1101305	3.0981	3.0981	0.	5
1101306	3.0981	3.0981	0.	6
1101307	3.0982	3.0982	0.	7
1101308	3.0982	3.0982	0.	8
1101309	3.0981	3.0981	0.	9
1101310	3.0981	3.0981	0.	10
1101311	3.0979	3.0979	0.	11

*

1200000 '03-12-84' BRANCH * LOWER PLENUM

* NO.J CONTROL

1200001 02 0 *

* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE

1200101 .000000 0.3730 .0245926 0.0 +90.000 +0.3730 8.0-5 .3120 00*

* CONTROL PRESSURE ENERGY QUALITY

1200200 0 15.942+6 1.2827+6 0. *

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS

1201101 110010000 120010000 .000000 01.24 00.65 0000 *27/11/84
 1202101 120010000 130000000 .000000 00.63 01.20 0000 *27/11/84
 * LIQUID VEL. VAPOR VEL. INTERFACE VEL
 1201201 3.0976 3.0976 0.0 *
 1202201 1.1856 1.1856 0.0 *
 *
 1300000 '03-12-84' SNGLVOL * CORE INLET LOWER VOLUME
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 1300101 .000000 0.5300 .0156614 0.0 +90.000 +0.5300 8.0-5 .198 00*
 * CONTROL PRESSURE ENERGY QUALITY
 1300200 0 15.938+6 1.2827+6 0. *
 *
 1400000 '03-12-84' BRANCH * CORE INLET UPPER VOLUME
 * NO.J CONTROL
 1400001 03 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 1400101 .000000 0.4720 .0101112 0.0 +90.000 +0.4720 8.0-5 .1300 00*
 * CONTROL PRESSURE ENERGY QUALITY
 1400200 0 15.928+6 1.2921+6 0. *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 1401101 130010000 140000000 .000000 05.52 05.50 0000 *29/11/84
 1402101 140010000 150000000 .000000 05.52 05.50 0000 *29/11/84
 1403101 140010000 160000000 .000000 50.00 50.00 0000 *29/11/84
 *
 * LIQUID VEL. VAPOR VEL. INTERFACE VEL
 1401201 1.6354 1.6354 0.0 *
 1402201 4.1935 4.1935 0.0 *
 1403201 1.2648 1.2648 0.0 *
 *
 1500000 '03-12-84' PIPE * CORE (HEATED TUBES BUNDLE)
 * VOLUMES
 1500001 08 *
 * AREA VOL.NO.
 1500101 .008115 8 *
 * J.AREA JUN.NO.
 1500201 .007350 07 *
 * LENGTH VOL.NO.
 1500301 0.6120 1 *
 1500302 0.6630 2 *
 1500303 0.4375 6 *
 1500304 0.6630 7 *
 1500305 0.7400 8 *
 * VOLUME V.NO.
 1500401 .0000000 8 *
 * H.A V.NO.
 1500501 0.0 8 *
 * V.ANGLE V.NO.
 1500601 +90.000 8 *
 * ROUGH. DIAM. V.NO.
 1500801 8.0-6 .0135 8 *27/11/84
 * K(FORD) K(REV) J.NO.
 1500901 00.00 00.00 07 *
 * FE V.NO
 1501001 00 8 *
 * CAHS J.NO.
 1501101 0100 07 *
 * CONTROL PRESSURE ENERGY QUALITY VOL NO.
 1501201 0 15.881+6 1.3065+6 0. 0. 1 *
 1501202 0 15.870+6 1.3352+6 0. 0. 2 *

1501203	0	15.861+6	1.3582+6	0.	0.	3	*
1501204	0	15.853+6	1.3813+6	0.	0.	4	*
1501205	0	15.846+6	1.4044+6	0.	0.	5	*
1501206	0	15.838+6	1.4273+6	0.	0.	6	*
1501207	0	15.829+6	1.4560+6	0.	0.	7	*
1501208	0	15.817+6	1.4716+6	0.	0.	8	*

* CONTROL

1501300 0

	LIQUID VEL.	VAPOR VEL.	0	JUN NO.	
1501301	4.2248	4.2248	0.	1	*
1501302	4.2894	4.2894	0.	2	*
1501303	4.3449	4.3449	0.	3	*
1501304	4.4021	4.4021	0.	4	*
1501305	4.4640	4.4640	0.	5	*
1501306	4.5284	4.5284	0.	6	*
1501307	4.6139	4.6139	0.	7	*

*

1600000 '03-12-84' PIPE * CORE BYPASS

* VOLUMES

1600001 06 *

* AREA VOL.NO.

1600101 .0009263 6 *

* J.AREA JUN.NO.

1600201 .0000000 05 *

* LENGTH VOL.NO.

1600301 0.6120 1 *

1600302 0.6630 2 *

1600303 0.8750 4 *

1600304 0.6630 5 *

1600305 0.7400 6 *

* VOLUME V.NO.

1600401 .0000000 6 *

* H.A V.NO.

1600501 0.0 6 *

* V.ANGLE V.NO.

1600601 +90.000 6 *

* ROUGH. DIAM. V.NO.

1600801 5.0-6 .0030 6 *

* K(FORD) K(REV) J.NO.

1600901 00.00 00.00 05 *

* FE V.NO

1601001 00 6 *

* CAHS J.NO.

1601101 0000 05 *

* CONTROL PRESSURE ENERGY QUALITY VOL NO.

1601201	0	15.893+6	1.2926+6	0.	0.	1	*
---------	---	----------	----------	----	----	---	---

1601202	0	15.885+6	1.2946+6	0.	0.	2	*
---------	---	----------	----------	----	----	---	---

1601203	0	15.876+6	1.2992+6	0.	0.	3	*
---------	---	----------	----------	----	----	---	---

1601204	0	15.865+6	1.3075+6	0.	0.	4	*
---------	---	----------	----------	----	----	---	---

1601205	0	15.855+6	1.3140+6	0.	0.	5	*
---------	---	----------	----------	----	----	---	---

1601206	0	15.846+6	1.3214+6	0.	0.	6	*
---------	---	----------	----------	----	----	---	---

* CONTROL

1601300 0

	LIQUID VEL.	VAPOR VEL.	0	JUN NO.	
--	-------------	------------	---	---------	--

1601301	1.2652	1.2652	0.	1	*
---------	--------	--------	----	---	---

1601302	1.2665	1.2665	0.	2	*
---------	--------	--------	----	---	---

1601303	1.2696	1.2696	0.	3	*
---------	--------	--------	----	---	---

1601304	1.2750	1.2750	0.	4	*
---------	--------	--------	----	---	---

1601305	1.2793	1.2793	0.	5	*
---------	--------	--------	----	---	---

*

1700000 '03-12-84' BRANCH * UPPER PLENUM LOWER VOLUME

* NO.J CONTROL

1700001 03 0 *

* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE

1700101 .025450 0.4218 .00000 0.0 +90.000 +0.4218 1.0-6 .0350 00*27/11

* CONTROL PRESSURE ENERGY QUALITY

1700200 0 15.810+6 1.4696+6 0. * *

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS

1701101 150010000 170000000 .007350 00.00 00.00 0100 *29/11/84

1702101 160010000 170000000 .000000 50.00 50.00 0000 *29/11/84

1703101 170010000 180000000 .020000 0.0 0.0 0100 *29/11/84

* LIQUID VEL VAPOR VEL. INTERFACE VEL

1701201 4.6641 4.6641 0.0 * *

1702201 1.2842 1.2842 0.0 * *

1703201 1.5362 1.5362 0.0 * *

*

1800000 '03-12-84' PIPE * UPPER PLENUM MIDDLE VOLUMES

* VOLUMES

1800001 03 *

* AREA VOL.NO.

1800101 .025500 3 *

* J.AREA JUN.NO.

1800201 .020000 02 *

* LENGTH VOL.NO.

1800301 0.4218 3 *

* VOLUME V.NO.

1800401 .0000000 3 *

* H.A V.NO.

1800501 0.0 3 *

* V.ANGLE V.NO.

1800601 +90.000 3 *

* ROUGH. DIAM. V.NO.

1800801 1.0-6 .0400 3 *27/11/84

* K(FORD) K(REV) J.NO.

1800901 00.00 00.00 02 *

* FE V.NO

1801001 00 3 *

* CAHS J.NO.

1801101 0100 02 *

* CONTROL PRESSURE ENERGY QUALITY VOL NO.

1801201 0 15.807+6 1.4725+6 0. 0. 1*

1801202 0 15.804+6 1.4754+6 0. 0. 2*

1801203 0 15.801+6 1.4783+6 0. 0. 3*

* CONTROL

1801300 0

* LIQUID VEL. VAPOR VEL. 0 JUN NO.

1801301 1.5363 1.5363 0. 1 *

1801302 1.5394 1.5394 0. 2 *

*

1900000 '03-12-84' BRANCH * UPPER PLENUM UPPER VOLUME

* NO.J CONTROL

1900001 05 0 *

* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE

1900101 .025450 0.315 .0000000 0.0 +90.000 +0.315 1.4-6 .0440 00*

* CONTROL PRESSURE ENERGY QUALITY

1900200 0 15.799+6 1.4716+6 0. *

*

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS

1901101 100010000 190010000 .000000 3.00+5 3.00+5 0000 *
 1902101 195010000 190010000 .000000 02.43 01.93 0000 *
 1903101 180010000 190000000 .000000 00.00 00.00 0100 *27/11/84
 1904101 190000000 200000000 .003324 00.00 00.00 0100 *27/11/84
 1905101 190000000 300000000 .001078 00.00 00.00 0100 *27/11/84
 * LIQUID VEL VAPOR VEL. INTERFACE VEL.
 1901201 2.6848-2 2.6848-2 0.0 *
 1902201 4.2388 4.2388 0.0 *
 1903201 1.5455 1.5455 0.0 *
 1904201 7.3430 7.3430 0.0 *
 1905201 5.9527 5.9527 0.0 *
 *
 1920000 '03-12-84' SNGLVOL * UPPER HEAD INLET TUBE UPTO TEE
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 1920101 .000314 0.9554 .0000000 0.0 +6.008 +0.1000 8.0-5 .0200 00*
 * CONTROL PRESSURE ENERGY QUALITY
 1920200 0 15.883+6 1.2825+6 0. 0. *
 *
 *
 1930000 '03-12-84' BRANCH * UPPER HEAD BYPASS WITH ORIFICE
 * JUNCTIONS CNTL
 1930001 3 0*
 * FROM TO AREA FORWARD REVERSE CAHS
 1931101 196010000 193000000 0.0 0.51 0.95 0000*
 1932101 192010000 193010000 0.0 72.0 72.90 0000*
 1933101 193000000 195000000 0.0 3.0 3.1 0000*
 * LIQUID VAPOR 0
 1931201 3.0985 3.0985 0.0 *
 1932201 1.1403 1.1403 0.0 *
 1933201 4.2388 4.2388 0.0 *.
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 1930101 .000314 0.8600 0.0 0.0 -22.926 -0.335 8.0-5 .0200 00*
 * CONTROL PRESSURE ENERGY QUALITY
 1930200 0 15.851+6 1.2820+6 0. *
 *
 *
 1940000 '03-12-84' PIPE * UPPER HEAD INLET TUBE FROM TEE
 * VOLUMES
 1940001 6 *
 * AREA VOL.NO.
 1940101 .000314 6 *
 * J.AREA JUN.NO.
 1940201 .000000 5 *
 * LENGTH VOL.NO.
 1940301 0.6400 5 *
 1940302 0.9083 6 *
 * VOLUME V.NO.
 1940401 .0000000 6 *
 * V.ANGLE V.NO.
 1940601 +90.000 5 *
 1940602 -10.082 6 *
 * ROUGH. DIAM. V.NO.
 1940801 8.0-5 .0200 6 *
 * K(FORD) K(REV) J.NO.
 1940901 00.00 00.00 04 *
 1940902 0.34 0.34 05 *
 * FE V.NO
 1941001 00 6 *
 * CAHS J.NO.

1941101 0000 05 *

	CONTROL	PRESSURE	ENERGY	QUALITY	VOL NO.
1941201	0	15.876+6	1.2825+6	0.	0.
1941202	0	15.868+6	1.2824+6	0.	0.
1941203	0	15.860+6	1.2823+6	0.	0.
1941204	0	15.852+6	1.2822+6	0.	0.
1941205	0	15.844+6	1.2822+6	0.	0.
1941206	0	15.837+6	1.2820+6	0.	0.

* CONTROL

1941300 0

	LIQUID VEL.	VAPOR VEL.	0	JUN NO.
1941301	3.0995	3.0995	0.	1
1941302	3.0994	3.0994	0.	2
1941303	3.0993	3.0993	0.	3
1941304	3.0992	3.0992	0.	4
1941305	3.0991	3.0991	0.	5

*

	'NAME'	TYPE
1950000	'03-12-84'	PIPE *
		UPPER HEAD OUTLET TUBE

* VOLUMES

1950001 02

	VOL AREA	VOL NO.
1950101	0.000314	02*

* JUN AREA JUN NO.

1950201 0.0 01*

* LENGTH VOL NO.

1950301 0.7013 01*

1950302 0.7000 02*

* ANGLE VOL NO.

1950601 -38.336 01

1950602 00.00 02

* ROUGHNESS DIAM VOL NO.

1950801 8.0-5 0.02 02

* FORWARD REVERSE JUN NO.

1950901 00.2 0.2 01

* FE-FLAG VOL NO.

1951001 00 02

* CAHS-FLAG JUN NO.

1951101 0000 01

	CNTL PRESSURE	ENERGY	QUALITY	VOL NO.
1951201	0 15.817+6	1.2820+6	0.	0.
1951202	0 15.811+6	1.2819+6	0.	0.

* CNTL

1951300 0*

	LIQUID	VAPOR	0	JUN NO.
1951301	4.2389	4.2389	0.0	01*

*

	'03-12-84'	PIPE *	UPPER HEAD VESSEL
--	------------	--------	-------------------

* VOLUMES

1960001 4 *

	AREA	VOL.NO.
1960101	.011310	4 *

* J.AREA JUN.NO.

1960201 .000000 3 *

* LENGTH VOL.NO.

1960301 0.7660 1 *

1960302 0.6466 4

* VOLUME V.NO.

1960401 .0000000 4 *

* V.ANGLE V.NO.
 1960601 -90.000 4 *
 * ROUGH. DIAM. V.NO.
 1960801 8.0-5 .1200 4 *
 * K(FORD) K(REV) J.NO.
 1960901 00.00 00.00 3 *
 * FE V.NO
 1961001 00 4 *
 * CAHS J.NO.
 1961101 0000 3 *
 * CONTROL PRESSURE ENERGY QUALITY VOL NO.
 1961201 0 15.838+6 1.2819+6 0. 0. 1 *
 1961202 0 15.843+6 1.2819+6 0. 0. 2 *
 1961203 0 15.848+6 1.2818+6 0. 0. 3 *
 1961204 0 15.852+6 1.2819+6 0. 0. 4 *

* CONTROL
 1961300 0
 * LIQUID VEL. VAPOR VEL. 0 JUN NO.
 1961301 8.6031-2 8.6031-2 0. 1 *
 1961302 8.6028-2 8.6028-2 0. 2 *
 1961303 8.6024-2 8.6024-2 0. 3 *

*
 * 'NAME' TYPE
 1970000 '03-12-84' VALVE *
 * FROM TO AREA FORWARD REVERSE CAHS
 1970101 192010000 194000000 0.000314 0.86 0.86 0100*
 * CNTL LIQUID V. VAPOR V. 0
 1970201 0 3.0996 3.0996 0.*
 * VALVE * TYPE
 1970300 MTRVLV *
 * TRIP NO
 1970301 502 503 0.125 1.0

*
 * 'NAME' TYPE
 1980000 '03-12-84' SNGLJUN *
 * FROM TO AREA FORWARD REVERSE CAHS
 1980101 194010000 196000000 0.0 1.11 0.28 0000 *
 * CNTL LIQUID V. VAPOR V. 0
 1980201 0 3.0990 3.0990 0.0*

*VS STRUCTURES
 *

 * VESSEL SIMULATOR WALL UPPER DOWNCOMER

11000000	1	7	2	1	.156
11000100	0		1		
11000101	6		0.21146		
11000201	1		6		
11000301	0.0		6		
11000400	-1				
11000401		559.08,549.79,540.89,532.34,524.10,516.14,508.43			
11000501	100010000	0	1	1	0.3150 1
11000601	-919	0	3929	1	0.315 1
11000701	0	0.0	0.0	0.0	1
11000801	0	.024	0.0	0.0	1

 * VESSEL SIMULATOR WALL FROM TOP TO TO LOWER DOWNCOMER

11100000	10	10	2	1	.156			
11100100	0	1						
11100101	6	.1766						
11100102	3	.2266						
11100201	1	6						
11100202	9	9						
11100301	0.0	9						
11100400	-1							
11100401	566.91	566.82	566.74	566.65	566.56	566.46	566.36	474.46
+ 389.56	311.56							
11100402	566.93	566.84	566.76	566.67	566.58	566.48	566.38	474.47
+ 389.57	311.04							
11100403	566.95	566.86	566.77	566.69	566.59	566.50	566.40	474.48
+ 389.57	311.05							
11100404	566.97	566.88	566.79	566.70	566.61	566.52	566.42	474.50
+ 389.58	311.05							
11100405	566.97	566.89	566.80	566.71	566.62	566.53	566.43	474.50
+ 389.58	311.05							
11100406	566.98	566.89	566.81	566.72	566.63	566.53	566.44	474.50
+ 389.58	311.05							
11100407	566.98	566.90	566.81	566.72	566.63	566.54	566.44	474.50
+ 389.58	311.05							
11100408	566.99	566.90	566.82	566.73	566.64	566.55	566.45	474.51
+ 389.58	311.05							
11100409	566.99	566.91	566.82	566.73	566.64	566.55	566.45	474.51
+ 389.58	311.05							
11100410	566.99	566.91	566.82	566.74	566.65	566.55	566.45	474.51
+ 389.59	311.05							
11100501	110010000	10000	1	1	.4218	4		
11100502	110050000	0	1	1	.740	5		
11100503	110060000	0	1	1	.663	6		
11100504	110070000	10000	1	1	.875	8		
11100505	110090000	0	1	1	.663	9		
11100506	110100000	0	1	1	.612	10		
11100601	-919	0	3949	1	.4218	4		
11100602	-919	0	3949	1	.740	5		
11100603	-919	0	3949	1	.663	6		
11100604	-919	0	3949	1	.875	8		
11100605	-919	0	3949	1	.663	9		
11100606	-919	0	3949	1	.612	10		
11100701	0	0.0	0.0	0.0	10			
11100801	0	.024	0.0	0.0	10			

* REACTOR VESSEL WALL-LOWER DOWNCOMER								

11101000	2	7	2	1	.156			
11101100	0	1						
11101101	6	0.20973						
11101201	1	6						
11101301	0.0	6						
11101400	-1							
11101401	566.54	560.67	555.06	549.67	544.46	539.43	534.54	
11101402	566.50	560.64	555.04	549.65	544.44	539.41	534.52	
11101501	110110000	0	1	1	0.4720	1		
11101502	110120000	0	1	1	0.5300	2		
11101601	-919	0	3939	1	0.472	1		
11101602	-919	0	3939	1	0.530	2		
11101701	0	0.0	0.0	0.0	2			
11101801	0	.024	0.0	0.0	2			

* REACTOR VESSEL WALL-LOWER PLENUM

11200000	1	10	2	1	.156			
11200100	0	1						
11200101	6	.17043						
11200102	3	.22043						
11200201	1	6						
11200202	9	9						
11200301	0.0	9						
11200400	-1							
11200401	566.47	566.42	566.37	566.31	566.25	566.18	566.11	473.98
+ 389.18	310.97							
11200501	120010000	0	1	1	.331	1		
11200601	-919	0	3949	1	.331	1		
11200701	0	0.0	0.0	0.0	1			
11200801	0	.312	0.0	0.0	1			

* REACTOR VESSEL WALL-BOTTOM

11201000	1	7	1	1	0.0			
11201100	0	1						
11201101	3	.019						
11201102	3	.069						
11201201	1	3						
11201202	9	6						
11201301	0.0	6						
11201400	-1							
11201401	566.66	566.58	566.46	566.32	482.20	397.60	312.94	
11201501	120010000	0	1	1	.07288	1		
11201601	-919	0	3949	1	.07288	1		
11201701	0	0.0	0.0	0.0	1			
11201801	0	0.0	0.0	0.0	1			

* NICKEL CORD CONNECTION

11400000	1	3	2	1	0.0			
11400100	0	1						
11400101	2	.0024						
11400201	4	2						
11400301	1.0	2						
11400400	-1							
11400401	644.49	640.70	629.34					
11400501	0	0	0	1	21.12	1		
11400601	140010000	0	1	1	21.12	1		
11400701	900	.047	0.0	0.0	1			
11400901	0	.072	.0789	.330	1			

* LOWER POWER CONNECTING RING

11401000	1	8	2	1	.075			
11401100	0	1						
11401101	7	.144						
11401201	1	7						
11401301	0.0	7						
11401400	-1							
11401401	568.72	568.62	568.48	568.29	568.04	567.73	567.37	567.00
11401501	140010000	0	1	1	.472	1		
11401601	110110000	0	1	1	.472	1		

11401701	0	0.0	0.0	0.0	1
11401801	0	.130	0.0	0.0	1
11401901	0	.024	0.0	0.0	1

* NICKEL ROD					

11500000	1	5	2	1	0.0
11500100	0	1			
11500101	4	.005375			
11500201	4	4			
11500301	1.0	4			
11500400	-1				
11500401	576.07	575.90	575.41	574.59	573.44
11500501	0	0	0	1	12.8
11500601	150010000	0	1	1	12.8
11500701	900	.005	0.0	0.0	1
11500901	0	.0135	0.	.200	1

* ACTIVE CORE (VOLUME 15001) *****					

11501000	1	5	2	1	.003225
11501100	0	1			
11501101	4	.005375			
11501201	3	4			
11501301	1.0	4			
11501400	-1				
11501401	605.88	604.36	600.08	593.29	584.16
11501501	0	0	0	1	26.36
11501601	150010000	0	1	1	26.36
11501701	900	.065	0.0	0.0	1
11501901	0	.0135	0.	.412	1

* ACTIVE CORE (VOLUME 15002)					

11502000	1	5	2	1	.003875
11502100	0	1			
11502101	4	.005375			
11502201	3	4			
11502301	1.0	4			
11502400	-1				
11502401	613.47	612.13	608.28	602.07	593.64
11502501	0	0	0	1	42.432
11502601	150020000	0	1	1	42.432
11502701	900	.140	0.0	0.0	1
11502901	0	.0135	0.0	.663	1

* ACTIVE CORE (VOLUMES 15003 AND 15006)					

11503000	4	5	2	1	.004175
11503100	0	1			
11503101	4	.005375			
11503201	3	4			
11503301	1.0	4			
11503400	-1				
11503401	620.49	619.23	615.54	609.56	601.38
11503402	624.28	623.01	619.33	613.37	605.20
11503403	628.09	626.82	623.15	617.20	609.05
11503404	631.77	630.51	626.85	620.91	612.77
11503501	0	0	0	1	28.00
					4

11503601	150030000	10000	1	1	28.00	4
11503701	900	.11275	0.0	0.0	4	
11503901	0	.0135	0.0	.4375	4	

* ACTIVE CORE (VOLUME 15007)						

11504000	1	5	2	1	.003875	
11504100	0	1				
11504101	4	.005375				
11504201	3	4				
11504301	1.0	4				
11504400	-1					
11504401	633.79	632.45	628.59	622.37	613.90	
11504501	0	0	0	1	42.432	1
11504601	150070000	0	1	1	42.432	1
11504701	900	.142	0.0	0.0	1	
11504901	0	.0135	0.0	.663	1	

* ACTIVE CORE (VOLUME 15008)						

11508000	1	5	2	1	.003225	
11508100	0	1				
11508101	4	.005375				
11508201	3	4				
11508301	1.0	4				
11508400	-1					
11508401	633.83	632.31	628.03	621.25	612.12	
11508501	0	0	0	1	26.37	1
11508601	150080000	0	1	1	26.37	1
11508701	900	.066	0.0	0.0	1	
11508901	0	.0135	0.0	.412	1	

* NICKEL TUBE (VOLUME 15008)						

11509000	1	5	2	1	.0025	
11509100	0	1				
11509101	4	.005375				
11509201	4	4				
11509301	1.0	4				
11509400	-1					
11509401	604.95	604.79	604.34	603.64	602.71	
11509501	0	0	0	1	20.99	1
11509601	150080000	0	1	1	20.99	1
11509701	900	.012	0.0	0.0	1	
11509901	0	.0135	0.0	.328	1	

* CERAMIC FILLER (IN CORE REGION)						

11600000	8	10	2	1	.0684	
11600100	0	1				
11600101	9	.0975				
11600201	6	9				
11600301	0.0	9				
11600400	-1					
11600401	571.34	571.02	570.72	570.44	570.16	569.90
+	569.16	568.94				
11600402	576.46	575.55	574.68	573.85	573.05	572.29
+	570.17	569.52				
11600403	580.55	579.23	577.97	576.77	575.62	574.52
						573.46
						572.44

+	571.46	570.52						
11600404	584.45	582.63	580.90	579.25	577.67	576.16	574.71	573.31
+	571.97	570.68						
11600405	592.17	589.55	587.06	584.69	582.43	580.26	578.20	576.21
+	574.30	572.47						
11600406	596.69	593.48	590.43	587.53	584.77	582.14	579.62	577.20
+	574.88	572.66						
11600407	596.73	593.66	590.76	587.99	585.36	582.85	580.44	578.13
+	575.92	573.79						
11600408	599.19	595.98	592.94	590.04	587.29	584.65	582.14	579.72
+	577.41	575.18						
11600501	150010000	0	1	1	.612	1		
11600502	150020000	0	1	1	.663	2		
11600503	150030000	10000	1	1	.4375	4		
11600504	150060000	10000	1	1	.4375	6		
11600505	150070000	0	1	1	.663	7		
11600506	150080000	0	1	1	.740	8		
11600601	160010000	0	1	1	.612	1		
11600602	160020000	0	1	1	.663	2		
11600603	160030000	0	1	1	.4375	4		
11600604	160040000	0	1	1	.4375	6		
11600605	160050000	0	1	1	.663	7		
11600606	160060000	0	1	1	.740	8		
11600701	0	0.0	0.0	0.0	8			
11600801	0	0.0135	0.	0.	8			
11600901	0	0.003	0.	0.	8			

* HONEYCOMB STRUCTURE = CORE BARREL TUBE

11601000	12	5	2	1	.099	
11601100	0	1				
11601101	4	.144				
11601201	8	4				
11601301	0.0	4				
11601400	-1					
11601401	596.72	589.12	582.19	575.82	569.92	
11601402	600.38	590.98	582.41	574.54	567.25	
11601403	599.95	590.67	582.22	574.45	567.26	
11601404	599.52	590.36	582.03	574.37	567.28	
11601405	599.06	590.04	581.83	574.28	567.29	
11601406	574.02	572.06	570.26	568.60	567.06	
11601407	572.69	571.11	569.66	568.31	567.05	
11601408	571.52	570.27	569.12	568.05	567.04	
11601409	570.02	569.19	568.43	567.71	567.03	
11601410	569.17	568.59	568.04	567.52	567.03	
11601411	568.80	568.32	567.87	567.44	567.03	
11601412	566.95	566.98	566.99	566.98	566.95	
11601501	190010000	0	1	1	.315	1
11601502	180030000	-10000	1	1	.4218	4
11601503	170010000	0	1	1	.4218	5
11601504	160060000	0	1	1	.740	6
11601505	160050000	0	1	1	.663	7
11601506	160040000	-10000	1	1	.875	9
11601507	160020000	0	1	1	.663	10
11601508	160010000	0	1	1	.612	11
11601509	130010000	0	1	1	.530	12
11601601	100010000	0	1	1	.315	1
11601602	110010000	10000	1	1	.4218	5
11601603	110050000	0	1	1	.740	6

11601604	110060000	0	1	1	.663	7
11601605	110070000	10000	1	1	.875	9
11601606	110090000	0	1	1	.663	10
11601607	110100000	0	1	1	.612	11
11601608	110120000	0	1	1	.530	12
11601701	0	0.0	0.0	0.0	12	
11601801	0	0.003	0.	0.	12	
11601901	0	0.024	0.	0.	12	

* HEATER TUBES IN UPPER PLENUM

11700000	5	5	2	1	.0025	
11700100	0	1				
11700101	4	.005375				
11700201	4	4				
11700301	1.0	4				
11700400	-1					
11700401	610.24	610.08	609.63	608.94	608.03	
11700402	610.68	610.52	610.07	609.39	608.47	
11700403	611.11	610.95	610.50	609.81	608.90	
11700404	611.54	611.37	610.93	610.24	609.32	
11700405	623.60	623.44	623.00	622.32	621.41	
11700501	0	0	0	1	26.995	4
11700502	0	0	0	1	20.16	5
11700601	170010000	0	1	1	26.995	1
11700602	180010000	10000	1	1	26.995	4
11700603	190010000	0	1	1	20.16	5
11700701	900	.0152	0.0	0.0	4	
11700702	900	.0112	0.0	0.0	5	
11700901	0	.044	0.0	.4218	4	
11700902	0	.044	0.0	.315	5	

*

* UPPER TUBE SHEET

* NH NP TYPE FLAG LEFT BOUNDARY						
11901000	1	6	1	1	0.0	*
*	FLAG	FLAG				
11901100	0	1	*			
*	NO INTERV.,	RIGHT COORD.	OR MESH INTERV.,	MESH NO		
11901101	5	0.195				
*	COMPOS.	NO	INTERV.	NO		
11901201	5	5				
*	SOURCE	INTERV.	NO			
11901301	0.0	5				
11901400	-1					
*	TEMP.	,	POINT NO	OR	TEMPS.	
11901401	594.21	573.97	553.02	531.58	509.74	487.51
*	VOLUME	INCRE	TYPE	AREA CODE	VALUE	STRUCT. NO
11901501	190010000	0	1	1	0.03	1
*	VOLUME	INCRE	TYPE	AREA CODE	VALUE	STRUCT. NO
11901601	-919	0	3929	1	0.03	1
*	SOURCE	TYPE	MULTI	DIRECT HEAT	LEFT	DIRECT HEAT RIGHT NO
11901701	0	0.	0.	0.	0.	1
*	CHF FLAG	HYDR.DIAM	HEAT. DIAM	CHANN.LENGTH	STRUCT NO	
11901801	0	0.044	0.	0.	0.	1

*

***** UPPER HEAD CONNECTION TUBES

* NH NP TYPE FLAG LEFT BOUNDARY
 11950000 10 7 2 1 0.0100 *

* FLAG FLAG
 11950100 0 1 *

* NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 11950101 3 0.013
 11950102 3 0.043

* COMPOS. NO INTERV. NO
 11950201 5 3
 11950202 9 6

* SOURCE INTERV. NO
 11950301 0. 6
 11950400 -1

* TEMP. , POINT NO OR TEMPS.
 11950401 566.84 566.76 566.68 566.61 446.89 369.74 312.78
 11950402 566.62 566.54 566.47 566.40 446.79 369.69 312.77
 11950403 566.80 566.72 566.65 566.58 446.88 369.73 312.78
 11950404 566.79 566.70 566.63 566.56 446.87 369.73 312.78
 11950405 566.77 566.69 566.61 566.55 446.85 369.72 312.78
 11950406 566.75 566.67 566.60 566.53 446.85 369.72 312.78
 11950407 566.73 566.65 566.58 566.51 446.84 369.72 312.78
 11950408 566.71 566.63 566.55 566.49 446.82 369.71 312.77
 11950409 566.70 566.62 566.55 566.48 446.84 369.71 312.77
 11950410 566.69 566.61 566.53 566.47 446.83 369.71 312.77

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 11950501 192010000 0 1 1 0.955 1
 11950502 193010000 0 1 1 0.860 2
 11950503 194010000 10000 1 1 0.640 7
 11950504 194060000 0 1 1 0.908 8
 11950505 195010000 0 1 1 0.701 9
 11950506 195020000 0 1 1 0.700 10

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 11950601 -919 0 3949 1 0.955 1
 11950602 -919 0 3949 1 0.860 2
 11950603 -919 0 3949 1 0.640 7
 11950604 -919 0 3949 1 0.908 8
 11950605 -919 0 3949 1 0.701 9
 11950606 -919 0 3949 1 0.700 10

* SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO
 11950701 0. 0. 0. 0. 0. 10*

* CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 11950801 0 0.020 0. 0. 10*

*

***** UPPER HEAD VESSEL *****

* NH NP TYPE FLAG LEFT BOUNDARY
 11960000 4 10 2 1 0.0600 *

* FLAG FLAG
 11960100 0 1 *

* NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 11960101 6 0.080
 11960102 3 0.160

* COMPOS. NO INTERV. NO
 11960201 5 6
 11960202 9 9

* SOURCE INTERV. NO
 11960301 0. 9

11960400 -1

* TEMP. , POINT NO OR TEMPS.

11960401 566.52 566.48 566.44 566.39 566.34 566.29 566.23 457.71
+ 372.91 303.51

11960402 566.52 566.48 566.44 566.39 566.34 566.29 566.23 457.71
+ 372.91 303.51

11960403 566.52 566.48 566.44 566.40 566.35 566.29 566.23 457.69
+ 372.90 303.51

11960404 566.53 566.49 566.45 566.41 566.36 566.30 566.24 457.69
+ 372.90 303.51

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

11960501 196010000 0 1 1 0.766 1

11960502 196010000 10000 1 1 0.647 4

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

11960601 -919 0 3949 1 0.766 1

11960602 -919 0 3949 1 0.647 4

* SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO

11960701 0. 0. 0. 0. 0. 0. 4

* CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO

11960801 0 0.120 0. 0. 0. 4

*

*

*INTACT LOOP

*

*

*IL CONTROLVARIABLES

*

	DUMMY	SUM	1.	0.	1
20520000					
20520001	0.	1.	CPUTIME	0	
*					
*					
20520100	DD11	SUM	1.	0.	1
20520101	0.	1.	RHO	200010000	
20520200	DD16	SUM	1.	0.	1
20520201	0.	1.	RHO	270010000	
20520300	TF11B	SUM	1.	0.	1
20520301	-273.16	1.	TEMPF	200010000	
20520400	TF11T	SUM	1.	0.	1
20520401	-273.16	1.	TEMPG	200010000	
20520500	TF16B	SUM	1.	0.	1
20520501	-273.16	1.	TEMPF	270010000	
20520600	TF16T	SUM	1.	0.	1
20520601	-273.16	1.	TEMPG	270010000	
20520700	RP71	SUM	9.549297	4820.	0
20520701	0.	1.	PMPVEL	250	
20520800	DD14	SUM	1.	0.	1
20520801	0.	1.	RHO	240080000	
*	HEAT LOSSES				
20521000	L1	SUM	1.-3	0.	1*HEAT LOSS IL
20521001	0.	0.52376	HTRNR	200000101	0.93182 HTRNR 210000101
+	0.58369	HTRNR	220000101	0.25943 HTRNR 230000101	
+	0.25943	HTRNR	230000201	0.25943 HTRNR 230000301	
+	0.25943	HTRNR	230000401	0.48782 HTRNR 230100101	
+	0.48782	HTRNR	230300101	0.25943 HTRNR 230400101	
+	0.25943	HTRNR	230400201	0.25943 HTRNR 230400301	
+	0.25943	HTRNR	230400401	0.49580 HTRNR 240000101	
+	0.38008	HTRNR	240100101	0.38008 HTRNR 240100201	
+	0.46564	HTRNR	240100301	0.29546 HTRNR 240100401	
20521100	L2	SUM	1.-3	0.	1*HEAT LOSS IL

20521101 0. 0.42404 HTRNR 240100501 0.33848 HTRNR 240100601
 + 0.50982 HTRNR 240200101 0.65840 HTRNR 250000101
 + 0.48773 HTRNR 260000101 0.37883 HTRNR 260100101
 + 0.37883 HTRNR 260100201 0.37883 HTRNR 260100301
 + 0.47781 HTRNR 270000101
 20521200 LOSS-IL SUM 1. 0. 1*HEAT LOSS IL
 20521201 0. 1. CNTRLVAR 210 1. CNTRLVAR 211
 *
 * HEAT TRANSFER TO/FROM SG1 (MW)
 20522000 PHTSG1 SUM 1. 0. 1*
 20522100 PHTSG1 SUM 1. 0. 1*
 20522200 THTSG1 SUM 1.-6 0. 1* HEAT TRANSFER TO/FROM SG1
 *
 *
 20522001 0. 1.129500 HTRNR 230200101 1.129500 HTRNR 230200201
 + 1.129500 HTRNR 230200301 1.129500 HTRNR 230200401
 + 1.129500 HTRNR 230200501 1.129500 HTRNR 230200601
 + 1.129500 HTRNR 230200701 1.129500 HTRNR 230200801
 + 1.129500 HTRNR 230200901 1.129500 HTRNR 230201001
 20522101 0. 1.586900 HTRNR 230201101 1.586900 HTRNR 230201201
 + 1.129500 HTRNR 230201301 1.129500 HTRNR 230201401
 + 1.129500 HTRNR 230201501 1.129500 HTRNR 230201601
 + 1.129500 HTRNR 230201701 1.129500 HTRNR 230201801
 + 1.129500 HTRNR 230201901 1.129500 HTRNR 230202001
 + 1.129500 HTRNR 230202101 1.129500 HTRNR 230202201
 20522201 0. 1.0 CNTRLVAR 220 1.0 CNTRLVAR 221
 *
 * PUMP SPEED CONTROLLER
 *
 20526100 SPDCNTLR SUM 1.0 0.0 1
 20526101 21.0 -1.0 MFLOWJ 270010000
 *
 20526200 DEADBAND STDFNCTN 1.0 0.0 1
 20526201 ABS CNTRLVAR 261
 *
 *
 20526300 PMPSPEED INTEGRAL 20.0 513.27 1 *
 20526301 CNTRLVAR 261 *
 *
 *
 20528000 PD90AB46 SUM 1.-6 0 1* S91
 20528100 PD90BNX1 SUM 1.-6 0 1* S92
 20528200 PD92NBX1 SUM 1.-6 0 1* S95
 20528300 PD92BA24 SUM 1.-6 0 1* S98
 20528400 PD9092AA SUM 1.-6 0 1* L13
 20528500 PD1190A SUM 1.-6 0 1* L12
 20528600 PD9217A SUM 1.-6 0 1* L14
 20528700 PD1714 SUM 1.-6 0 1* L15
 20528800 PD151456 SUM 1.-6 0 1* L16(PUMP HEAD)
 20528900 PD251653 SUM 1.-6 0 1* L17
 20529000 PD161133 SUM 1.-6 0 1* L19
 *
 20528001 0.0 1.0 P 230010000 -0.363 RHO 230010000
 + -1.0 P 230060000 -2.452 RHO 230060000
 20528101 0.0 1.0 P 230060000 2.452 RHO 230060000
 + -0.5 P 230160000 1.520 RHO 230160000
 + -0.5 P 230170000 1.520 RHO 230170000
 20528201 0.0 0.5 P 230160000 -1.520 RHO 230160000
 + 0.5 P 230170000 -1.520 RHO 230170000

+ -1.0 P 230270000 -2.452 RHO 230270000
 20528301 0.0 1.0 P 230270000 2.452 RHO 230270000
 + -1.0 P 230320000 0.363 RHO 230320000
 20528401 0.0 1.0 P 230010000 -0.363 RHO 230010000
 + -1.0 P 230320000 0.363 RHO 230320000
 20528501 0.0 1.0 P 200010000 0.186 RHO 200010000
 + -1.0 P 230010000 0.363 RHO 230010000
 20528601 0.0 1.0 P 230320000 -0.363 RHO 230320000
 + -1.0 P 240050000 -0.2450 RHO 240050000
 20528701 0.0 1.0 P 240050000 0.2450 RHO 240050000
 + -1.0 P 240080000 -2.1770 RHO 240080000
 20528801 0.0 1.0 P 240080000 +2.1770 RHO 240080000
 + -1.0 P 260010000 -0.098 RHO 260010000
 20528901 0.0 1.0 P 260010000 0.098 RHO 260010000
 + -1.0 P 270010000 -0.186 RHO 270010000
 20529001 0.0 1.0 P 270010000 0.186 RHO 270010000
 + -1.0 P 200010000 -0.186 RHO 200010000
 *
 *IL VOLUMES
 *
 2000000 '84-12-12' BRANCH * VESSEL OULET NOZZLE
 * NO.J CONTROL
 2000001 01 0 *
 * AREA LENGTH VOLUME O ANGLE O ROUGHN DIAM FE
 2000101 0.0 0.8330 0.0035278 0. 00.275 .004 8.0-5 0.0737 00*
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 2001101 200010000 400000000 .000068 00.00 00.00 0100 *
 * CNTL PRESSURE ENERGY QUALITY
 2000200 0 15.764+6 1.4681+6 0. *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 2001201 -3.3555 -3.3555 0.0 *
 *
 2100000 '20-08-84' BRANCH * CONNECTION WITH PRESSURISER
 * NO.J CONTROL
 2100001 03 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 2100101 .004266 1.9920 .0000000 0.0 +00.201 +0.0070 8.0-5 .0737 00*
 * CONTROL PRESSURE ENERGY QUALITY
 2100200 0 15.744+6 1.4681+6 0. *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 2101101 400000000 210000000 .000068 00.00 00.00 0100 *
 2102101 210010000 220000000 .000000 00.27 00.27 0000 *
 2103101 200010000 210000000 .000000 00.62 00.62 0000 * 0.52
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 2101201 -3.3519 -3.3519 0.0 *
 2102201 7.4751 7.4751 0.0 *
 2103201 7.5754 7.5754 0.0 *
 *
 2200000 '20-08-84' SNGLVOL *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 2200101 .000000 1.0110 .0042772 0.0 +67.494 +0.9340 8.0-5 .0737 00*
 * CONTROL PRESSURE ENERGY QUALITY
 2200200 0 15.728+6 1.4681+6 0. *
 *
 * 'NAME' TYPE
 2250000 '84-12-12' SNGLJUN * S. G. INLET
 * FROM TO AREA
 2250101 220010000 230000000 0.0 0.0 0.0 0000 *

*	CONTROL	LIQUID V.	VAPOR V.	0
2250201	0	7.4753	7.4753	0.0 *
*				
*				
2300000 '84-12-15' PIPE *				
*	VOLUMES			
2300001	32 *			
*	AREA	VOL.NO.		
2300101	.000000	32 *		
*	J.AREA	JUN.NO.		
2300201	.000000	04 *	.01088	
2300202	.000000	05 *	.007241	
2300203	.000000	26 *		
2300204	.000000	27 *	.007241	
2300205	.000000	31 *	.01088	
*	LENGTH	VOL.NO.		
2300301	0.4150	4 *		
2300302	0.3330	5 *		
2300303	0.6190	15 *		
2300304	0.8697	17 *		
2300305	0.6190	27 *		
2300306	0.3330	28 *		
2300307	0.4150	32 *		
*	VOLUME	V.NO.		
2300401	.0043797	4 *		
2300402	.0095736	5 *		
2300403	.0044823	15 *		
2300404	.0062977	17 *		
2300405	.0044823	27 *		
2300406	.0095736	28 *		
2300407	.0043797	32 *		
*	H.A	V.NO.		
2300501	0.0	32 *		
*	V.ANGLE	V.NO.		
2300601	+90.000	3 *		
2300602	+74.038	4 *		
2300603	+66.336	5 *		
2300604	+90.000	16 *		
2300605	-90.000	27 *		
2300606	-66.336	28 *		
2300607	-74.038	29 *		
2300608	-90.000	32 *		
*	ELEVAT.	V.NO.		
2300701	+0.4150	3 *		
2300702	+0.3990	4 *		
2300703	+0.3050	5 *		
2300704	+0.6190	15 *		
2300705	+0.8697	16 *		
2300706	-0.8697	17 *		
2300707	-0.6190	27 *		
2300708	-0.3050	28 *		
2300709	-0.3990	29 *		
2300710	-0.4150	32 *		
*	ROUGH.	DIAM.	V.NO.	
2300801	2.0-5	.1120	4 *	
2300802	2.0-5	.1560	5 *	
2300803	1.50-6	.0196	27 *	
2300804	2.0-5	.1560	28 *	
2300805	2.0-5	.1120	32 *	

*	K(FORD)	K(REV)	J.NO.				
2300901	00.00	00.00	02*				
2300902	00.61	00.31	03* .06				
2300903	00.00	00.00	15*				
2300904	00.00	00.00	16* .12				
2300905	00.00	00.00	28*				
2300906	00.31	00.61	29* .06				
2300907	00.00	00.00	31*				
*	FE	V.NO					
2301001	00	32	*				
*	CAHS	J.NO.					
2301101	0000	03	*				
2301102	0100	04	*				
2301103	0000	05	*				
2301104	0000	26	*				
2301105	0000	27	*				
2301106	0100	28	*				
2301107	0000	31	*				
*	CONTROL	PRESSURE	ENERGY/TEMP	QUALITY	VOL NO.		
2301201	0	15.736+6	1.4681+6	0.	0.	01	*
2301202	0	15.733+6	1.4681+6	0.	0.	02	*
2301203	0	15.731+6	1.4681+6	0.	0.	03	*
2301204	0	15.726+6	1.4681+6	0.	0.	04	*
2301205	0	15.725+6	1.4675+6	0.	0.	05	*
2301206	0	15.715+6	1.4526+6	0.	0.	06	*
2301207	0	15.708+6	1.4386+6	0.	0.	07	*
2301208	0	15.701+6	1.4255+6	0.	0.	08	*
2301209	0	15.694+6	1.4133+6	0.	0.	09	*
2301210	0	15.688+6	1.4018+6	0.	0.	10	*
2301211	0	15.681+6	1.3910+6	0.	0.	11	*
2301212	0	15.674+6	1.3810+6	0.	0.	12	*
2301213	0	15.667+6	1.3716+6	0.	0.	13	*
2301214	0	15.661+6	1.3628+6	0.	0.	14	*
2301215	0	15.654+6	1.3545+6	0.	0.	15	*
2301216	0	15.645+6	1.3438+6	0.	0.	16	*
2301217	0	15.642+6	1.3339+6	0.	0.	17	*
2301218	0	15.644+6	1.3275+6	0.	0.	18	*
2301219	0	15.646+6	1.3214+6	0.	0.	19	*
2301220	0	15.648+6	1.3156+6	0.	0.	20	*
2301221	0	15.650+6	1.3102+6	0.	0.	21	*
2301222	0	15.652+6	1.3052+6	0.	0.	22	*
2301223	0	15.654+6	1.3004+6	0.	0.	23	*
2301224	0	15.656+6	1.2960+6	0.	0.	24	*
2301225	0	15.658+6	1.2918+6	0.	0.	25	*
2301226	0	15.660+6	1.2879+6	0.	0.	26	*
2301227	0	15.662+6	1.2840+6	0.	0.	27	*
2301228	0	15.669+6	1.2840+6	0.	0.	28	*
2301229	0	15.669+6	1.2840+6	0.	0.	29	*
2301230	0	15.671+6	1.2840+6	0.	0.	30	*
2301231	0	15.673+6	1.2840+6	0.	0.	31	*
2301232	0	15.676+6	1.2840+6	0.	0.	32	*
*	CONTROL						
2301300	0						
*	LIQUID VEL		VAPOUR VEL	INTERFACE VEL.	JUN NO.		
2301301	2.9966		2.9966	0.0	01	*	
2301302	2.9966		2.9966	0.0	02	*	
2301303	2.9966		2.9966	0.0	03	*	
2301304	2.9967		2.9967	0.0	04	*	
2301305	4.3658		4.3658	0.0	05	*	

2301306	4.3217	4.3217	0.0	06	*
2301307	4.2826	4.2826	0.0	07	*
2301308	4.2465	4.2465	0.0	08	*
2301309	4.2143	4.2143	0.0	09	*
2301310	4.1842	4.1842	0.0	10	*
2301311	4.1569	4.1569	0.0	11	*
2301312	4.1322	4.1322	0.0	12	*
2301313	4.1099	4.1099	0.0	13	*
2301314	4.0895	4.0895	0.0	14	*
2301315	4.0710	4.0710	0.0	15	*
2301316	4.0464	4.0464	0.0	16	*
2301317	4.0245	4.0245	0.0	17	*
2301318	4.0104	4.0104	0.0	18	*
2301319	3.9974	3.9974	0.0	19	*
2301320	3.9853	3.9853	0.0	20	*
2301321	3.9742	3.9742	0.0	21	*
2301322	3.9639	3.9639	0.0	22	*
2301323	3.9543	3.9543	0.0	23	*
2301324	3.9452	3.9452	0.0	24	*
2301325	3.9367	3.9367	0.0	25	*
2301326	3.9288	3.9288	0.0	26	*
2301327	3.9211	3.9211	0.0	27	*
2301328	2.6903	2.6903	0.0	28	*
2301329	2.6903	2.6903	0.0	29	*
2301330	2.6903	2.6903	0.0	30	*
2301331	2.6903	2.6903	0.0	31	*

*

*

* 'NAME' TYPE

2350000 '84-12-12' SNGLJUN * S. G. INLET

* FROM TO AREA

2350101 230010000 240000000 0.0 0.0 0.0 0.0000 *

* CONTROL LIQUID V. VAPOR V. 0

2350201 0 6.7232 6.7232 0.0 *

*

*

*

2400000 '84-12-12' PIPE *

* VOLUMES

2400001 08 *

* AREA VOL.NO.

2400101 .000000 8 *

* J.AREA JUN.NO.

2400201 .000000 07 *

* LENGTH VOL.NO.

2400301 0.8300 1 *

2400302 0.8040 3 *

2400303 1.0880 4 *

2400304 0.6250 5 *

2400305 0.8970 6 *

2400306 0.7160 7 *

2400307 0.7681 8 *

* VOLUME V.NO.

2400401 .0035051 1 *

2400402 .0034299 3 *

2400403 .0046414 4 *

2400404 .0026663 5 *

2400405 .0038244 6 *

2400406 .0030523 7 *

2400407 .0032201 8 *

 * H.A V.NO.

 2400501 0.0 8 *

 * V.ANGLE V.NO.

 2400601 -90.000 3 *

 2400602 -69.941 4 *

 2400603 +00.000 5 *

 2400604 +67.884 6 *

 2400605 +90.000 8 *

 * ELEVAT. V.NO.

 2400701 -0.8300 1 *

 2400702 -0.8040 3 *

 2400703 -1.0220 4 *

 2400704 +0.0000 5 *

 2400705 +0.8310 6 *

 2400706 +0.7160 7 *

 2400707 +0.7681 8 *

 * ROUGH. DIAM. V.NO.

 2400801 2.0-5 .0737 8 *

 * K(FORD) K(REV) J.NO.

 2400901 00.10 00.10 01 * 0.1

 2400902 00.00 00.00 03 *

 2400903 00.17 00.17 05 *

 2400904 00.00 00.00 06 *

 2400905 00.00 00.00 07 * 0.22

 * FE V.NO

 2401001 00 8 *

 * CAHS J.NO.

 2401101 0000 07 *

 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.

 2401201 0 15.665+6 1.2840+6 0. 0. 01 *

 2401202 0 15.667+6 1.2840+6 0. 0. 02 *

 2401203 0 15.670+6 1.2840+6 0. 0. 03 *

 2401204 0 15.674+6 1.2840+6 0. 0. 04 *

 2401205 0 15.672+6 1.2840+6 0. 0. 05 *

 2401206 0 15.664+6 1.2840+6 0. 0. 06 *

 2401207 0 15.655+6 1.2840+6 0. 0. 07 *

 2401208 0 15.647+6 1.2840+6 0. 0. 08 *

 * CONTROL

 2401300 0

 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.

 2401301 6.7233 6.7233 0.0 1 *

 2401302 6.6554 6.6554 0.0 2 *

 2401303 6.6555 6.6555 0.0 3 *

 2401304 6.6554 6.6554 0.0 4 *

 2401305 6.6593 6.6593 0.0 5 *

 2401306 6.6602 6.6602 0.0 6 *

 2401307 6.7726 6.7726 0.0 7 *

 *

 *

 2500000 '84-12-12' PUMP *

 * FLOWAREA LENGTH VOLUME H.A VER.ANGL ELEVAT. CNTLFLAG

 2500101 0.0033183 0.0000 0.002370 0.0 +17.140 +0.2105 0 *

 * CODENO. J.AREA K(FORWARD) K(VERSE) CAHS

 2500108 240010000 0.0 0.13 0.13 0000 *0.23 *

 * CODENO. J.AREA K(FORWARD) K(VERSE) CAHS

 2500109 255000000 0.0 0.04 0.03 0000 *

 *

 * CONTROL PRESSURE ENERGY QUALITY

2500200 0 15.796+6 1.2838+6 0. 0. *
 * CNTLW INIT L VEL INIT V VEL INTERFACE VEL
 2500201 0 8.5565 8.5565 0.0 *
 * CNTLW INIT L VEL INIT V VEL INTERFACE VEL
 2500202 0 8.5541 8.5541 0.0 *
 *
 2500301 0 0 0 -1 0 0 0 *
 *
 2500302 745.605 0.6884 .02787 139.9 45.47 1.444 747.3 *
 2500303 0. 0. 0. 0. 0. *
 *
 2500310 0. 0. 0.*
 2506100 501 CNTRLVAR 263
 2506101 0. 0.0
 2506102 745.605 745.605*
 *PUMP DATA

 **** PUMP DATA ****
 **** SINGLE PHASE HEAD CURVE DATA ****

 *

 * HEAD CURVE 1 ****

 2501100 1 1 *
 2501101 0.0000 1.0550 *
 2501102 0.0500 1.0640 *
 2501103 0.1000 1.0790 *
 2501104 0.2000 1.1020 *
 2501105 0.3000 1.1200 *
 2501106 0.4000 1.1310 *
 2501107 0.5000 1.1310 *
 2501108 0.6000 1.1230 *
 2501109 0.7000 1.1040 *
 2501110 0.8000 1.0785 *
 2501111 0.9000 1.0430 *
 2501112 1.0000 1.0000 *

 * HEAD CURVE 2 ****

 2501200 1 2 *
 2501201 0.0000 -0.7800 *
 2501202 0.1000 -0.6285 *
 2501203 0.2000 -0.4780 *
 2501204 0.3000 -0.3230 *
 2501205 0.3100 -0.3080 *
 2501206 0.3500 -0.2480 *
 2501207 0.4000 -0.1690 *
 2501208 0.4500 -0.0840 *
 2501209 0.5015 0.0000 *
 2501210 0.5500 0.0820 *
 2501211 0.6000 0.1730 *
 2501212 0.7000 0.3650 *
 2501213 0.7500 0.4610 *
 2501214 0.8000 0.5560 *
 2501215 0.9000 0.7680 *
 2501216 0.9500 0.8810 *

* HEAD CURVE 3 ****

2501300 1 3 *
2501301 -1.000 2.1100 *
2501302 -0.900 1.9270 *
2501303 -0.800 1.7590 *
2501304 -0.700 1.6105 *
2501305 -0.600 1.4890 *
2501306 -0.500 1.3800 *
2501307 -0.400 1.2820 *
2501308 -0.300 1.2000 *
2501309 -0.200 1.1330 *
2501310 -0.100 1.0805 *
2501311 -0.050 1.0615 *
2501312 0.000 1.0550 *

* HEAD CURVE 4 ****

2501400 1 4 *
2501401 -0.900 1.8620 *
2501402 -0.800 1.6500 *
2501403 -0.700 1.4740 *
2501404 -0.600 1.3320 *
2501405 -0.500 1.2120 *
2501406 -0.400 1.1050 *
2501407 -0.300 1.0020 *
2501408 -0.200 0.9110 *
2501409 -0.100 0.8300 *
2501410 0.000 0.7610 *

* HEAD CURVE 5 ****

2501500 1 5 *
2501501 0.0000 0.4240 *
2501502 0.0500 0.4580 *
2501503 0.1000 0.4890 *
2501504 0.1500 0.5175 *
2501505 0.2000 0.5430 *
2501506 0.2500 0.5730 *
2501507 0.3000 0.6030 *
2501508 0.3500 0.6310 *
2501509 0.4000 0.6600 *
2501510 0.4870 0.7020 *
2501511 0.5000 0.7095 *
2501512 0.5500 0.7305 *
2501513 0.6000 0.7495 *
2501514 0.6500 0.7620 *
2501515 0.7000 0.7770 *
2501516 0.7500 0.7890 *
2501517 0.8000 0.8040 *
2501518 0.8500 0.8280 *
2501519 0.9000 0.8610 *
2501520 0.9500 0.9010 *

* HEAD CURVE 6 ****

2501600 1 6 *
2501601 0.0000 0.7610 *
2501602 0.1000 0.7100 *

2501603	0.2000	0.6640	*
2501604	0.3000	0.6440	*
2501605	0.3500	0.6460	*
2501606	0.4000	0.6530	*
2501607	0.5000	0.6795	*
2501608	0.6000	0.7070	*
2501609	0.7000	0.7460	*
2501610	0.8000	0.7990	*
2501611	0.9000	0.8610	*
2501612	0.9500	0.9010	*
2501613	1.0000	0.9480	*

* HEAD CURVE 7 *****			

2501700	1	7	*
2501701	-0.600	-0.2830	*
2501702	-0.500	-0.1470	*
2501703	-0.450	-0.0810	*
2501704	-0.384	0.0000	*
2501705	-0.350	0.0410	*
2501706	-0.300	0.1060	*
2501707	-0.250	0.1700	*
2501708	-0.200	0.2330	*
2501709	-0.150	0.2900	*
2501710	-0.100	0.3395	*
2501711	-0.050	0.3840	*
2501712	0.000	0.4240	*

*TORQUE CURVE 1 *****			

2501800	2	1	*
2501801	0.0000	0.4390	*
2501802	0.0500	0.4420	*
2501803	0.1000	0.4600	*
2501804	0.2000	0.5150	*
2501805	0.3000	0.5825	*
2501806	0.4000	0.6470	*
2501807	0.5000	0.7060	*
2501808	0.6000	0.7640	*
2501809	0.7000	0.8230	*
2501810	0.8000	0.8820	*
2501811	0.9000	0.9415	*
2501812	1.0000	1.0000	*

*TORQUE CURVE 2 *****			

2501900	2	2	*
2501901	0.0000	-0.5180	*
2501902	0.1000	-0.3500	*
2501903	0.2000	-0.1840	*
2501904	0.3000	-0.0184	*
2501905	0.3100	0.0000	*
2501906	0.3500	0.0660	*
2501907	0.4000	0.1510	*
2501908	0.4500	0.2380	*
2501909	0.5015	0.3200	*
2501910	0.5500	0.3960	*
2501911	0.6000	0.4640	*
2501912	0.7000	0.5985	*

2501913	0.7500	0.6660	*
2501914	0.8000	0.7310	*
2501915	0.9000	0.8640	*
2501916	0.9500	0.9305	*

 *TORQUE CURVE 3 *****

2502000	2	3	*
2502001	-1.000	1.1820	*
2502002	-0.900	1.0370	*
2502003	-0.800	0.9110	*
2502004	-0.700	0.8040	*
2502005	-0.600	0.7120	*
2502006	-0.500	0.6320	*
2502007	-0.400	0.5670	*
2502008	-0.300	0.5130	*
2502009	-0.200	0.4730	*
2502010	-0.100	0.4495	*
2502011	-0.050	0.4410	*
2502012	0.000	0.4390	*

 *TORQUE CURVE 4 *****

2502100	2	4	*
2502101	-0.900	1.1200	*
2502102	-0.800	1.0930	*
2502103	-0.700	1.1040	*
2502104	-0.600	1.2400	*
2502105	-0.500	1.3230	*
2502106	-0.400	1.3400	*
2502107	-0.300	1.2560	*
2502108	-0.200	1.1220	*
2502109	-0.100	1.0410	*
2502110	0.000	0.9840	*

 *TORQUE CURVE 5 *****

2502200	2	5	*
2502201	0.0000	-0.5690	*
2502202	0.0500	-0.5010	*
2502203	0.1000	-0.4390	*
2502204	0.1500	-0.3780	*
2502205	0.2000	-0.3180	*
2502206	0.2500	-0.2595	*
2502207	0.3000	-0.2020	*
2502208	0.3500	-0.1500	*
2502209	0.4000	-0.0980	*
2502210	0.4870	0.0000	*
2502211	0.5000	0.0130	*
2502212	0.5500	0.0695	*
2502213	0.6000	0.1210	*
2502214	0.6500	0.1730	*
2502215	0.7000	0.2290	*
2502216	0.7500	0.2840	*
2502217	0.8000	0.3450	*
2502218	0.8500	0.4090	*
2502219	0.9000	0.4740	*
2502220	0.9500	0.5490	*

*TORQUE CURVE 6 ****

2502300 2 6 *
2502301 0.0000 0.9840 *
2502302 0.1000 0.9505 *
2502303 0.2000 0.9290 *
2502304 0.3000 0.9050 *
2502305 0.3500 0.8900 *
2502306 0.4000 0.8730 *
2502307 0.5000 0.8400 *
2502308 0.6000 0.8020 *
2502309 0.7000 0.7610 *
2502310 0.8000 0.7205 *
2502311 0.9000 0.6780 *
2502312 0.9500 0.6530 *
2502313 1.0000 0.6300 *

*TORQUE CURVE 7 ****

2502400 2 7 *
2502401 -0.600 -1.5900 *
2502402 -0.500 -1.3900 *
2502403 -0.450 -1.2970 *
2502404 -0.384 -1.1800 *
2502405 -0.350 -1.1205 *
2502406 -0.300 -1.0400 *
2502407 -0.250 -0.9560 *
2502408 -0.200 -0.8700 *
2502409 -0.150 -0.7905 *
2502410 -0.100 -0.7160 *
2502411 -0.050 -0.6400 *
2502412 0.000 -0.5690 *

* TWO PHASE MULTIPLIER DATA

* HEAD CURVE

* CNTLNO. VOIDF MULTPR
2503000 0 0.00 0.0 *
2503001 0.20 0.0 *
2503002 0.43 1.0 *
2503003 0.86 1.0 *
2503004 1.00 0.0 *

*TORQUE CURVE

* CNTLNO. VOIDF MULTPR
2503100 0 0.00 0.00 *
2503101 0.15 0.00 *
2503102 0.24 0.56 *
2503103 0.80 0.56 *
2503104 0.96 0.45 *
2503105 1.00 0.00 *

* PUMP I_ PHASE DIFFERENCE DATA

* HEAD CURVE 1

2504100 1 1 *

2504101	0.0000	0.1650	*
2504102	0.0500	0.7740	*
2504103	0.1000	0.8100	*
2504104	0.3000	0.7730	*
2504105	0.5000	0.8040	*
2504106	0.7000	0.8280	*
2504107	1.0000	0.8160	*

* HEAD CURVE 2 *****

2504200	1	2	*
2504201	0.0000	0.2200	*
2504202	0.1000	0.2285	*
2504203	0.3000	0.2480	*
2504204	0.5015	0.3310	*
2504205	0.7000	0.4770	*

* HEAD CURVE 3 *****

2504300	1	3	*
2504301	-1.000	-0.8200	*
2504302	-0.800	-1.4910	*
2504303	-0.700	-1.6695	*
2504304	-0.500	-1.7800	*
2504305	-0.300	-1.5000	*
2504306	-0.200	-1.1370	*
2504307	-0.100	-0.5895	*
2504308	0.000	0.1650	*

* HEAD CURVE 4 *****

2504400	1	4	*
2504401	-0.900	-0.5380	*
2504402	-0.800	-0.3300	*
2504403	-0.600	-0.0980	*
2504404	-0.400	-0.0450	*
2504405	-0.200	-0.0390	*
2504406	0.000	-0.0390	*

* HEAD CURVE 5 *****

2504500	1	5	*
2504501	0.0000	-0.0460	*
2504502	0.2000	-0.3660	*
2504503	0.4000	-0.5800	*
2504504	0.6000	-0.6805	*
2504505	0.8000	-0.6760	*

* HEAD CURVE 6 *****

2504600	1	6	*
2504601	0.0000	-0.0390	*
2504602	0.2000	-0.0660	*
2504603	0.4000	-0.0970	*
2504604	0.6000	-0.1730	*
2504605	0.8000	-0.3310	*
2504606	1.0000	-0.4820	*

* HEAD CURVE 7 *****

 2504700 1 7 *
 2504701 -0.600 0.7970 *
 2504702 -0.400 0.5092 *
 2504703 -0.200 0.2330 *

 *TORQUE CURVE 1 *****

 2504800 2 1 *
 2504801 0.0000 0.5400 *
 2504802 0.2000 0.5900 *
 2504803 0.4000 0.6500 *
 2504804 0.6000 0.7700 *
 2504805 0.8000 0.9500 *
 2504806 0.9000 0.9800 *
 2504807 0.9500 0.9600 *
 2504808 1.0000 0.8700 *

 *TORQUE CURVE 2 *****

 2504900 2 2 *
 2504901 0.0000 -0.1500 *
 2504902 0.2000 0.0200 *
 2504903 0.4000 0.2200 *
 2504904 0.6000 0.4600 *
 2504905 0.8000 0.7100 *
 2504906 0.9000 0.8100 *
 2504907 0.9500 0.8500 *
 2504908 1.0000 0.8700 *

 *TORQUE CURVE 3 *****

 2505000 2 3 *
 2505001 -1.000 0.6200 *
 2505002 -0.800 0.6800 *
 2505003 -0.600 0.5300 *
 2505004 -0.400 0.4600 *
 2505005 -0.200 0.4900 *
 2505006 0.000 0.5400 *

 *TORQUE CURVE 4 *****

 2505100 2 4 *
 2505101 -1.000 0.6200 *
 2505102 -0.800 0.5300 *
 2505103 -0.600 0.4600 *
 2505104 -0.400 0.4200 *
 2505105 -0.200 0.3900 *
 2505106 0.000 0.3600 *

 *TORQUE CURVE 5 *****

 2505200 2 5 *
 2505201 0.0000 -0.6300 *
 2505202 0.2000 -0.5100 *
 2505203 0.4000 -0.3900 *
 2505204 0.6000 -0.2900 *
 2505205 0.8000 -0.2000 *
 2505206 0.9000 -0.1600 *

2505207 1.0000 -0.1300 *

*TORQUE CURVE 6 *****

2505300 2 6 *
2505301 0.0000 0.3600 *
2505302 0.2000 0.3200 *
2505303 0.4000 0.2700 *
2505304 0.6000 0.1800 *
2505305 0.8000 0.0500 *
2505306 1.0000 -0.1300 *

*TORQUE CURVE 7 *****

2505400 2 7 *
2505401 -1.000 -1.4400 *
2505402 -0.800 -1.2500 *
2505403 -0.600 -1.0800 *
2505404 -0.400 -0.9200 *
2505405 -0.200 -0.7700 *
2505406 0.000 -0.6300 *

*

2550000 '20-08-84' BRANCH * SEAL WATER CONNECTION
* NO.J CONTROL

2550001 01 0 *
* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
2550101 .000000 0.7410 .0031019 0.0 -00.348 -0.0045 8.0-5 .0737 00*
* CONTROL PRESSURE ENERGY QUALITY
2550200 0 15.972+6 1.2832+6 0. *
* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
2551101 255010000 260000000 .000000 00.20 00.20 0000 *
* LIQUID VEL VAPOR VEL. INTERFACE VEL
2551201 6.7807 6.7807 0.0 *
*

2600000 '05-09-84' PIPE *

* VOLUMES

2600001 03 *
* AREA VOL.NO.
2600101 .000000 3 *
* J.AREA JUN.NO.
2600201 .000000 02 *
* LENGTH VOL.NO.
2600301 0.7960 3 *
* VOLUME V.NO.
2600401 .0033972 3 *
* H.A V.NO.
2600501 0.0 3 *
* V.ANGLE V.NO.
2600601 -00.0480 3 *
* ELEVAT. V.NO.
2600701 -0.0007 3 *
* ROUGH. DIAM. V.NO.
2600801 8.0-5 .0737 3 *
* K(FORD) K(REV) J.NO.
2600901 00.00 00.00 02 *
* FE V.NO
2601001 00 3 *
* CAHS J.NO.

2601101 0000 02 *

*
* CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
2601201 0 15.964+6 1.2832+6 0. 0. 01 *
2601202 0 15.961+6 1.2832+6 0. 0. 02 *
2601203 0 15.957+6 1.2831+6 0. 0. 03 *
* CONTROL
2601300 0
* LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
2601301 6.6509 6.6509 0.0 1 *
2601302 6.6509 6.6509 0.0 2 *
*
*
*
2700000 '85-01-29' BRANCH * I.L. VESSEL INLET NOZZLE
* NO.J CONTROL
2700001 01 0 *
* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
2700101 .000 0.7730 .0032715 0.0 -00.2965 -0.004 8.0-5 .0737 00*
* CONTROL PRESSURE ENERGY QUALITY
2700200 0 15.951+6 1.2831+6 0. *
* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
2701101 260010000 270000000 .000 00.15 00.15 0000 *
* LIQUID VEL. VAPOR VEL. INTERFACE VEL
2701201 6.7068 6.7068 0.0*
*
*IL STRUCTURES
*

*VESSEL OUTLET

* NH NP G.TYPE FLAG LEFT BOUNDARY
12000000 01 8 2 1 0.03685 *
* FLAG FLAG
12000100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12000101 4 0.07007 *
12000102 3 0.10007 *
* COMPOSITION NO. INTERVAL NO.
12000201 5 4 *
12000202 9 7 *
* SOURCE VALUE INTERVAL NO.
12000301 0.0 7 *
* TEMP POINT NO
12000401 526.98 8 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12000501 200010000 00000 1 1 0.8330 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12000601 -919 0 3980 1 0.8330 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
12000701 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
12000801 0 0.0737 0.0 0.0 1 *
*

*PIPE

* NH NP G.TYPE FLAG LEFT BOUNDARY
12100000 01 7 2 1 0.03685 *

* FLAG FLAG
12100100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12100101 3 0.04445 *
12100102 3 0.07445 *
* COMPOSITION NO. INTERVAL NO.
12100201 5 3 *
12100202 9 6 *
* SOURCE VALUE INTERVAL NO.
12100301 0.0 6 *
* TEMP POINT NO
12100401 488.85 7 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12100501 210010000 00000 1 1 1.9920 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12100601 -919 0 3980 1 1.9920 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
12100701 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
12100801 0 0.0737 0.0 0.0 1 *

*PIPE INLET TO STEAM GENERATOR

* NH NP G.TYPE FLAG LEFT BOUNDARY
12200000 01 8 2 1 0.03685 *
* FLAG FLAG
12200100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12200101 4 0.061887 *
12200102 3 0.091887 *
* COMPOSITION NO. INTERVAL NO.
12200201 5 7 *
* SOURCE VALUE INTERVAL NO.
12200301 0.0 7 *
* TEMP POINT NO
12200401 595.29 8 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12200501 220010000 00000 1 1 1.0110 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12200601 -919 0 3980 1 1.0110 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
12200701 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
12200801 0 0.0737 0.0 0.0 1 *

* NH NP G.TYPE FLAG LEFT BOUNDARY
12300000 04 8 2 1 0.05600 *
* FLAG FLAG
12300100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12300101 4 0.069494 *
12300102 3 0.099494 *
* COMPOSITION NO. INTERVAL NO.
12300201 5 4 *
12300202 9 7 *
* SOURCE VALUE INTERVAL NO.
12300301 0.0 7 *
* TEMP POINT NO

12300401 507.89 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12300501 230010000 10000 1 1 0.4150 4 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12300601 -919 0 3980 1 0.4150 4 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12300701 0 0 0 0 0 4 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12300801 0 0.1120 0.0 0.0 4 *
 *

 *STEAM GENERATOR PRIMARY SIDE (INLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12301000 01 10 2 1 0.07800 *
 * FLAG FLAG
 12301100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12301101 4 0.1331515 *
 12301102 5 0.2331515 *
 * COMPOSITION NO. INTERVAL NO.
 12301201 5 4 *
 12301202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 12301301 0.0 9 *
 * TEMP POINT NO
 12301401 476.06 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12301501 230050000 0 1 1 0.3330 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12301601 -919 0 3980 1 0.3330 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12301701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12301801 0 0.1560 0.0 0.0 1 *
 *

 *STEAM GENERATOR (TUBES)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12302000 22 6 2 1 0.00980 *
 * FLAG FLAG
 12302100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12302101 5 0.011 *
 * COMPOSITION NO. INTERVAL NO.
 12302201 7 5 *
 * SOURCE VALUE INTERVAL NO.
 12302301 0.0 5 *
 * TEMP POINT NO
 12302401 566.30 6 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12302501 230060000 10000 1 1 16.342 10 * 14.856
 12302502 230160000 10000 1 1 22.960 12 * 20.873
 12302503 230180000 10000 1 1 16.342 22 * 14.856
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12302601 520010000 10000 1 1 16.342 10 *
 12302602 520110000 0000 1 1 22.960 11 *
 12302603 520110000 0000 1 1 22.960 12 *

12302604 520100000 -10000 1 1 16.342 22 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12302701 0 0 0 0 22 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12302801 0 0.0196 0.0 0.0 22 *
 12302901 0 0.0220 0.0 0.0 22 *
 *

 *STEAM GENERATOR (OUTLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12303000 01 10 2 1 0.07800 *
 * FLAG FLAG
 12303100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12303101 4 0.133151 *
 12303102 5 0.233151 *
 * COMPOSITION NO. INTERVAL NO.
 12303201 5 4 *
 12303202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 12303301 0.0 9 *
 * TEMP POINT NO
 12303401 457.14 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12303501 230280000 0 1 1 0.3330 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12303601 -919 0 3980 1 0.3330 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12303701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12303801 0 0.1560 0.0 0.0 1 *
 *

 *STEAM GENERATOR (PRIMARY SIDE)_ AFTER OUTLET CHAMBER

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12304000 04 8 2 1 0.05600 *
 * FLAG FLAG
 12304100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12304101 4 0.069494 *
 12304102 3 0.099494 *
 * COMPOSITION NO. INTERVAL NO.
 12304201 5 4 *
 12304202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 12304301 0.0 7 *
 * TEMP POINT NO
 12304401 485.44 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12304501 230290000 10000 1 1 0.4150 4 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12304601 -919 0 3980 1 0.4150 4 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12304701 0 0 0 0 4 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12304801 0 0.1120 0.0 0.0 4 *
 *

*INLET/OUTLET CHAMBER PARTITIONING DISC

* NH NP G.TYPE FLAG LEFT BOUNDARY
12305000 01 6 1 1 0.0 *
* FLAG FLAG
12305100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12305101 5 0.025 *
* COMPOSITION NO. INTERVAL NO.
12305201 5 5 *
* SOURCE VALUE INTERVAL NO.
12305301 0.0 5 *
* CONTROL WORD
12305400 -1
12305401 596.18 591.05 585.91 580.47 575.55 570.33
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12305501 230050000 0 1 1 0.0936 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12305601 230280000 0 1 1 0.0936 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
12305701 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
12305801 0 0.1560 0.0 0.0 1 *
12305901 0 0.1560 0.0 0.0 1 *
*

*VERTICAL MEASUREMENT INSERT

* NH NP G.TYPE FLAG LEFT BOUNDARY
12400000 01 8 2 1 0.03685 *
* FLAG FLAG
12400100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12400101 4 0.065071 *
12400102 3 0.095071 *
* COMPOSITION NO. INTERVAL NO.
12400201 5 4 *
12400202 9 7 *
* SOURCE VALUE INTERVAL NO.
12400301 0.0 7 *
* TEMP POINT NO
12400401 498.07 8 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12400501 240010000 00000 1 1 0.8300 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
12400601 -919 0 3980 1 0.8300 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
12400701 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
12400801 0 0.0737 0.0 0.0 1 *
*
*PIPING
* NH NP G.TYPE FLAG LEFT BOUNDARY
12401000 06 7 2 1 0.03685 *
* FLAG FLAG
12401100 0 1 *
* NO INTERVAL RIGHT COORDINATE
12401101 3 0.045238 *

12401102 3 0.075238 *
 * COMPOSITION NO. INTERVAL NO.
 12401201 5 3 *
 12401202 9 6 *
 * SOURCE VALUE INTERVAL NO.
 12401301 0.0 6 *
 * TEMP POINT NO
 12401401 470.09 7 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12401501 240020000 10000 1 1 0.8040 2 *
 12401502 240040000 00000 1 1 0.9850 3 *
 12401503 240050000 00000 1 1 0.6250 4 *
 12401504 240060000 00000 1 1 0.8970 5 *
 12401505 240070000 00000 1 1 0.7160 6 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12401601 -919 0 3980 1 0.8040 2 *
 12401602 -919 0 3980 1 0.9850 3 *
 12401603 -919 0 3980 1 0.6250 4 *
 12401604 -919 0 3980 1 0.8970 5 *
 12401605 -919 0 3980 1 0.7160 6 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12401701 0 0 0 0 0 6 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12401801 0 0.0737 0.0 0.0 6 *
 *
 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12402000 01 9 2 1 0.03685 *
 * FLAG FLAG
 12402100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12402101 5 0.075515 *
 12402102 3 0.105515 *
 * COMPOSITION NO. INTERVAL NO.
 12402201 5 5 *
 12402202 9 8 *
 * SOURCE VALUE INTERVAL NO.
 12402301 0.0 8 *
 * TEMP POINT NO
 12402401 506.68 9 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12402501 240080000 00000 1 1 0.7690 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12402601 -919 0 3980 1 0.7690 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12402701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12402801 0 0.0737 0.0 0.0 1 *
 ****=
 *PUMP
 ****=
 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12500000 01 10 2 1 0.03250 *
 * FLAG FLAG
 12500100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12500101 9 0.1467212 *
 * COMPOSITION NO. INTERVAL NO.
 12500201 5 9 *

* SOURCE VALUE INTERVAL NO.
 12500301 0.0 9 *
 * TEMP POINT NO
 12500401 457.27 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12500501 250010000 00000 1 1 0.7142 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12500601 -919 0 3981 1 0.7142 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12500701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12500801 0 0.0650 0.0 0.0 1 *
 *
 *
 ****=
 *PIPE WITH MEASUREMENT INSERT & ECC INJECTION POINT
 ****=
 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12600000 01 9 2 1 0.03685 *
 * FLAG FLAG
 12600100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12600101 5 0.074756 *
 12600102 3 0.104756 *
 * COMPOSITION NO. INTERVAL NO.
 12600201 5 5 *
 12600202 9 8 *
 * SOURCE VALUE INTERVAL NO.
 12600301 0.0 8 *
 * TEMP POINT NO
 12600401 506.12 9 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12600501 255010000 00000 1 1 0.7410 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12600601 -919 0 3980 1 0.7410 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 12600701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 12600801 0 0.0737 0.0 0.0 1 *
 *
 *
 * NH NP G.TYPE FLAG LEFT BOUNDARY
 12601000 03 7 2 1 0.03685 *
 * FLAG FLAG
 12601100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 12601101 3 0.0457453 *
 12601102 3 0.0757453 *
 * COMPOSITION NO. INTERVAL NO.
 12601201 5 6 *
 * SOURCE VALUE INTERVAL NO.
 12601301 0.0 6 *
 * TEMP POINT NO
 12601401 564.86 7 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12601501 260010000 10000 1 1 0.7960 3 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 12601601 -919 0 3980 1 0.7960 3 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO

12601701 0 0 0 0 3 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

12601801 0 0.0737 0.0 0.0 3 *

*

*VESSEL INLET

* NH NP G.TYPE FLAG LEFT BOUNDARY

12700000 01 8 2 1 0.03685 *

* FLAG FLAG

12700100 0 1 *

* NO INTERVAL RIGHT COORDINATE

12700101 4 0.068377 *

12700102 3 0.098377 *

* COMPOSITION NO. INTERVAL NO.

12700201 5 4 *

12700202 9 7 *

* SOURCE VALUE INTERVAL NO.

12700301 0.0 7 *

* TEMP POINT NO

12700401 501.05 8 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

12700501 270010000 00000 1 1 0.7730 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

12700601 -919 0 3980 1 0.7730 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO

12700701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

12700801 0 0.0737 0.0 0.0 1 *

*

*

*BROKEN LOOP

*

*

*BL CONTROL VARIABLES

*

20530000 TRIPCOND TRIPUNIT 1. 1. 0

20530001 515

20530100 CM05 SUM 1.0 0. 1*

20530101 0. 1.0 MFLOWJ 390010000

20530200 BREAKM INTEGRAL 1.0 0. 1*

20530201 CNTRLVAR 301

20530300 TRIPCOND TRIPUNIT 1. 0. 0

20530301 505

20530400 TRIPTR TRIPDLAY 1.0 0.0 1

20530401 505

20530500 ARGUM SUM 1.0 0.0 1

20530501 0. 1. TIME 0 -1. CNTRLVAR 304

20530600 TIME MULT 1.0 0.0 1

20530601 CNTRLVAR 303 CNTRLVAR 305

20530700 ACTIME SUM 1.0 0. 1

20530701 0. 1. CNTRLVAR 300 1.0 CNTRLVAR 306

20530800 BREAKF DIV 1.0 0. 1*

20530801 CNTRLVAR 307 CNTRLVAR 302

*

* HEAT CARRIED AWAY BY LEAK FLOW (MW,MJ)

20530900 LEAKPOW MULT 1.-6 0. 1

20530901 CNTRLVAR 301 U 390010000

20531000 LEAKENG INTEGRAL 1.0 0. 1

20531001 CNTRLVAR 309

*PRESSURE DROPS

*PRIMARY SIDE

20531100	PD80AB42	SUM	1.-6	0	1*	S81
20531200	PD80BNX1	SUM	1.-6	0	1*	S82
20531300	PD82NBX1	SUM	1.-6	0	1*	S85
20531400	PD82BA64	SUM	1.-6	0	1*	S88
20531500	PD8082AA	SUM	1.-6	0	1*	L23
20531600	PD2180A	SUM	1.-6	0	1*	L22
20531700	PD8227	SUM	1.-6	0	1*	L24
20531800	PD2724	SUM	1.-6	0	1*	L25
20531900	PD252451	SUM	1.-6	0	1*	L26(PUMP HEAD)
20532000	PD2526	SUM	1.-6	0	1*	L27
20532100	PD262133	SUM	1.-6	0	1*	L29

*

*

20531101	0.0	1.0	P	330010000	1.2027	RHO	330010000
+		-1.0	P	330060000	-2.8057	RHO	330060000
20531201	0.0	1.0	P	330060000	2.8057	RHO	330060000
+		-0.5	P	330160000	-0.5	P	330170000
20531301	0.0	0.5	P	330160000	0.5	P	330170000
+		-1.0	P	330270000	-2.8057	RHO	330270000
20531401	0.0	1.0	P	330270000	2.8057	RHO	330270000
+		-1.0	P	330320000	-1.2027	RHO	330320000
20531501	0.0	1.0	P	330010000	1.2027	RHO	330010000
+		-1.0	P	330320000	-1.2027	RHO	330320000
20531601	0.0	1.0	P	300020000			
+		-1.0	P	330010000	-1.2027	RHO	330010000
20531701	0.0	1.0	P	330320000	+1.2027	RHO	330320000
+		-1.0	P	340050000	-0.9320	RHO	340050000
20531801	0.0	1.0	P	340050000	+0.9320	RHO	340050000
+		-1.0	P	340080000	-1.7070	RHO	340080000
20531901	0.0	-1.0	P	340080000	-1.7070	RHO	340080000
+		1.0	P	360010000			
20532001	0.0	1.0	P	360010000	-1.0	P	395020000
20532101	0.0	1.0	P	395020000	-1.0	P	300020000

*

* HEAT TRANSFER TO/FROM SG2 (MW)

20533000	PHTSG2	SUM	1.	0.	1*		
20533100	PHTSG2	SUM	1.	0.	1*		
20533200	THTSG2	SUM	1.-6	0.	1*	HEAT TRANSFER TO/FROM SG2	

*

*

20533001	0.	0.360500	HTRNR	330200101	0.360500	HTRNR	330200201
+		0.360500	HTRNR	330200301	0.360500	HTRNR	330200401
+		0.360500	HTRNR	330200501	0.360500	HTRNR	330200601
+		0.360500	HTRNR	330200701	0.360500	HTRNR	330200801
+		0.360500	HTRNR	330200901	0.360500	HTRNR	330201001
20533101	0.	0.500740	HTRNR	330201101	0.500740	HTRNR	330201201
+		0.360500	HTRNR	330201301	0.360500	HTRNR	330201401
+		0.360500	HTRNR	330201501	0.360500	HTRNR	330201601
+		0.360500	HTRNR	330201701	0.360500	HTRNR	330201801
+		0.360500	HTRNR	330201901	0.360500	HTRNR	330202001
+		0.360500	HTRNR	330202101	0.360500	HTRNR	330202201
20533201	0.	1.0	CNTRLVAR	330	1.0	CNTRLVAR	331

* HEAT LOSSES (KW)

20534300 L SUM 1.-3 0. 1*

20534400 L SUM 1.-3 0. 1*

20534500 LOSS-BL SUM 1.0 0. 1* SUM IN BL

*

	A0	SURFACE AREA	VAR.	CODE	SURFACE AREA	VAR.	CODE
20534301	0	0.345390	HTRNR	300000101	0.345390	HTRNR	300000201
+		0.325210	HTRNR	300200101	0.382060	HTRNR	300200201
+		0.202740	HTRNR	330000101	0.202740	HTRNR	330000201
+		0.202740	HTRNR	330000301	0.202740	HTRNR	330000401
+		0.202740	HTRNR	330400101	0.202740	HTRNR	330400201
+		0.202740	HTRNR	330400301	0.202740	HTRNR	330400401
+		0.329110	HTRNR	340000101	0.329110	HTRNR	340000201
+		0.329110	HTRNR	340000301	0.382760	HTRNR	340000401
+		0.330010	HTRNR	340000501	0.320720	HTRNR	340000601
+		0.266890	HTRNR	340000701	0.266890	HTRNR	340000801
20534401	0	0.658400	HTRNR	350000101			
+		0.352550	HTRNR	360000101	0.352550	HTRNR	360100101
+		0.112640	HTRNR	360200101	0.112640	HTRNR	360200201
+		0.042635	HTRNR	370000101	0.042635	HTRNR	390000101
+		0.190580	HTRNR	395000101	0.190580	HTRNR	395000201
+		0.448910	HTRNR	395100101			
+		0.221440	HTRNR	330100101			
+		0.221440	HTRNR	330300101			
+		0.342400	HTRNR	300100101			

20534501 0. 1.0 CNTRLVAR 343 1.0 CNTRLVAR 344

20535000	TF21B	SUM	1.	0.	1
20535001	-273.15	1.	TEMPF	300010000	
20535100	TF21T	SUM	1.	0.	1
20535101	-273.15	1.	TEMPG	300010000	
20535200	TF26B	SUM	1.	0.	1
20535201	-273.15	1.	TEMPF	395030000	
20535300	TF26T	SUM	1.	0.	1
20535301	-273.15	1.	TEMPG	395030000	
20535400	DD21	SUM	1.	0.	1
20535401	0.	1.	RHO	300010000	
20535500	DD24	SUM	1.	0.	1
20535501	0.	1.	RHO	340010000	
20535600	DD25	SUM	1.	0.	1
20535601	0.	1.	RHO	360010000	
20535700	DD26	SUM	1.	0.	1
20535701	0.	1.	RHO	395030000	

*

* PUMP SPEED CONTROLLER

*

20536100	SPDCNTLR	SUM	1.0	0.0	1
20536101	6.7	-1.0	MFLOWJ	300010000	

*

20536200 DEADBAND STDFNCTN 1.0 0.0 1

20536201 ABS CNTRLVAR 361

*

20536300 PMPSPEED INTEGRAL 60.0 406.49 1 *

20536301 CNTRLVAR 361 *

20539000 TF26T SUM 1. 0. 1

20539001 -273.16 1. TEMPG 395010000

20539100 TF26B SUM 1. 0. 1

20539101 -273.16 1. TEMPF 395010000

20539200 TF21T SUM 1. 0. 1

20539201 -273.16 1. TEMPG 300010000

20539300 TF21B SUM 1. 0. 1
 20539301 -273.16 1. TEMPF 300010000
 *
 *
 *BL VOLUMES
 *
 *
 3000000 '05-09-84' PIPE *
 * VOLUMES
 3000001 5 *
 * AREA VOL.NO.
 3000101 .000000 5 *
 * J.AREA JUN.NO.
 3000201 .000000 04 *
 * LENGTH VOL.NO.
 3000301 0.6790 2 *
 3000302 0.7700 3 *
 3000303 0.7380 4 *
 3000304 0.8675 5 *
 * VOLUME V.NO.
 3000401 .0011237 2 *
 3000402 .0012967 3 *
 3000403 .0012207 4 *
 3000404 .0014341 5 *
 * H.A V.NO.
 *000501 0.0 5 *
 * V.ANGLE V.NO.
 3000601 -00.190 2 *
 3000602 +00.369 3 *
 3000603 +5.91086 4 *
 3000604 +90.000 5 *
 * ELEVAT. V.NO.
 3000701 -0.0023 2 *
 3000702 +0.0050 3 *
 3000703 +0.0760 4 *
 3000704 +0.8675 5 *
 * ROUGH. DIAM. V.NO.
 3000801 2.0-5 .0461 5 *
 * K(FORD) K(REV) J.NO.
 3000901 00.05 00.05 01*
 3000902 00.11 00.11 02* .41 .41 (.21,.21)
 3000903 00.07 00.07 03* .07 .07
 3000904 01.38 00.38 04* 1.30 .30 L
 * FE V.NO
 3001001 00 5 *
 * CAHS J.NO.
 3001101 0000 04 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 3001201 0 15.766+6 1.46667+6 0. 0. 01 *
 3001202 0 15.761+6 1.46666+6 0. 0. 02 *
 3001203 0 15.757+6 1.46666+6 0. 0. 03 *
 3001204 0 15.752+6 1.46666+6 0. 0. 04 *
 3001205 0 15.728+6 1.46666+6 0. 0. 05 *
 * CONTROL
 3001300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
 3001301 6.0937 6.0937 0.0 1 *
 3001302 6.0937 6.0937 0.0 2 *
 3001303 6.0969 6.0969 0.0 3 *

3001304	6.1003	6.1003	0.0	4	*
*					
* SINGLE JUNCTION					
3150000	'05-09-84'	SNGLJUN	*PIPE TO S.G EXPANSION		
*	CODE(FROM)	CODE(TO)	AREA	K(FORD)	K(REV)CAHS COEFFICIENT
3150101	300010000	330000000	.000000	00.19	00.05 0000 * .41 .27
*	C.WORD	INIT L FLO	INIT V FLO	INTERFACE VEL	(.19,.05)
3150201	0	6.1006	6.1006	0.0	*
*					
*					
3300000	'05-09-84'	PIPE *			
*	VOLUMES				
3300001	32	*			
*	AREA	VOL.NO.			
3300101	.000000	32	*		
*	J.AREA	JUN.NO.			
3300201	.000000	04	*		
3300202	.000000	05	*		
3300203	.000000	26	*		
3300204	.000000	27	*		
3300205	.000000	31	*		
*	LENGTH	VOL.NO.			
3300301	0.4490	4	*		
3300302	0.2160	5	*		
3300303	0.6210	15	*		
3300304	0.8625	17	*		
3300305	0.6210	27	*		
3300306	0.2160	28	*		
3300307	0.4490	32	*		
*	VOLUME	V.NO.			
3300401	.0016057	4	*		
3300402	.0025784	5	*		
3300403	.0014989	15	*		
3300404	.0020819	17	*		
3300405	.0014989	27	*		
3300406	.0025784	28	*		
3300407	.0016057	32	*		
*	V.ANGLE	V.NO.			
3300601	+90.000	3	*		
3300602	+77.291	4	*		
3300603	+66.444	5	*		
3300604	+90.000	16	*		
3300605	-90.000	27	*		
3300606	-66.444	28	*		
3300607	-77.291	29	*		
3300608	-90.000	32	*		
*	ELEVAT.	V.NO.			
3300701	+0.4490	3	*		
3300702	+0.4380	4	*		
3300703	+0.1980	5	*		
3300704	+0.6210	15	*		
3300705	+0.8625	16	*		
3300706	-0.8625	17	*		
3300707	-0.6210	27	*		
3300708	-0.1980	28	*		
3300709	-0.4380	29	*		
3300710	-0.4490	32	*		
*	ROUGH.	DIAM.	V.NO.		
3300801	2.0-5	.0684	4	*	

3300802	2.0-5	.1020	5	*	.102
3300803	0.2-5	.0196	27	*	.2-5
3300804	2.0-5	.1020	28	*	
3300805	2.0-5	.0684	32	*	
*	K(FORD)	K(REV)	J.NO.		
3300901	00.00	00.00	02*		
3300902	00.01	00.01	03*	.02	.02
3300903	00.00	00.00	11*		
3300904	00.15	00.15	15*		
3300905	00.00	00.00	16*	.55	TOTAL
3300906	00.00	00.00	28*		
3300907	00.00	00.00	29*	.02	.02
3300908	00.00	00.00	31*		
*	FE	V.NO			
3301001	00	32	*		
*	CAHS	J.NO.			
3301101	0000	03	*		
3301102	0100	04	* 0000		
3301103	0100	05	*		
3301104	0000	26	*		
3301105	0100	27	* 0000		
3301106	0100	28	*		
3301107	0000	31	*		
*	CONTROL	PRESSURE	ENERGY	QUALITY	VOL NO.
3301201	0	15.729+6	1.4666+6	0.	01
3301202	0	15.726+6	1.4666+6	0.	02
3301203	0	15.723+6	1.4666+6	0.	03
3301204	0	15.720+6	1.4666+6	0.	04
3301205	0	15.719+6	1.4666+6	0.	05
3301206	0	15.707+6	1.4515+6	0.	06
3301207	0	15.700+6	1.4377+6	0.	07
3301208	0	15.694+6	1.4247+6	0.	08
3301209	0	15.687+6	1.4125+6	0.	09
3301210	0	15.681+6	1.4012+6	0.	10
3301211	0	15.674+6	1.3905+6	0.	11
3301212	0	15.667+6	1.3805+6	0.	12
3301213	0	15.660+6	1.3712+6	0.	13
3301214	0	15.652+6	1.3624+6	0.	14
3301215	0	15.645+6	1.3541+6	0.	15
3301216	0	15.636+6	1.3433+6	0.	16
3301217	0	15.633+6	1.3334+6	0.	17
3301218	0	15.635+6	1.3270+6	0.	18
3301219	0	15.637+6	1.3209+6	0.	19
3301220	0	15.639+6	1.3152+6	0.	20
3301221	0	15.641+6	1.3099+6	0.	21
3301222	0	15.643+6	1.3048+6	0.	22
3301223	0	15.646+6	1.3001+6	0.	23
3301224	0	15.648+6	1.2956+6	0.	24
3301225	0	15.650+6	1.2915+6	0.	25
3301226	0	15.652+6	1.2876+6	0.	26
3301227	0	15.654+6	1.2839+6	0.	27
3301228	0	15.658+6	1.2839+6	0.	28
3301229	0	15.657+6	1.2839+6	0.	29
3301230	0	15.660+6	1.2839+6	0.	30
3301231	0	15.663+6	1.2839+6	0.	31
3301232	0	15.666+6	1.2839+6	0.	32
*	CONTROL				
3301300	0				
*	LIQUID VEL	VAPOUR VEL	INTERFACE VEL.	JUN NO.	

3301301	2.8201	2.8201	0.0	1	*
3301302	2.8201	2.8201	0.0	2	*
3301303	2.8201	2.8201	0.0	3	*
3301304	2.8201	2.8201	0.0	4	*
3301305	4.1773	4.1773	0.0	5	*
3301306	4.1359	4.1359	0.0	6	*
3301307	4.0988	4.0988	0.0	7	*
3301308	4.0647	4.0647	0.0	8	*
3301309	4.0342	4.0342	0.0	9	*
3301310	4.0056	4.0056	0.0	10	*
3301311	3.9797	3.9797	0.0	11	*
3301312	3.9563	3.9563	0.0	12	*
3301313	3.9351	3.9351	0.0	13	*
3301314	3.9157	3.9157	0.0	14	*
3301315	3.8980	3.8980	0.0	15	*
3301316	3.8741	3.8741	0.0	16	*
3301317	3.8532	3.8532	0.0	17	*
3301318	3.8397	3.8397	0.0	18	*
3301319	3.8273	3.8273	0.0	19	*
3301320	3.8159	3.8159	0.0	20	*
3301321	3.8053	3.8053	0.0	21	*
3301322	3.7955	3.7955	0.0	22	*
3301323	3.7864	3.7864	0.0	23	*
3301324	3.7777	3.7777	0.0	24	*
3301325	3.7695	3.7695	0.0	25	*
3301326	3.7620	3.7620	0.0	26	*
3301327	3.7548	3.7548	0.0	27	*
3301328	2.5344	2.5344	0.0	28	*
3301329	2.5343	2.5343	0.0	29	*
3301330	2.5343	2.5343	0.0	30	*
3301331	2.5343	2.5343	0.0	31	*

*

*

3350000 '05-09-84' SNGLJUN *STEAM GENERATOR TO PIPING

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT

3350101	330010000	340000000	.000000	00.05	00.19	0000	*.27 .41
*	C.WORD	INIT L FLO	INIT V FLO	INTERFACE	VEL		(.15,.29)
3350201	0	5.4484	5.4484	0.0			

*

3400000 '05-09-84' PIPE *

* VOLUMES

3400001	8	*
*	AREA	VOL.NO.
3400101	.000000	4 *
3400102	.001669	5 *
3400103	.000000	8 *
*	J.AREA	JUN.NO.
3400201	.000000	07 *
*	LENGTH	VOL.NO.
3400301	0.7300	3 *
3400302	0.8010	4 *
3400303	0.7320	5 *
3400304	0.6630	6 *
3400305	0.5920	8 *
*	VOLUME	V.NO.
3400401	.0012143	3 *
3400402	.0014135	4 *
3400403	.0000000	5 *
3400404	.0011773	6 *

3400405 .0009780 8 *
 * H.A V.NO.
 *400501 0.0 8 *
 * V.ANGLE V.NO.
 3400601 -90.000 3 *
 3400602 -71.147 4 *
 3400603 +00.000 5 *
 3400604 +69.251 6 *
 3400605 +90.000 8 *
 * ELEVAT. V.NO.
 3400701 -0.7300 3 *
 3400702 -0.7580 4 *
 3400703 +0.0000 5 *
 3400704 +0.6200 6 *
 3400705 +0.5920 8 *
 * ROUGH. DIAM. V.NO.
 3400801 2.0-5 .0461 8 *
 * K(FORD) K(REV) J.NO.
 3400901 00.10 00.10 01* .22
 3400902 00.00 00.00 03*
 3400903 00.75 00.75 04* .8 .8 L
 3400904 00.07 00.07 05* .07 .07 L
 3400905 00.00 00.00 06*
 3400906 00.24 00.24 07* .34 L
 * FE V.NO
 3401001 00 8 *
 * CAHS J.NO.
 3401101 0000 07 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 3401201 0 15.659+6 1.2838+6 0. 0. 01 *
 3401202 0 15.661+6 1.2838+6 0. 0. 02 *
 3401203 0 15.663+6 1.2838+6 0. 0. 03 *
 3401204 0 15.667+6 1.2838+6 0. 0. 04 *
 3401205 0 15.658+6 1.2838+6 0. 0. 05 *
 3401206 0 15.653+6 1.2838+6 0. 0. 06 *
 3401207 0 15.645+6 1.2838+6 0. 0. 07 *
 3401208 0 15.636+6 1.2837+6 0. 0. 08 *
 * CONTROL
 3401300 0
 * LIQUID VEL./FLOW VAPOUR VEL INTERFACE VEL. JUN NO.
 3401301 5.4484 5.4484 0.0 1 *
 3401302 5.4483 5.4483 0.0 2 *
 3401303 5.4482 5.4482 0.0 3 *
 3401304 5.4300 5.4300 0.0 4 *
 3401305 5.4300 5.4300 0.0 5 *
 3401306 5.4858 5.4858 0.0 6 *
 3401307 5.4858 5.4858 0.0 7 *
 *
 3500000 '05-09-84' PUMP *
 * FLOWAREA LENGTH VOLUME H.A VER.ANGL ELEVAT. CNTLFLAG
 3500101 0.0033183 0.0000 0.002370 0.0 +15.260 +0.1880 0 *
 * CODENO. J.AREA K(FORWARD) K(VERSE) CAHS
 3500108 340010000 0.0000 0.15 0.15 0000 * .001669
 * CODENO. J.AREA K(FORWARD) K(VERSE) CAHS
 3500109 355000000 0.0000 0.85 0.85 0000 * .001669
 * CONTROL PRESSURE ENERGY QUALITY
 3500200 0 15.808+6 1.2828+6 0. 0. *
 * CNTLW INIT L VEL INIT V VEL INTERFACE VEL

3500201 0 5.4858 5.4858 0.0 *
 * CNTLW INIT L VEL INIT V VEL INTERFACE VEL
 3500202 0 5.4556 5.4556 0.0 *
 *
 3500301 0 0 0 -1 0 0 0 * W5 -1
 *
 3500302 745.605 0.5452 .02787 139.9 45.47 1.444 747.3 *.6048845
 3500303 0. 0. 0. 0. 0. * .55 L
 *
 3500310 0. 0. 0.*
 3506100 501 CNTRLVAR 363
 3506101 0.0 0.0 *
 3506102 745.605 745.605 *
 *
 *PUMP DATA
 **** PUMP DATA ****
 **** SINGLE PHASE HEAD CURVE DATA ****

 *
 * HEAD CURVE 1 *

 3501100 1 1 *
 3501101 0.0000 1.0550 *
 3501102 0.0500 1.0640 *
 3501103 0.1000 1.0790 *
 3501104 0.2000 1.1020 *
 3501105 0.3000 1.1200 *
 3501106 0.4000 1.1310 *
 3501107 0.5000 1.1310 *
 3501108 0.6000 1.1230 *
 3501109 0.7000 1.1040 *
 3501110 0.8000 1.0785 *
 3501111 0.9000 1.0430 *
 3501112 1.0000 1.0000 *

 * HEAD CURVE 2 *

 3501200 1 2 *
 3501201 0.0000 -0.7800 *
 3501202 0.1000 -0.6285 *
 3501203 0.2000 -0.4780 *
 3501204 0.3000 -0.3230 *
 3501205 0.3100 -0.3080 *
 3501206 0.3500 -0.2480 *
 3501207 0.4000 -0.1690 *
 3501208 0.4500 -0.0840 *
 3501209 0.5015 0.0000 *
 3501210 0.5500 0.0820 *
 3501211 0.6000 0.1730 *
 3501212 0.7000 0.3650 *
 3501213 0.7500 0.4610 *
 3501214 0.8000 0.5560 *
 3501215 0.9000 0.7680 *
 3501216 0.9500 0.8810 *

 * HEAD CURVE 3 *

3501300	1	3	*
3501301	-1.000	2.1100	*
3501302	-0.900	1.9270	*
3501303	-0.800	1.7590	*
3501304	-0.700	1.6105	*
3501305	-0.600	1.4890	*
3501306	-0.500	1.3800	*
3501307	-0.400	1.2820	*
3501308	-0.300	1.2000	*
3501309	-0.200	1.1330	*
3501310	-0.100	1.0805	*
3501311	-0.050	1.0615	*
3501312	0.000	1.0550	*

* HEAD CURVE 4 *****

3501400	1	4	*
3501401	-0.900	1.8620	*
3501402	-0.800	1.6500	*
3501403	-0.700	1.4740	*
3501404	-0.600	1.3320	*
3501405	-0.500	1.2120	*
3501406	-0.400	1.1050	*
3501407	-0.300	1.0020	*
3501408	-0.200	0.9110	*
3501409	-0.100	0.8300	*
3501410	0.000	0.7610	*

* HEAD CURVE 5 *****

3501500	1	5	*
3501501	0.0000	0.4240	*
3501502	0.0500	0.4580	*
3501503	0.1000	0.4890	*
3501504	0.1500	0.5175	*
3501505	0.2000	0.5430	*
3501506	0.2500	0.5730	*
3501507	0.3000	0.6030	*
3501508	0.3500	0.6310	*
3501509	0.4000	0.6600	*
3501510	0.4870	0.7020	*
3501511	0.5000	0.7095	*
3501512	0.5500	0.7305	*
3501513	0.6000	0.7495	*
3501514	0.6500	0.7620	*
3501515	0.7000	0.7770	*
3501516	0.7500	0.7890	*
3501517	0.8000	0.8040	*
3501518	0.8500	0.8280	*
3501519	0.9000	0.8610	*
3501520	0.9500	0.9010	*

* HEAD CURVE 6 *****

3501600	1	6	*
3501601	0.0000	0.7610	*
3501602	0.1000	0.7100	*
3501603	0.2000	0.6640	*
3501604	0.3000	0.6440	*

3501605	0.3500	0.6460	*
3501606	0.4000	0.6530	*
3501607	0.5000	0.6795	*
3501608	0.6000	0.7070	*
3501609	0.7000	0.7460	*
3501610	0.8000	0.7990	*
3501611	0.9000	0.8610	*
3501612	0.9500	0.9010	*
3501613	1.0000	0.9480	*

* HEAD CURVE 7 *

3501700	1	7	*
3501701	-0.600	-0.2830	*
3501702	-0.500	-0.1470	*
3501703	-0.450	-0.0810	*
3501704	-0.384	0.0000	*
3501705	-0.350	0.0410	*
3501706	-0.300	0.1060	*
3501707	-0.250	0.1700	*
3501708	-0.200	0.2330	*
3501709	-0.150	0.2900	*
3501710	-0.100	0.3395	*
3501711	-0.050	0.3840	*
3501712	0.000	0.4240	*

*TORQUE CURVE 1 *

3501800	2	1	*
3501801	0.0000	0.4390	*
3501802	0.0500	0.4420	*
3501803	0.1000	0.4600	*
3501804	0.2000	0.5150	*
3501805	0.3000	0.5825	*
3501806	0.4000	0.6470	*
3501807	0.5000	0.7060	*
3501808	0.6000	0.7640	*
3501809	0.7000	0.8230	*
3501810	0.8000	0.8820	*
3501811	0.9000	0.9415	*
3501812	1.0000	1.0000	*

*TORQUE CURVE 2 *

3501900	2	2	*
3501901	0.0000	-0.5180	*
3501902	0.1000	-0.3500	*
3501903	0.2000	-0.1840	*
3501904	0.3000	-0.0184	*
3501905	0.3100	0.0000	*
3501906	0.3500	0.0660	*
3501907	0.4000	0.1510	*
3501908	0.4500	0.2380	*
3501909	0.5015	0.3200	*
3501910	0.5500	0.3960	*
3501911	0.6000	0.4640	*
3501912	0.7000	0.5985	*
3501913	0.7500	0.6660	*
3501914	0.8000	0.7310	*

3501915	0.9000	0.8640	*
3501916	0.9500	0.9305	*

*TORQUE CURVE 3 *****

3502000	2	3	*
3502001	-1.000	1.1820	*
3502002	-0.900	1.0370	*
3502003	-0.800	0.9110	*
3502004	-0.700	0.8040	*
3502005	-0.600	0.7120	*
3502006	-0.500	0.6320	*
3502007	-0.400	0.5670	*
3502008	-0.300	0.5130	*
3502009	-0.200	0.4730	*
3502010	-0.100	0.4495	*
3502011	-0.050	0.4410	*
3502012	0.000	0.4390	*

*TORQUE CURVE 4 *****

3502100	2	4	*
3502101	-0.900	1.1200	*
3502102	-0.800	1.0930	*
3502103	-0.700	1.1040	*
3502104	-0.600	1.2400	*
3502105	-0.500	1.3230	*
3502106	-0.400	1.3400	*
3502107	-0.300	1.2560	*
3502108	-0.200	1.1220	*
3502109	-0.100	1.0410	*
3502110	0.000	0.9840	*

*TORQUE CURVE 5 *****

3502200	2	5	*
3502201	0.0000	-0.5690	*
3502202	0.0500	-0.5010	*
3502203	0.1000	-0.4390	*
3502204	0.1500	-0.3780	*
3502205	0.2000	-0.3180	*
3502206	0.2500	-0.2595	*
3502207	0.3000	-0.2020	*
3502208	0.3500	-0.1500	*
3502209	0.4000	-0.0980	*
3502210	0.4870	0.0000	*
3502211	0.5000	0.0130	*
3502212	0.5500	0.0695	*
3502213	0.6000	0.1210	*
3502214	0.6500	0.1730	*
3502215	0.7000	0.2290	*
3502216	0.7500	0.2840	*
3502217	0.8000	0.3450	*
3502218	0.8500	0.4090	*
3502219	0.9000	0.4740	*
3502220	0.9500	0.5490	*

*TORQUE CURVE 6 *****

3502300	2	6	*
3502301	0.0000	0.9840	*
3502302	0.1000	0.9505	*
3502303	0.2000	0.9290	*
3502304	0.3000	0.9050	*
3502305	0.3500	0.8900	*
3502306	0.4000	0.8730	*
3502307	0.5000	0.8400	*
3502308	0.6000	0.8020	*
3502309	0.7000	0.7610	*
3502310	0.8000	0.7205	*
3502311	0.9000	0.6780	*
3502312	0.9500	0.6530	*
3502313	1.0000	0.6300	*

*TORQUE CURVE 7

3502400	2	7	*
3502401	-0.600	-1.5900	*
3502402	-0.500	-1.3900	*
3502403	-0.450	-1.2970	*
3502404	-0.384	-1.1800	*
3502405	-0.350	-1.1205	*
3502406	-0.300	-1.0400	*
3502407	-0.250	-0.9560	*
3502408	-0.200	-0.8700	*
3502409	-0.150	-0.7905	*
3502410	-0.100	-0.7160	*
3502411	-0.050	-0.6400	*
3502412	0.000	-0.5690	*

* TWO PHASE MULTIPLIER DATA

* HEAD CURVE

CNTLNO.	VOIDF	MULTPR
3503000	0	0.00 0.0 *
3503001		0.20 0.0 *
3503002		0.43 1.0 *
3503003		0.86 1.0 *
3503004		1.00 0.0 *

*TORQUE CURVE

CNTLNO.	VOIDF	MULTPR
3503100	0	0.00 0.00 *
3503101		0.15 0.00 *
3503102		0.24 0.56 *
3503103		0.80 0.56 *
3503104		0.96 0.45 *
3503105		1.00 0.00 *

* PUMP I_ PHASE DIFFERENCE DATA

* HEAD CURVE 1

3504100	1	1	*
3504101	0.0000	0.1650	*
3504102	0.0500	0.7740	*

3504103	0.1000	0.8100	*
3504104	0.3000	0.7730	*
3504105	0.5000	0.8040	*
3504106	0.7000	0.8280	*
3504107	1.0000	0.8160	*

* HEAD CURVE 2 *****			

3504200	1	2	*
3504201	0.0000	0.2200	*
3504202	0.1000	0.2285	*
3504203	0.3000	0.2480	*
3504204	0.5015	0.3310	*
3504205	0.7000	0.4770	*

* HEAD CURVE 3 *****			

3504300	1	3	*
3504301	-1.000	-0.8200	*
3504302	-0.800	-1.4910	*
3504303	-0.700	-1.6695	*
3504304	-0.500	-1.7800	*
3504305	-0.300	-1.5000	*
3504306	-0.200	-1.1370	*
3504307	-0.100	-0.5895	*
3504308	0.000	0.1650	*

* HEAD CURVE 4 *****			

3504400	1	4	*
3504401	-0.900	-0.5380	*
3504402	-0.800	-0.3300	*
3504403	-0.600	-0.0980	*
3504404	-0.400	-0.0450	*
3504405	-0.200	-0.0390	*
3504406	0.000	-0.0390	*

* HEAD CURVE 5 *****			

3504500	1	5	*
3504501	0.0000	-0.0460	*
3504502	0.2000	-0.3660	*
3504503	0.4000	-0.5800	*
3504504	0.6000	-0.6805	*
3504505	0.8000	-0.6760	*

* HEAD CURVE 6 *****			

3504600	1	6	*
3504601	0.0000	-0.0390	*
3504602	0.2000	-0.0660	*
3504603	0.4000	-0.0970	*
3504604	0.6000	-0.1730	*
3504605	0.8000	-0.3310	*
3504606	1.0000	-0.4820	*

* HEAD CURVE 7 *****			

3504700	1	7	*

3504701	-0.600	0.7970	*
3504702	-0.400	0.5092	*
3504703	-0.200	0.2330	*

*TORQUE CURVE 1 *****

3504800	2	1	*
3504801	0.0000	0.5400	*
3504802	0.2000	0.5900	*
3504803	0.4000	0.6500	*
3504804	0.6000	0.7700	*
3504805	0.8000	0.9500	*
3504806	0.9000	0.9800	*
3504807	0.9500	0.9600	*
3504808	1.0000	0.8700	*

*TORQUE CURVE 2 *****

3504900	2	2	*
3504901	0.0000	-0.1500	*
3504902	0.2000	0.0200	*
3504903	0.4000	0.2200	*
3504904	0.6000	0.4600	*
3504905	0.8000	0.7100	*
3504906	0.9000	0.8100	*
3504907	0.9500	0.8500	*
3504908	1.0000	0.8700	*

*TORQUE CURVE 3 *****

3505000	2	3	*
3505001	-1.000	0.6200	*
3505002	-0.800	0.6800	*
3505003	-0.600	0.5300	*
3505004	-0.400	0.4600	*
3505005	-0.200	0.4900	*
3505006	0.000	0.5400	*

*TORQUE CURVE 4 *****

3505100	2	4	*
3505101	-1.000	0.6200	*
3505102	-0.800	0.5300	*
3505103	-0.600	0.4600	*
3505104	-0.400	0.4200	*
3505105	-0.200	0.3900	*
3505106	0.000	0.3600	*

*TORQUE CURVE 5 *****

3505200	2	5	*
3505201	0.0000	-0.6300	*
3505202	0.2000	-0.5100	*
3505203	0.4000	-0.3900	*
3505204	0.6000	-0.2900	*
3505205	0.8000	-0.2000	*
3505206	0.9000	-0.1600	*
3505207	1.0000	-0.1300	*

*TORQUE CURVE 6 ****

3505300	2	6	*
3505301	0.0000	0.3600	*
3505302	0.2000	0.3200	*
3505303	0.4000	0.2700	*
3505304	0.6000	0.1800	*
3505305	0.8000	0.0500	*
3505306	1.0000	-0.1300	*

*TORQUE CURVE 7 ****

3505400	2	7	*
3505401	-1.000	-1.4400	*
3505402	-0.800	-1.2500	*
3505403	-0.600	-1.0800	*
3505404	-0.400	-0.9200	*
3505405	-0.200	-0.7700	*
3505406	0.000	-0.6300	*

*

3550000 '20-08-84' BRANCH * SEAL WATER CONNECTION

* NO.J CONTROL

3550001	01	0	*						
*	AREA	LENGTH	VOLUME	H.A.	V.ANGLE	ELEVAT.	ROUGH	DIAM.	FE
3550101	.001660	0.6415	.0000000	0.0	-00.134	-0.0015	8.0-5	.0461	00*
*	CONTROL	PRESSURE	ENERGY	QUALITY					
3550200	0	15.959+6	1.2812+6	0.	*				
*	CODE(FROM)	CODE(TO)	AREA	K(FORD)	K(REV)CAHS	COEFFICIENT			
3551101	355010000	360000000	.000000	00.40	00.40	0000	*		
*	LIQUID VEL	VAPOR VEL.	INTERFACE VEL						
3551201	5.4575	5.4575	0.0			*			
*									

3600000 '05-09-84' PIPE *

* VOLUMES

3600001	3	*				
*	AREA	VOL.NO.				
3600101	.001669	3 *				
*	J.AREA	JUN.NO.				
3600201	.000000	02 *				
*	LENGTH	VOL.NO.				
3600301	0.6415	1 *				
3600302	0.2984	3 *				
*	VOLUME	V.NO.				
3600401	.0000000	3 *				
*	H.A	V.NO.				
3600501	0.0	3 *				
*	V.ANGLE	V.NO.				
3600601	-00.134	1 *				
3600602	+00.288	3 *				
*	ELEVAT.	V.NO.				
3600701	-0.0015	1 *				
3600702	+0.0015	3 *				
*	ROUGH.	DIAM.	V.NO.			
3600801	2.0-5	.0461	3 *			
*	K(FORD)	K(REV)	J.NO.			
3600901	00.50	00.50	01*	.40	.40	
3600902	00.22	00.22	02*	.20	.20	L
*	FE	V.NO				

3601001 00 3 *
 * CAHS J.NO.
 3601101 0000 02 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 3601201 0 15.950+6 1.2812+6 0. 0. 01 *
 3601202 0 15.943+6 1.2812+6 0. 0. 02 *
 3601203 0 15.939+6 1.2812+6 0. 0. 03 *
 * CONTROL
 3601300 0
 * LIQUID VEL./FLOW VAPOUR VEL INTERFACE VEL. JUN NO.
 3601301 5.4281 5.4281 0.0 1 *
 3601302 5.4281 5.4281 0.0 2 *
 *
 *
 3700000 '20-08-84' BRANCH * LEAK ASSEMBLY VOL I
 * NO.J CONTROL
 3700001 2 0 *
 * AREA LENGTH VOLUME H.A. VANGLE ELEVAT. ROUGH DIAM. FE
 3700101 .001669 0.225 .0000000 0.0 0. 0. 2.0-5 .0461 00*
 * CONTROL PRESSURE ENERGY QUALITY
 3700200 0 15.938+6 1.2812+6 0. *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 3701101 360010000 370000000 .000000 00.00 00.00 0000 *
 3702101 370010000 390000000 .000000 00.00 00.00 0000 *
 *703101 370010000 380000000 .000003534 01.00 00.50 0000 *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 3701201 5.4282 5.4282 0.0 *
 3702201 5.4280 5.4280 0.0 *
 *
 3800000 '20-08-84' BRANCH * LEAK DISCHARGE LINE
 * NO.J CONTROL
 3800001 0 0 *
 * AREA LENGTH VOLUME H.A. VANGLE ELEVAT. ROUGH DIAM. FE
 3800101 .001652 1.452 .0000000 0.0 -5.0 -0.1266 8.0-5 .0461 00*
 * CONTROL PRESSURE ENERGY QUALITY
 3800200 0 15.949+6 1.2846+6 0. *
 *
 3810000 '20-08-84' VALVE ** BREAK DISCHARGE
 * FROM TO AREA FORW REV CAHS
 3810101 380010000 382000000 0.0003142 0. 0. 1100* 0.0003142
 * CNTL LIQU VEL VAP VEL 0
 3810201 0 0.0 0.0 0.*
 * VALVE * TYPE
 3810300 MTRVLV*
 * OPEN TRIP NO. CLOSE TRIP NO. CHANGE RATE INITIAL POS.
 3810301 505 502 0.25 0.0
 *
 * 'NAME' TYPE
 3820000 '84-12-15' TMDPVOL * BUNKER
 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
 3820101 1. 1. 0.0 0. 0.0 0.0 8.-5 1. 00*
 * CNTL TRIP VARIABLE CODE
 3820200 3 501 TIME 0 *
 * SEARCH VAR. FLUID COND. (2 QUANTITIES)
 3820201 0. 0.1+6 568.15 *
 *
 3900000 '20-08-84' BRANCH * LEAK ASSEMBLY VOL II
 * NO.J CONTROL
 3900001 02 0 *

* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 3900101 .001669 0.225 .0000000 0.0 0. 0. 2.0-5 .0461 00*
 * CONTROL PRESSURE ENERGY QUALITY
 3900200 0 15.937+6 1.2811+6 0. *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 3901101 390000000 380000000 .000007069 01.00 00.50 0000 *
 3902101 390010000 395000000 .000000 00.00 00.00 0000 *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 3901201 0.0 0.0 0.0 *
 3902201 5.4731 5.4731 0.0 *
 *
 *
 3950000 '05-09-84' PIPE *
 * VOLUMES
 3950001 3 *
 * AREA VOL.NO.
 3950101 .000000 3 *
 * J.AREA JUN.NO.
 3950201 .000000 02 *
 * LENGTH VOL.NO.
 3950301 0.3170 2 *
 3950302 0.7467 3 *
 * VOLUME V.NO.
 3950401 .0005247 2 *
 3950402 .0012350 3 *
 * H.A V.NO.
 *950501 0.0 3 *
 * V.ANGLE V.NO.
 3950601 +00.499 3 *
 * ELEVAT. V.NO.
 3950701 +0.0028 2 *
 3950702 +0.0065 3 *
 * ROUGH. DIAM. V.NO.
 3950801 2.0-5 .0461 3 *
 * K(FORD) K(REV) J.NO.
 3950901 00.00 00.00 01*
 3950902 00.05 00.05 02* .31 .31(.05,.05)
 * FE V.NO
 3951001 00 3 *
 * CAHS J.NO.
 3951101 0000 02 *
 * CONTROL PRESSURE ENERGY QUALITY VOL NO.
 3951201 0 15.936+6 1.2811+6 0. 0. 01 *
 3951202 0 15.935+6 1.2811+6 0. 0. 02 *
 3951203 0 15.932+6 1.2811+6 0. 0. 03 *
 * CONTROL
 3951300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL JUN NO.
 3951301 5.4824 5.4824 0.0 1 *
 3951302 5.4865 5.4865 0.0 2 *
 *
 *BL STRUCTURES
 *

 *VESSEL OUTLET

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13000000 02 8 2 1 0.02305 *
 * FLAG FLAG

13000100 0 1 *
* NO INTERVAL RIGHT COORDINATE
13000101 4 0.050957 *
13000102 3 0.080957 *
* COMPOSITION NO. INTERVAL NO.
13000201 5 4 *
13000202 9 7 *
* SOURCE VALUE INTERVAL NO.
13000301 0.0 7 *
* TEMP POINT NO
13000401 490.46 8 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
13000501 300010000 10000 1 1 0.6790 2 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
13000601 -919 0 3982 1 0.6790 2 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
13000701 0 0 0 0 0 2 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
13000801 0 0.0461 0.0 0.0 2 *

* NH NP G.TYPE FLAG LEFT BOUNDARY
13001000 01 8 2 1 0.02305 *
* FLAG FLAG
13001100 0 1 *
* NO INTERVAL RIGHT COORDINATE
13001101 4 0.0401349 *
13001102 3 0.0701349 *
* COMPOSITION NO. INTERVAL NO.
13001201 5 4 *
13001202 9 7 *
* SOURCE VALUE INTERVAL NO.
13001301 0.0 7 *
* TEMP POINT NO
13001401 471.45 8 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
13001501 300030000 00000 1 1 0.7770 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
13001601 -919 0 3982 1 0.7770 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
13001701 0 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
13001801 0 0.0461 0.0 0.0 1 *

* NH NP G.TYPE FLAG LEFT BOUNDARY
13002000 02 8 2 1 0.02305 *
* FLAG FLAG
13002100 0 1 *
* NO INTERVAL RIGHT COORDINATE
13002101 4 0.0401345 *
13002102 3 0.0701345 *
* COMPOSITION NO. INTERVAL NO.
13002201 5 4 *
13002202 9 7 *
* SOURCE VALUE INTERVAL NO.
13002301 0.0 7 *
* TEMP POINT NO
13002401 471.45 8 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
13002501 300040000 0000 1 1 0.738 1 *

13002502 300050000 0000 1 1 0.867 2 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13002601 -919 0 3982 1 0.738 1 *
 13002602 -919 0 3982 1 0.867 2 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13002701 0 0 0 0 0 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13002801 0 0.0461 0.0 0.0 2 *
 *

 *STEAM GENERATOR (PRIMARY SIDE) _ BEFORE INLET CHAMBER

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13300000 04 10 2 1 0.03420 *
 * FLAG FLAG
 13300100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13300101 4 0.041866 *
 13300102 5 0.071866 *
 * COMPOSITION NO. INTERVAL NO.
 13300201 5 4 *
 13300202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 13300301 0.0 9 *
 *
 13300400 -1*
 * TEMP POINT NO
 13300401 599.00 598.89 598.78 598.68 598.59 527.85
 + 465.38 409.41 358.72 312.42
 13300402 598.99 598.88 598.78 598.68 598.59 527.85
 + 465.38 409.41 358.72 312.42
 13300403 598.99 598.88 598.78 598.68 598.58 527.85
 + 465.37 409.40 358.72 312.42
 13300404 598.98 598.87 598.77 598.67 598.58 527.85
 + 465.37 409.40 358.72 312.42
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13300501 330010000 10000 1 1 0.4490 4 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13300601 -919 0 3982 1 0.4490 4 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13300701 0 0 0 0 0 4 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13300801 0 0.0684 0.0 0.0 4 *
 *

 *STEAM GENERATOR PRIMARY SIDE (INLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13301000 01 10 2 1 0.051 *
 * FLAG FLAG
 13301100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13301101 4 0.063161 *
 13301102 5 0.163161 *
 * COMPOSITION NO. INTERVAL NO.
 13301201 5 4 *
 13301202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 13301301 0.0 9 *

*
 13301400 -1
 *
 TEMP POINT NO
 13301401 598.92 598.86 598.80 598.74 598.68 512.74
 +
 444.76 388.73 341.10 299.69
 *
 BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13301501 330050000 0 1 1 0.2160 1 *
 *
 BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13301601 -919 0 3982 1 0.2160 1 *
 *
 SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13301701 0 0 0 0 0 1 *
 *
 CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13301801 0 0.102 0.0 0.0 1 *
 *

 *STEAM GENERATOR (TUBES)

 *
 NH NP G.TYPE FLAG LEFT BOUNDARY
 13302000 22 6 2 1 0.00980 *
 *
 FLAG FLAG
 13302100 0 1 *
 *
 NO INTERVAL RIGHT COORDINATE
 13302101 5 0.011 *
 *
 COMPOSITION NO. INTERVAL NO.
 13302201 7 5 *
 *
 SOURCE VALUE INTERVAL NO.
 13302301 0.0 5 *
 *
 13302400 -1
 *
 TEMP POINT NO
 13302401 585.07 580.58 576.17 571.85 567.61 563.45
 13302402 583.50 579.29 575.15 571.10 567.12 563.22
 13302403 581.98 578.02 574.14 570.33 566.59 562.93
 13302404 580.57 576.86 573.22 569.65 566.16 562.72
 13302405 579.19 575.71 572.30 568.96 565.69 562.47
 13302406 577.87 574.61 571.42 568.29 565.22 562.21
 13302407 576.64 573.59 570.59 567.66 564.78 561.97
 13302408 575.48 572.61 569.80 567.05 564.35 561.71
 13302409 574.39 571.69 569.05 566.47 563.94 561.46
 13302410 573.37 570.84 568.36 565.94 563.56 561.24
 13302411 571.72 569.32 566.97 564.68 562.43 560.22
 13302412 570.44 568.24 566.10 564.00 561.95 559.93
 13302413 569.78 567.80 565.85 563.95 562.09 560.27
 13302414 568.98 567.11 565.28 563.49 561.47 560.02
 13302415 568.23 566.47 564.75 563.07 561.42 559.81
 13302416 567.52 565.87 564.25 562.67 561.13 559.61
 13302417 566.86 565.30 563.78 562.30 560.84 559.42
 13302418 566.23 564.77 563.35 561.95 560.58 559.24
 13302419 565.63 564.26 562.92 561.61 560.33 559.07
 13302420 565.06 563.77 562.51 561.28 560.08 558.90
 13302421 564.53 563.32 562.14 560.99 559.86 558.76
 13302422 563.95 562.80 561.67 560.57 559.49 558.43
 *
 BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13302501 330060000 10000 1 1 5.216 10 * 4.968
 13302502 330160000 10000 1 1 7.245 12 * 6.900
 13302503 330180000 10000 1 1 5.216 22 * 4.968
 *
 BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13302601 620010000 10000 1 1 5.216 10 *
 13302602 620110000 0000 1 1 7.245 11 *

13302603 620110000 0000 1 1 7.245 12 *
 13302604 620100000 -10000 1 1 5.216 22 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13302701 0 0 0 0 0 22 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13302801 0 0.0196 0.0 0.0 22 *
 13302901 0 0.0220 0.0 0.0 22 *
 *

 *STEAM GENERATOR (OUTLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13303000 01 10 2 1 0.051 *
 * FLAG FLAG
 13303100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13303101 4 0.063161 *
 13303102 5 0.163161 *
 * COMPOSITION NO. INTERVAL NO.
 13303201 5 4 *
 13303202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 13303301 0.0 9 *
 *
 13303400 -1
 * TEMP POINT NO
 13303401 567.00 566.93 566.88 566.82 566.77 489.66 428.86
 + 378.78 336.22 299.21
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13303501 330280000 0 1 1 0.2160 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13303601 -919 0 3982 1 0.2160 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13303701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13303801 0 0.1020 0.0 0.0 1 *
 *

 *STEAM GENERATOR (PRIMARY SIDE)_ AFTER OUTLET CHAMBER

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13304000 04 10 2 1 0.0342 *
 * FLAG FLAG
 13304100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13304101 4 0.041866 *
 13304102 5 0.071866 *
 * COMPOSITION NO. INTERVAL NO.
 13304201 5 4 *
 13304202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 13304301 0.0 9 *
 13304400 -1
 * TEMP POINT NO
 13304401 567.00 566.90 566.80 566.71 566.62 503.27 447.35
 + 397.29 351.97 310.58
 13304402 567.00 566.90 566.80 566.71 566.62 503.27 447.35
 + 397.29 351.97 310.58
 13304403 567.00 566.89 566.80 566.71 566.62 503.27 447.35

+ 397.29 351.97 310.58
 13304404 566.99 566.89 566.80 566.71 566.62 503.27 447.35
 + 397.29 351.97 310.58
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13304501 330290000 10000 1 1 0.4490 4 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13304601 -919 0 3982 1 0.4490 4 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13304701 0 0 0 0 0 4 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13304801 0 0.0684 0.0 0.0 4 *
 *

 *INLET/OUTLET CHAMBER PARTITIONING DISC

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13305000 01 6 1 1 0.0 *
 * FLAG FLAG
 13305100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13305101 5 0.02 *
 * COMPOSITION NO. INTERVAL NO.
 13305201 5 5 *
 * SOURCE VALUE INTERVAL NO.
 13305301 0.0 5 *
 * CONTROL WORD
 13305400 -1
 13305401 595.04 590.33 585.60 580.85 576.08 571.29
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13305501 330050000 0 1 1 0.04 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13305601 330280000 0 1 1 0.04 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13305701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13305801 0 0.102 0.0 0.0 1 *
 13305901 0 0.102 0.0 0.0 1 *
 *

 *PIPE UPTO PUMP INLET

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13400000 08 8 2 1 0.02305 *
 * FLAG FLAG
 13400100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13400101 4 0.041752 *
 13400102 3 0.071752 *
 * COMPOSITION NO. INTERVAL NO.
 13400201 5 4 *
 13400202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 13400301 0.0 7 *
 * TEMP POINT NO
 13400401 455.76 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13400501 340010000 10000 1 1 0.7300 3 *
 13400502 340040000 00000 1 1 0.8490 4 *
 13400503 340050000 00000 1 1 0.7320 5 *

13400504 340060000 00000 1 1 0.7114 6 *
 13400505 340070000 10000 1 1 0.5920 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13400601 -919 0 3982 1 0.7300 3 *
 13400602 -919 0 3982 1 0.8490 4 *
 13400603 -919 0 3982 1 0.7320 5 *
 13400604 -919 0 3982 1 0.7114 6 *
 13400605 -919 0 3982 1 0.5920 8 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13400701 0 0 0 0 0 8 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13400801 0 0.0461 0.0 0.0 8 *
 *

 *PUMP

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13500000 01 10 2 1 0.03250 *
 * FLAG FLAG
 13500100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13500101 9 0.1467212 *
 * COMPOSITION NO. INTERVAL NO.
 13500201 5 9 *
 * SOURCE VALUE INTERVAL NO.
 13500301 0.0 9 *
 * TEMP POINT NO
 13500401 455.60 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13500501 350010000 00000 1 1 0.7142 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13500601 -919 0 3983 1 0.7142 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13500701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13500801 0 0.0650 0.0 0.0 1 *
 *
 *

 *PIPE WITH MEASUREMENT INSERT & RESISTANCE SIMULATOR

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13600000 01 8 2 1 0.02305 *
 * FLAG FLAG
 13600100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13600101 4 0.057466 *
 13600102 3 0.087466 *
 * COMPOSITION NO. INTERVAL NO.
 13600201 5 4 *
 13600202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 13600301 0.0 7 *
 * TEMP POINT NO
 13600401 477.25 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13600501 355010000 00000 1 1 0.6415 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13600601 -919 0 3982 1 0.6415 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13600701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13600801 0 0.0461 0.0 0.0 1 *

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13601000 01 8 2 1 0.02305 *
 * FLAG FLAG
 13601100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13601101 4 0.057466 *
 13601102 3 0.087466 *
 * COMPOSITION NO. INTERVAL NO.
 13601201 5 4 *
 13601202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 13601301 0.0 7 *
 * TEMP POINT NO
 13601401 477.25 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13601501 360010000 00000 1 1 0.6415 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13601601 -919 0 3982 1 0.6415 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13601701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13601801 0 0.0461 0.0 0.0 1 *

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13602000 02 8 2 1 0.02305 *
 * FLAG FLAG
 13602100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13602101 4 0.030158 *
 13602102 3 0.060158 *
 * COMPOSITION NO. INTERVAL NO.
 13602201 5 4 *
 13602202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 13602301 0.0 7 *
 * TEMP POINT NO
 13602401 429.43 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13602501 360020000 10000 1 1 0.2980 2 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13602601 -919 0 3982 1 0.2980 2 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13602701 0 0 0 0 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13602801 0 0.0461 0.0 0.0 2 *
 *

 * LEAK ASSEMBLY I

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13700000 01 5 2 1 0.02305 *
 * FLAG FLAG
 13700100 0 1 *
 * NO INTERVAL RIGHT COORDINATE

13700101 4 0.030158 *
 * COMPOSITION NO. INTERVAL NO.
 13700201 5 4 *
 * SOURCE VALUE INTERVAL NO.
 13700301 0.0 4 *
 * TEMP POINT NO
 13700401 564.30 5 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13700501 370010000 00000 1 1 0.2250 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13700601 -919 0 3982 1 0.2250 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13700701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13700801 0 0.0461 0.0 0.0 1 *
 *
 ****=
 *LEAK DISCHARGE LINE WITH MEASUREMENT INSERT
 ****=
 * * NH NP G.TYPE FLAG LEFT BOUNDARY
 * 13800000 04 5 2 1 0.02305 *
 * * FLAG FLAG
 * 13800100 0 1 *
 * * NO INTERVAL RIGHT COORDINATE
 * 13800101 4 0.047802 *
 * * COMPOSITION NO. INTERVAL NO.
 * 13800201 5 4 *
 * * SOURCE VALUE INTERVAL NO.
 * 13800301 0.0 4 *
 * * TEMP POINT NO
 * 13800401 567.2 5 *
 * * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 * 13800501 380010000 10000 1 1 0.3630 4 *
 * * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 * 13800601 -919 0 3982 1 0.3630 4 *
 * * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 * 13800701 0 0 0 0 4 *
 * * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 * 13800801 0 0.0461 0.0 0.0 4 *
 * *
 ****=
 *LEAK ASSEMBLY II
 ****=
 * * NH NP G.TYPE FLAG LEFT BOUNDARY
 13900000 01 5 2 1 0.02305 *
 * * FLAG FLAG
 13900100 0 1 *
 * * NO INTERVAL RIGHT COORDINATE
 13900101 4 0.030158 *
 * * COMPOSITION NO. INTERVAL NO.
 13900201 5 4 *
 * * SOURCE VALUE INTERVAL NO.
 13900301 0.0 4 *
 * * TEMP POINT NO
 13900401 564.29 5 *
 * * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13900501 390010000 00000 1 1 0.2250 1 *
 * * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13900601 -919 0 3982 1 0.2250 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13900701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13900801 0 0.0461 0.0 0.0 1 *
 *

 *PIPE WITH MEASUREMENT INSERT & VESSEL INLET

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13950000 02 8 2 1 0.02305 *
 * FLAG FLAG
 13950100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13950101 4 0.065682 *
 13950102 3 0.095682 *
 * COMPOSITION NO. INTERVAL NO.
 13950201 5 4 *
 13950202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 13950301 0.0 7 *
 * TEMP POINT NO
 13950401 485.15 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13950501 395010000 10000 1 1 0.3170 2 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13950601 -919 0 3982 1 0.3170 2 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13950701 0 0 0 0 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13950801 0 0.0461 0.0 0.0 2 *
 *
 * NH NP G.TYPE FLAG LEFT BOUNDARY
 13951000 01 8 2 1 0.02305 *
 * FLAG FLAG
 13951100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 13951101 4 0.065682 *
 13951102 3 0.095682 *
 * COMPOSITION NO. INTERVAL NO.
 13951201 5 4 *
 13951202 9 7 *
 * SOURCE VALUE INTERVAL NO.
 13951301 0.0 7 *
 * TEMP POINT NO
 13951401 485.15 8 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13951501 395030000 00000 1 1 0.7467 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 13951601 -919 0 3982 1 0.7467 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 13951701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 13951801 0 0.0461 0.0 0.0 1 *
 *
 *
 *PRESSURIZER
 *
 *
 *PR CONTROL VARIABLES

*

20540000	DUMMY	SUM	1.	0.	1
20540001	0.	1.	CPUTIME	0	

*

20540100	PA40	SUM	1.-6	0.	1
20540101	0.	1.	P	420070000	

*

20540200	L1	SUM	1.-3	0.	1		
20540201	0.	.16977	HTRNR	400000101	.12127	HTRNR	400000201
+		.12127	HTRNR	400000301	.12127	HTRNR	400000401
+		.14673	HTRNR	400000501	.14261	HTRNR	400000601
+		.11714	HTRNR	400000701	.11714	HTRNR	400000801
+		.11714	HTRNR	400000901	.11714	HTRNR	400001001
+		.11714	HTRNR	400001101	.14140	HTRNR	400001201
+		.17705	HTRNR	400001301	.69492	HTRNR	410000101
+		.51459	HTRNR	420000101	.93172	HTRNR	420000201
+		.93172	HTRNR	420000301	.93172	HTRNR	420000401
+		.93172	HTRNR	420000501	.93172	HTRNR	420000601
20540300	L2	SUM	1.-3	0.	1		
20540301	0.	.56077	HTRNR	420000701			

*

20540400	LOSS-PR	SUM	1.	0.	1		
20540401	0.	1.	CNTRLVAR	402	1.	CNTRLVAR	403

*

20540500	CL4340	SUM	1.	0.	1		
20540501	0.	0.7900	VOIDF	410010000	0.5850	VOIDF	420010000
+		0.6375	VOIDF	420020000	0.6375	VOIDF	420030000
+		0.6375	VOIDF	420040000	0.6375	VOIDF	420050000
+		0.6375	VOIDF	420060000	0.6375	VOIDF	420070000
*		0.6325	VOIDF	420080000	0.6325	VOIDF	420090000
*		0.6325	VOIDF	420100000	0.6325	VOIDF	420110000

*

*PR VOLUMES

*

4000000 '84-12-12' PIPE * SURGE LINE

* VOLUMES

40000001	13	*
*	AREA	VOL.NO.
4000101	.000137	13 *
*	J.AREA	JUN.NO.
4000201	.000000	12 *
*	LENGTH	VOL.NO.
4000301	0.7000	1 *
4000302	0.5000	4 *
4000303	0.6050	5 *
4000304	0.5880	6 *
4000305	0.4870	11 *
4000306	0.5830	12 *
4000307	0.7300	13 *
*	VOLUME	V.NO.
4000401	.0000000	13 *
*	H.A	V.NO.
4000501	0.0	13 *
*	V.ANGLE	V.NO.
4000601	-45.585	01 *
4000602	-90.000	04 *
4000603	-55.735	05 *
4000604	+55.228	06 *
4000605	+90.000	11 *

4000606 +55.942 12 *

 4000607 -59.657 13 *

 * ROUGH. DIAM. V.NO.

 4000801 8.0-5 .0132 13 *

 * K(FORD) K(REV) J.NO.

 4000901 00.16 00.16 01 *

 4000902 00.00 00.00 04 *

 4000903 00.32 00.32 05 *

 4000904 00.00 00.00 11 *

 4000905 00.32 00.32 12 *

 * FE V.NO

 4001001 00 13 *

 * CAHS J.NO.

 4001101 0000 12 *

 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.

 4001201 0 15.758+6 1.4677+6 0. 0. 01 *

 4001202 0 15.761+6 1.3172+6 0. 0. 02 *

 4001203 0 15.765+6 1.3544+6 0. 0. 03 *

 4001204 0 15.768+6 1.3888+6 0. 0. 04 *

 4001205 0 15.772+6 1.4179+6 0. 0. 05 *

 4001206 0 15.772+6 1.4461+6 0. 0. 06 *

 4001207 0 15.769+6 1.4659+6 0. 0. 07 *

 4001208 0 15.766+6 1.4774+6 0. 0. 08 *

 4001209 0 15.762+6 1.4868+6 0. 0. 09 *

 4001210 0 15.759+6 1.4954+6 0. 0. 10 *

 4001211 0 15.756+6 1.5048+6 0. 0. 11 *

 4001212 0 15.753+6 1.5168+6 0. 0. 12 *

 4001213 0 15.754+6 1.5377+6 0. 0. 13 *

 * CONTROL

 4001300 0

 * LIQUID VEL VAPOUR VEL INTERFACE VEL JUN NO.

 4001301 -4.2163-3 -4.2163-3 0.0 1 *

 4001302 -4.3702-3 -4.3702-3 0.0 2 *

 4001303 -4.5401-3 -4.5401-3 0.0 3 *

 4001304 -4.7224-3 -4.7224-3 0.0 4 *

 4001305 -4.9558-3 -4.9558-3 0.0 5 *

 4001306 -5.1932-3 -5.1932-3 0.0 6 *

 4001307 -5.3930-3 -5.3930-3 0.0 7 *

 4001308 -5.5989-3 -5.5989-3 0.0 8 *

 4001309 -5.8092-3 -5.8092-3 0.0 9 *

 4001310 -6.0271-3 -6.0271-3 0.0 10 *

 4001311 -6.2579-3 -6.2597-3 0.0 11 *

 4001312 -6.5609-3 -6.5609-3 0.0 12 *

 *

 *

 4100000 '84-12-12' BRANCH * LOWER VOLUME

 * NO.J CONTROL

 4100001 02 0 *

 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE

 4100101 .006346 0.7900 .0000000 0.0 +90.000 +0.7900 8.0-5 .0260 00*

 * CONTROL PRESSURE ENERGY QUALITY

 4100200 0 15.758+6 1.5845+6 0.0 *

 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS

 4101101 400010000 410010000 .000000 00.00 00.00 0100 *

 4102101 410010000 420000000 .000000 00.00 00.00 0000 *

 * LIQUID VEL VAPOR VEL. INTERFACE VEL

 4101201 -7.0196-3 -7.0196-3 0.0 *

 4102201 -1.7430-4 -1.7430-4 0.0 *

 *

*
 4200000 '84-12-12' PIPE * UPPER VOLUME
 * VOLUMES
 4200001 07 *
 * AREA VOL.NO.
 4200101 .008227 1 *
 4200102 .011962 07 *
 * J.AREA JUN.NO.
 4200201 .000000 06 *
 * LENGTH VOL.NO.
 4200301 0.5850 1 *
 4200302 0.6375 07 *
 *200303 0.6325 11 *
 * VOLUME V.NO.
 4200401 .0000000 07 *
 * H.A V.NO.
 4200501 0.0 07 *
 * V.ANGLE V.NO.
 4200601 +90.000 07 *
 * ROUGH. DIAM. V.NO.
 4200801 8.0-5 .0320 1 *
 4200802 8.0-5 .1240 07 *
 * K(FORD) K(REV) J.NO.
 4200901 00.00 00.00 06 *
 * FE V.NO
 4201001 00 07 *
 * CAHS J.NO.
 4201101 0000 06 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 4201201 0 15.754+6 1.5948+6 0. 0. 01 *
 4201202 0 15.750+6 1.5971+6 0. 0. 02 *
 4201203 0 15.746+6 1.5972+6 0. 0. 03 *
 4201204 0 15.743+6 1.5972+6 0. 0. 04 *
 4201205 0 15.739+6 1.5972+6 0. 0. 05 *
 4201206 0 15.735+6 1.5974+6 0. 0. 06 *
 4201207 0 15.731+6 1.5992+6 0. 0. 07 *
 * CONTROL
 4201300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
 4201301 -1.4880-4 -1.4880-4 0.0 01 *
 4201302 -1.1877-4 -1.1877-4 0.0 02 *
 4201303 -1.3520-4 -1.3520-4 0.0 03 *
 4201304 -1.5163-4 -1.5163-4 0.0 04 *
 4201305 -1.6809-4 -1.6809-4 0.0 05 *
 4201306 -1.8478-4 -1.8478-4 0.0 06 *
 *
 * 'NAME' TYPE
 4210000 '84-12-12' SNGLJUN * PRESSURISER
 * FROM TO AREA
 4210101 422000000 420010000 0.0 0.0 0.0 0000*
 * CONTROL LIQUID V. VAPOR V. 0
 4210201 0 2.0339-4 2.0339-4 0.0 *
 * 'NAME' TYPE
 4220000 '84-12-12' TMDPVOL * PRESSURISER (STEAM REGION)
 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
 4220101 0.011962 2.5300 0.0 0. 90.0 2.5300 8.-5 0.124 00*
 * CNTL TRIP VARIABLE CODE
 4220200 1 501 TIME 0 *
 * SEARCH VAR. FLUID COND. (2 QUANTITIES)

4220201 0. 619.10 0. * 619.16

*
*PR STRUCTURES
*

*PRESSURISER - SURGE LINE

* NH NP G.TYPE FLAG LEFT BOUNDARY

14000000 13 7 2 1 0.0066 *

* FLAG FLAG

14000100 0 1 *

* NO INTERVAL RIGHT COORDINATE

14000101 3 0.0086 *

14000102 3 0.0386 *

* COMPOSITION NO. INTERVAL NO.

14000201 5 3 *

14000202 9 6 *

* SOURCE VALUE INTERVAL NO.

14000301 0.0 6 *

* TEMP POINT NO

14000401 405.00 7 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

14000501 400010000 00000 1 1 0.7000 1 *

14000502 400020000 10000 1 1 0.5000 4 *

14000503 400050000 00000 1 1 0.6050 5 *

14000504 400060000 00000 1 1 0.5880 6 *

14000505 400070000 10000 1 1 0.4830 11 *

14000506 400120000 00000 1 1 0.5830 12 *

14000507 400130000 00000 1 1 0.7300 13 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

14000601 -919 0 3959 1 0.7000 1 *

14000602 -919 0 3959 1 0.5000 4 *

14000603 -919 0 3959 1 0.6050 5 *

14000604 -919 0 3959 1 0.5880 6 *

14000605 -919 0 3959 1 0.4830 11 *

14000606 -919 0 3959 1 0.5830 12 *

14000607 -919 0 3959 1 0.7300 13 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO

14000701 0 0 0 0 0 13 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

14000801 0 0.0132 0.0 0.0 13 *

*

*PRESSURISER - LOWER VOLUME

* NH NP G.TYPE FLAG LEFT BOUNDARY

14100000 1 9 2 1 0.062 *

* FLAG FLAG

14100100 0 1 *

* NO INTERVAL RIGHT COORDINATE

14100101 5 0.0800 *

14100102 3 0.1400 *

* COMPOSITION NO. INTERVAL NO.

14100201 5 5 *

14100202 9 8 *

* SOURCE VALUE INTERVAL NO.

14100301 0.0 8 *

* TEMP POINT NO

14100401 470.35 9 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 14100501 410010000 0 1 1 0.7900 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 14100601 -919 0 3959 1 0.7900 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 14100701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 14100801 0 0.0260 0.0 0.0 1 *
 *
 *

 *PRESSURISER - UPPER VOLUME

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 14200000 07 9 2 1 0.062 *
 * FLAG FLAG
 14200100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 14200101 5 0.0800 *
 14200102 3 0.1400 *
 * COMPOSITION NO. INTERVAL NO.
 14200201 5 5 *
 14200202 9 8 *
 * SOURCE VALUE INTERVAL NO.
 14200301 0.0 8 *
 * TEMP POINT NO
 14200401 471.21 9 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 14200501 420010000 00000 1 1 0.5850 1 *
 14200502 420020000 10000 1 1 1.0592 07 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 14200601 -919 0 3959 1 0.5850 1 *
 14200602 -919 0 3959 1 1.0592 07 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 14200701 0 0 0 0 0 07 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 14200801 0 0.0320 0.0 0.0 07 *
 *
 *
 *STEAM GENERATOR I
 *
 *
 *SG1 CONTROL VARIABLES
 *
 20550000 DUMMY SUM 1. 0. 1
 20550001 0. 1. CPUTIME 0
 * LIQUID MASS INVENTORY
 20550100 V50501 MULT 0.0060126 0 1*F.W INLET RING (50501)
 20550200 V51001 MULT 0.0103929 0 1*DOWNCOMER (51001)
 20550300 V51002 MULT 0.0073971 0 1*DOWNCOMER (51002)
 20550400 V51003 MULT 0.0073971 0 1*DOWNCOMER (51003)
 20550500 V51004 MULT 0.0073971 0 1*DOWNCOMER (51004)
 20550600 V51005 MULT 0.0073971 0 1*DOWNCOMER (51005)
 20550700 V51006 MULT 0.0073971 0 1*DOWNCOMER (51006)
 20550800 V51007 MULT 0.0073971 0 1*DOWNCOMER (51007)
 20550900 V51008 MULT 0.0073971 0 1*DOWNCOMER (51008)
 20551000 V51009 MULT 0.0073971 0 1*DOWNCOMER (51009)
 20551100 V51010 MULT 0.0073971 0 1*DOWNCOMER (51010)
 20551200 V51011 MULT 0.0063216 0 1*DOWNCOMER (51011)

20551400	V52001	MULT	0.0155843	0	1*RISER/BOILER	(52001)
20551500	V52002	MULT	0.0182357	0	1*RISER/BOILER	(52002)
20551600	V52003	MULT	0.0182357	0	1*RISER/BOILER	(52003)
20551700	V52004	MULT	0.0182357	0	1*RISER/BOILER	(52004)
20551800	V52005	MULT	0.0182357	0	1*RISER/BOILER	(52005)
20551900	V52006	MULT	0.0182357	0	1*RISER/BOILER	(52006)
20552000	V52007	MULT	0.0182357	0	1*RISER/BOILER	(52007)
20552100	V52008	MULT	0.0182357	0	1*RISER/BOILER	(52008)
20552200	V52009	MULT	0.0182357	0	1*RISER/BOILER	(52009)
20552300	V52010	MULT	0.0182357	0	1*RISER/BOILER	(52010)
20552400	V52011	MULT	0.0306013	0	1*RISER/BOILER	(52011)
20552500	V52012	MULT	0.0321193	0	1*RISER/BOILER	(52012)
20552600	V52013	MULT	0.0388078	0	1*RISER/BOILER	(52013)
20552700	V52014	MULT	0.0333336	0	1*RISER/BOILER	(52014)
20552800	V52015	MULT	0.0729641	0	1*RISER/BOILER	(52015)
20552900	V53001	MULT	0.0580046	0	1*SEPERATOR	(53001)
20553000	V54001	MULT	0.0995201	0	1*DOWNCOMER	(54001)
20553100	V54002	MULT	0.0773596	0	1*DOWNCOMER	(54002)
20553200	M1	SUM	1.0	0	1* MASS INVENTORY	
20553300	T2	SUM	1.0	0	1* MASS INVENTORY	
20553400	INVENT1	SUM	1.0	0	1*TOTAL MASS INVENTORY SGI	

20553500	V50501	MULT	0.0517077	0	1*DOWNCOMER	(55001)

20550101	RHOF	505010000	VOIDF	505010000		
20550201	RHOF	510010000	VOIDF	510010000		
20550301	RHOF	510020000	VOIDF	510020000		
20550401	RHOF	510030000	VOIDF	510030000		
20550501	RHOF	510040000	VOIDF	510040000		
20550601	RHOF	510050000	VOIDF	510050000		
20550701	RHOF	510060000	VOIDF	510060000		
20550801	RHOF	510070000	VOIDF	510070000		
20550901	RHOF	510080000	VOIDF	510080000		
20551001	RHOF	510090000	VOIDF	510090000		
20551101	RHOF	510100000	VOIDF	510100000		
20551201	RHOF	510110000	VOIDF	510110000		

20551401	RHOF	520010000	VOIDF	520010000		
20551501	RHOF	520020000	VOIDF	520020000		
20551601	RHOF	520030000	VOIDF	520030000		
20551701	RHOF	520040000	VOIDF	520040000		
20551801	RHOF	520050000	VOIDF	520050000		
20551901	RHOF	520060000	VOIDF	520060000		
20552001	RHOF	520070000	VOIDF	520070000		
20552101	RHOF	520080000	VOIDF	520080000		
20552201	RHOF	520090000	VOIDF	520090000		
20552301	RHOF	520100000	VOIDF	520100000		
20552401	RHOF	520110000	VOIDF	520110000		
20552501	RHOF	520120000	VOIDF	520120000		
20552601	RHOF	520130000	VOIDF	520130000		
20552701	RHOF	520140000	VOIDF	520140000		
20552801	RHOF	520150000	VOIDF	520150000		

20552901	RHOF	530010000	VOIDF	530010000		

20553001	RHOF	540010000	VOIDF	540010000		
20553101	RHOF	540020000	VOIDF	540020000		

20553201	0.	1.0	CNTRLVAR 501 1.0		CNTRLVAR 502	

+ 1.0 CNTRLVAR 503 1.0 CNTRLVAR 504
 + 1.0 CNTRLVAR 505 1.0 CNTRLVAR 506
 + 1.0 CNTRLVAR 507 1.0 CNTRLVAR 508
 + 1.0 CNTRLVAR 509 1.0 CNTRLVAR 510
 + 1.0 CNTRLVAR 511 1.0 CNTRLVAR 512
 + 1.0 CNTRLVAR 514 1.0 CNTRLVAR 515
 + 1.0 CNTRLVAR 516 1.0 CNTRLVAR 517
20553301 0. 1.0 CNTRLVAR 518 1.0 CNTRLVAR 519
 + 1.0 CNTRLVAR 520 1.0 CNTRLVAR 521
 + 1.0 CNTRLVAR 522 1.0 CNTRLVAR 523
 + 1.0 CNTRLVAR 524 1.0 CNTRLVAR 525
 + 1.0 CNTRLVAR 526 1.0 CNTRLVAR 527
 + 1.0 CNTRLVAR 528 1.0 CNTRLVAR 529
 + 1.0 CNTRLVAR 530 1.0 CNTRLVAR 531
 + 1.0 CNTRLVAR 535
20553401 0. 1.0 CNTRLVAR 532 1.0 CNTRLVAR 533

20553501 RHOF 550010000 VOIDF 550010000
* HEAT LOSSES
20554300 LOSS-S1 SUM 1.-3 0. 1
* AO SURFACE AREA VAR. CODE SURFACE AREA VAR. CODE
20554301 0 0.59223 HTRNR 550000101
+ 1.1903 HTRNR 510000101 0.84721 HTRNR 510000201
+ 0.84721 HTRNR 510000301 0.84721 HTRNR 510000401
+ 0.84721 HTRNR 510000501 0.84721 HTRNR 510000601
+ 0.84721 HTRNR 510000701 0.84721 HTRNR 510000801
+ 0.84721 HTRNR 510000901 0.84721 HTRNR 510001001
+ 0.72403 HTRNR 510001101
+ 1.5886 HTRNR 540000101
+ 1.3909 HTRNR 540100101
+ 1.2332 HTRNR 520100101
+ 0.79247 HTRNR 560000101
+ 0.20284 HTRNR 560100101
20554400 PA97S SUM 1.-6 0. 1
20554401 0. 1. P 560010000
20554500 TF95B SUM 1. 0. 1
20554501 -273.15 1. TEMP 520010000
20554600 TF95N SUM 1. 0. 1
20554601 -273.15 1. TEMP 520110000
20554700 TF97T SUM 1. 0. 1
20554701 -273.15 1. TEMP 560010000
20554800 CM93G SUM 1. 0. 1
20554801 0. 1. MFLOWJ 510070000
20554900 CM65 SUM 1. 0. 1
20554901 0. 1. MFLOWJ 560010000
* EXIT POWER (MW), ENERGY MJ
20555000 DELTAU SUM 1. 0. 1
20555001 0. 1. U 560010000 -1. U 500010000
20555100 POWSGI MULT 1.-6 0. 1
20555101 CNTRLVAR 550 MFLOWJ 560010000
20555300 HTSGI INTEGRAL 1.0 0. 1
20555301 CNTRLVAR 551
* LIQUID LEVEL
20555200 CL93BN SUM 1.000 0 1* STEAM GEN. SEC. SIDE
* AO LENGTH VAR. CODE LENGTH VAR. CODE
20555201 0.0 0.671 VOIDF 520150000 0.860 VOIDF 540010000
+ 0.843 VOIDF 540020000 0.433 VOIDF 550010000
+ 0.870 VOIDF 510010000 0.619 VOIDF 510020000

+ 0.619 VOIDF 510030000 0.619 VOIDF 510040000
+ 0.619 VOIDF 510050000 0.619 VOIDF 510060000
+ 0.619 VOIDF 510070000 0.619 VOIDF 510080000
+ 0.619 VOIDF 510090000 0.619 VOIDF 510100000
+ 0.529 VOIDF 510110000

*
*SG1 CONTROLLER
*
* STEAM FLOW CONTROL
*
20556800 DT SUM 1. 0. 1
20556801 652.00 -1.-4 P 560010000
*0556801 566.86 -1. TEMPF 270010000
20556900 DEADBAND FUNCTION 1.0 0. 1
20556901 CNTRLVAR 568 502

*
*
20557000 INTDELT INTEGRAL 1. 0. 1
20557001 CNTRLVAR 569
20557100 STEMPOS SUM 1. 0.0666 0 3 0. 1. *0.0666
20557101 0.0666 -.0144 CNTRLVAR 569 -.0015 CNTRLVAR 570 *0.0666

*
20557200 LVLERR SUM 1.0 0. 1
*INPUT LIQUID LEVEL
20557201 8.33 -1. CNTRLVAR 552
20557300 FEEDMULT FUNCTION 1. 1. 1
20557301 CNTRLVAR 572 503

*
*
20557400 FEEDFLOW MULT 1. 2.0 0
20557401 CNTRLVAR 573 MFLOWJ 560010000 CNTRLVAR 575
20557500 CLOSE FUNCTION 1.0 1.0 0 *
20557501 CNTRLVAR 576 576
20557600 ARGUM MULT 1.0 0.0 0
20557601 CNTRLVAR 578 CNTRLVAR 579
20557700 TRIPD TRIPDAY 1.0 0.0 1
20557701 506
20557800 ARGUM SUM 1.0 0.0 1
20557801 0. 1. TIME 0 -1. CNTRLVAR 577
20557900 ONOFF TRIPUNIT 1. 0. 0
20557901 506
* PRESSURE DROPS
*
20559100 PD-BS SUM 1.-6 0 1* B & S (DOWNCOMER)
20559200 PD-RS SUM 1.-6 0 1* R & S (DOWNCOMER)
20559300 PD-ST SUM 1.-6 0 1* S & T
20559400 PD93FB10 SUM 1.-6 0 1* PD93FB10
20559500 PD95BF06 SUM 1.-6 0 1* PD95BF06

*
20559101 0.0 0.5 P 510110000 0.5 P 520010000
+ 1.471 RHO 510110000 1.471 RHO 520010000
+ -1.0 P 520150000 -1.814 RHO 520150000
20559201 0.0 1.0 P 540020000 1.647 RHO 540020000
+ -1.0 P 520150000 -1.814 RHO 520150000
20559301 0.0 1.0 P 520150000 1.814 RHO 520150000
+ -1.0 P 560010000 1.765 RHO 560010000
20559401 0.0 1.0 P 510090000 -2.765 RHO 510090000
+ -0.5 P 510110000 -0.5 P 520010000
+ -1.471 RHO 510110000 -1.471 RHO 520010000

20559501 0.0 0.5 P 510110000 0.5 P 520010000
 + 1.471 RHO 510110000 1.471 RHO 520010000
 + -1.0 P 520030000 2.765 RHO 520030000
 *
 *
 **SG1 VOLUMES
 *
 * 'NAME' TYPE
 5000000 '84-12-15' TMDPVOL * FEED WATER INLET
 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
 5000101 0.011698 0.5140 0.0 0. 0.0 0.0 8.-5 0.0532 00*
 * CNTL TRIP VARIABLE CODE
 5000200 3 501 TIME 0 *
 * SEARCH VAR. FLUID COND. (2 QUANTITIES)
 5000201 0. 5.2395+6 486.06 * 54K SUBCOOLING
 *
 * 'NAME' TYPE
 5010000 '84-12-15' TMDPJUN * FEED WATER
 * FROM TO AREA
 5010101 500000000 505000000 0.0 *
 * CNTL TRIP NO. VARIABLE CODE
 5010200 1 501 CNTRLVAR 574
 * SEARCH VAR. LIQUID V. VAPOR V. 0
 5010201 0. 0.0 0.0 0.0 *
 5010202 3.0 3.0 0.0 0.0 *
 *
 5050000 '84-12-15' SNGLVOL * FEED WATER INLET RING
 * AREA LENGTH VOLUME H.A. VANGLE ELEVAT. ROUGH DIAM. FE
 5050101 .000000 0.5140 .0060126 0.0 +00.000 +0.0000 8.0-5 .0532 00*
 * CONTROL PRESSURE ENERGY QUALITY
 5050200 0 6.5380+6 9.5603+5 0.0 *
 *
 5100000 '84-12-15' ANNULUS * DOWNCOMER NARROW REGION
 * VOLUMES
 5100001 11 *
 * AREA VOL.NO.
 5100101 .011950 11 *
 * J.AREA JUN.NO.
 5100201 .000000 10 *
 * LENGTH VOL.NO.
 5100301 0.8697 1 *
 5100302 0.6190 10 *
 5100303 0.5290 11 *
 * VOLUME V.NO.
 5100401 .0000000 11 *
 * H.A V.NO.
 5100501 0.0 11 *
 * VANGLE V.NO.
 5100601 -90.000 11 *
 * ELEVAT. V.NO.
 5100701 -0.8697 1 *
 5100702 -0.6190 10 *
 5100703 -0.5290 11 *
 * ROUGH. DIAM. V.NO.
 5100801 2.0-5 .0240 11 *
 * K(FORD) K(REV) J.NO.
 5100901 00.00 00.00 10 *
 * FE V.NO
 5101001 00 11 *

* CAHS J.NO.

5101101 0000 10 *

	CONTROL	PRESSURE	ENERGY/TEMP	QUALITY	VOL NO.
5101201	0	6.5427+6	1.1903+6	1.-7 0.	1 *
5101202	0	6.5477+6	1.1912+6	0. 0.	2 *
5101203	0	6.5518+6	1.1921+6	0. 0.	3 *
5101204	0	6.5559+6	1.1929+6	0. 0.	4 *
5101205	0	6.5600+6	1.1937+6	0. 0.	5 *
5101206	0	6.5641+6	1.1944+6	0. 0.	6 *
5101207	0	6.5682+6	1.1950+6	0. 0.	7 *
5101208	0	6.5722+6	1.1956+6	0. 0.	8 *
5101209	0	6.5763+6	1.1961+6	0. 0.	9 *
5101210	0	6.5804+6	1.1965+6	0. 0.	10 *
5101211	0	6.5842+6	1.1970+6	0. 0.	11 *

* CONTROL

5101300 0

* LIQUID VEL./FLOW VAPOUR VEL INTERFACE VEL. JUN NO.

	LIQUID VEL./FLOW	VAPOUR VEL	INTERFACE VEL.	JUN NO.
5101301	1.6534	1.6534	0.0	01 *
5101302	1.6541	1.6541	0.0	02 *
5101303	1.6547	1.6547	0.0	03 *
5101304	1.6553	1.6553	0.0	04 *
5101305	1.6559	1.6559	0.0	05 *
5101306	1.6565	1.6565	0.0	06 *
5101307	1.6570	1.6570	0.0	07 *
5101308	1.6574	1.6574	0.0	08 *
5101309	1.6578	1.6578	0.0	09 *
5101310	1.6581	1.6581	0.0	10 *

*

* SINGLE JUNCTION

5150000 '84-12-15' SNGLJUN *DOWNCOMER TO RISER

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT

5150101 510010000 520000000 .000000 02.00 02.00 0000 * 0.0

* C.WORD INIT L VEL INIT V VEL INTERFACE VEL

5150201 0 1.6585 1.6585 0.0

*

5200000 '84-12-15' PIPE * BOILER

* VOLUMES

5200001 15 *

* AREA VOL.NO.

	AREA	VOL.NO.
5200101	.029460	10 *
5200102	.035186	11 *
5200103	.000000	13 *
5200104	.038760	14 *
5200105	.084842	15 *

* J.AREA JUN.NO.

	J.AREA	JUN.NO.
5200201	.018000	11 *
5200202	.000000	12 *
5200203	.000000	14 *

* LENGTH VOL.NO.

	LENGTH	VOL.NO.
5200301	0.5290	1 *
5200302	0.6190	10 *
5200303	0.8697	11 *
5200304	0.4327	12 *
5200305	0.8430	13 *
5200306	0.8600	14 *
5200307	0.6710	15 *

* VOLUME V.NO.

	VOLUME	V.NO.
5200401	.0000000	11 *
5200402	.0321193	12 *

5200403 .0388078 13 *
 5200404 .0000000 15 *
 * H.A V.NO.
 5200501 0.0 15 *
 * V.ANGLE V.NO.
 5200601 +90.000 15 *
 * ROUGH. DIAM. V.NO.
 5200801 8.0-5 .0220 11 *
 5200802 8.0-5 .3010 12 *
 5200803 8.0-5 .2080 13 *
 5200804 8.0-5 .3840 14 *
 5200805 8.0-5 .1870 15 *
 * K(FORD) K(REV) J.NO.
 5200901 00.00 00.00 10 *
 5200902 10.00 10.00 11 *
 5200903 00.00 00.00 14 *
 * FE V.NO
 5201001 00 15 *
 * CAHS J.NO.
 5201101 0100 10 *
 5201102 0000 11 *
 5201103 0100 12 *
 5201104 0000 14 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 5201201 0 6.5827+6 1.2229+6 0. 0. 1 *
 5201202 0 6.5783+6 1.2445+6 5.6428-3 0. 2 *
 5201203 0 6.5740+6 1.2573+6 1.5323-2 0. 3 *
 5201204 0 6.5702+6 1.2675+6 2.3110-2 0. 4 *
 5201205 0 6.5666+6 1.2766+6 2.9969-2 0. 5 *
 5201206 0 6.5633+6 1.2850+6 3.6336-2 0. 6 *
 5201207 0 6.5600+6 1.2934+6 4.2730-2 0. 7 *
 5201208 0 6.5568+6 1.3014+6 4.8766-2 0. 8 *
 5201209 0 6.5536+6 1.3102+6 5.5392-2 0. 9 *
 5201210 0 6.5506+6 1.3367+6 7.5149-2 0. 10 *
 5201211 0 6.5465+6 1.2779+6 3.1683-2 0. 11 *
 5201212 0 6.5332+6 1.3356+6 7.4957-2 0. 12 *
 5201213 0 6.5307+6 1.2912+6 4.2206-2 0. 13 *
 5201214 0 6.5275+6 1.2934+6 4.3933-2 0. 14 *
 5201215 0 6.5245+6 1.2768+6 3.1757-2 0. 15 *
 * CONTROL
 5201300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
 5201301 0.68114 0.71749 0.0 01 *
 5201302 0.76573 0.95481 0.0 02 *
 5201303 0.89898 1.34450 0.0 03 *
 5201304 1.00240 1.66780 0.0 04 *
 5201305 1.09070 1.95450 0.0 05 *
 5201306 1.17040 2.21450 0.0 06 *
 5201307 1.24960 2.44540 0.0 07 *
 5201308 1.32230 2.66880 0.0 08 *
 5201309 1.40280 2.86540 0.0 09 *
 5201310 1.68330 2.82440 0.0 10 *
 5201311 1.66350 8.17690 0.0 11 *
 5201312 1.05440 2.09390 0.0 12 *
 5201313 0.88569 3.23600 0.0 13 *
 5201314 0.90457 3.17130 0.0 14 *

*
 5300000 '84-12-15' SEPARATR*
 * NO.J CONTROL

5300001 03 0 *

* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 5300101 .086445 0.6710 .0000000 0.0 +90.000 +0.6710 8.0-5 .0200 00*

* CONTROL PRESSURE ENERGY QUALITY

5300200 0 6.5235+6 1.6642+6 0.31833 *

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS

5301101 530010000 5600000000 .060000 00.00 00.00 0100 *

5302101 520010000 530010000 .040000 00.00 00.00 0100 *

5303101 5300000000 5400000000 .000000 00.00 00.00 0000 *

* LIQUID VEL VAPOR VEL. INTERFACE VEL

5301201 0.20739 0.71729 0.0 *

5302201 0.35357 1.73770 0.0 *

5303201 2.30790 -2.9635-3 0.0 *

*

*

5400000 '84-12-15' ANNULUS * DOWNCOMER

* VOLUMES

5400001 2 *

* AREA VOL.NO.

5400101 .115721 1 *

5400102 .091767 2 *

* J.AREA JUN.NO.

5400201 .000000 01 *

* LENGTH VOL.NO.

5400301 0.8600 1 *

5400302 0.8430 2 *

* VOLUME V.NO.

5400401 .0000000 2 *

* H.A V.NO.

5400501 0.0 2 *

* V.ANGLE V.NO.

5400601 -90.000 2 *

* ELEVAT. V.NO.

5400701 -0.8600 1 *

5400702 -0.8430 2 *

* ROUGH. DIAM. V.NO.

5400801 8.0-5 .0830 1 *

5400802 8.0-5 .1050 2 *

* K(FORD) K(REV) J.NO.

5400901 00.00 00.00 01 *

* FE V.NO

5401001 00 2 *

* CAHS J.NO.

5401101 0000 01 *

* CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.

5401201 0 6.5239+6 1.8044+6 .42201 0. 1 *

5401202 0 6.5253+6 1.2769+6 .03176 0. 2 *

* CONTROL

5401300 0

* LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.

5401301 3.2547 5.8826-4 0.0 1 *

*

5500000 '84-12-15' BRANCH *

* NO.J CONTROL

5500001 03 0 *

* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 5500101 .011950 0.4327 .0000000 0.0 -90.000 -0.4327 8.0-5 .0240 00*

* CONTROL PRESSURE ENERGY QUALITY

5500200 0 6.5380+6 1.1890+6 0.0 *

* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 5501101 505010000 550000000 .001608 00.00 00.00 0100 *
 5502101 540010000 550000000 .000000 00.00 00.00 0100 *
 5503101 550010000 510000000 .000000 00.00 00.00 0000 *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 5501201 0.21351 0.21351 0.0 *
 5502201 2.5109 -1.6108 0.0 *
 5503201 1.6524 1.6524 0.0 *
 *
 5600000 '84-12-15' BRANCH * STEAM DOME
 * NO.J CONTROL
 5600001 01 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 5600101 .000000 0.4290 .0660335 0.0 +90.000 0.4290 8.0-5 .4610 00*
 * CONTROL PRESSURE ENERGY QUALITY
 5600200 0 6.5230+6 2.5856+6 1.0 *
 *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 5601101 560010000 700000000 .000000 00.00 00.00 0100 *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 5601201 16.628 16.628 0.0 *
 *
 *SG1 SEC STRUCTURES
 *

 *STEAM GENERATOR(SECONDARY SIDE)_FEED WATER INLET

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15000000 1 7 2 1 0.0350 *
 * FLAG FLAG
 15000100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 15000101 6 0.045 *
 * COMPOSITION NO. INTERVAL NO.
 15000201 5 6 *
 * SOURCE VALUE INTERVAL NO.
 15000301 0.0 6 *
 * TEMP POINT NO
 15000401 532.05 7 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15000501 505010000 0 1 1 10.104 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15000601 550010000 0 1 1 10.104 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15000701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15000801 0 0.0532 0 10.104 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15000901 0 0.024 0 10.104 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER NARROW REGION_OUTER WALL

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15100000 11 10 2 1 0.16450 *
 * FLAG FLAG
 15100100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 15100101 4 0.187832 *

15100102 5 0.217832 *
 * COMPOSITION NO. INTERVAL NO.
 15100201 5 4 *
 15100202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 15100301 0.0 9 *
 * TEMP POINT NO
 15100401 468.50 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15100501 510010000 0 1 1 0.8697 1 *
 15100502 510020000 10000 1 1 0.6190 10 *
 15100503 510110000 0 1 1 0.5290 11 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15100601 -919 0 3969 1 0.8697 1 *
 15100602 -919 0 3969 1 0.6190 10 *
 15100603 -919 0 3969 1 0.5290 11 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15100701 0 0 0 0 11 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15100801 0 0.0240 0.0 0.0 11 *
 *

 ***** TUBE WRAPPER *****

 * NH NP TYPE FLAG LEFT BOUNDARY
 15150000 12 3 2 1 0.1505 *
 * FLAG FLAG
 15150100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 15150101 2 0.1525 *
 * COMPOS. NO INTERV. NO
 15150201 5 2 *
 * SOURCE INTERV. NO
 15150301 0.0 2 *
 * TEMP. , POINT NO OR TEMPS.
 15150401 549. 3 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 15150501 520010000 0000 1 1 0.529 1
 15150502 520020000 10000 1 1 0.619 10
 15150503 520110000 0000 1 1 0.8697 11
 15150504 520120000 0000 1 1 0.4327 12
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 15150601 510110000 0000 1 1 0.529 1
 15150602 510100000 -10000 1 1 0.619 10
 15150603 510010000 0000 1 1 0.8697 11
 15150604 550010000 0000 1 1 0.4327 12
 * SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO
 15150701 0. 0. 0. 0. 12
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 15150801 0 0.022 0. 0. 12
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 15150901 0 0.024 0. 0. 12
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ FILLER TUBE

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15200000 11 4 2 1 0.07615 *
 * FLAG FLAG

15200100 0 1 *
* NO INTERVAL RIGHT COORDINATE
15200101 3 0.08415 *
* COMPOSITION NO. INTERVAL NO.
15200201 5 3 *
* SOURCE VALUE INTERVAL NO.
15200301 0.0 3 *
* TEMP POINT NO
15200401 554.50 4 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
15200501 0 0 0 1 0.5290 1 *
15200502 0 0 0 1 0.6190 10 *
15200503 0 0 0 1 0.6200 11 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
15200601 520010000 0 1 1 0.5290 1 *
15200602 520020000 10000 1 1 0.6190 10 *
15200603 520110000 0 1 1 0.6200 11 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
15200701 0 0 0 0 0 11 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
15200901 0 0.022 0 0.5290 1 *
15200902 0 0.022 0 0.6190 10 *
15200903 0 0.022 0 0.6200 11 *
*
***** RISER TOP VOLUME OUTER WALL *****

* NH NP TYPE FLAG LEFT BOUNDARY
15201000 1 10 2 1 0.2335 *
* FLAG FLAG
15201100 0 1 *
* NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
15201101 6 0.2625 *
15201102 3 0.2925 *
* COMPOS. NO INTERV. NO
15201201 5 6 *
15201202 9 9 *
* SOURCE INTERV. NO
15201301 0.0 9 *
* TEMP. POINT NO OR TEMPS.
15201401 482.71 10 *
* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
15201501 520150000 0 1 1 0.671 1 *
* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
15201601 -919 0 3969 1 0.671 1 *
* SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO
15201701 0. 0. 0. 0. 0. 1 *
* CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
15201801 0 0.187 0. 0. 0. 1 *
*

*STEAM GENERATOR (SECONDARY SIDE)_ COARSE SEPERATOR

* NH NP G.TYPE FLAG LEFT BOUNDARY
15202000 2 3 2 1 0.114 *
* FLAG FLAG
15202100 0 1 *
* NO INTERVAL RIGHT COORDINATE
15202101 2 0.115 *

* COMPOSITION NO. INTERVAL NO.
 15202201 5 2 *
 * SOURCE VALUE INTERVAL NO.
 15202301 0.0 2 *
 * TEMP POINT NO
 15202401 554.26 3 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15202501 520140000 0 1 1 3.8450 1 *
 15202502 520130000 0 1 1 1.9230 2 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15202601 540010000 0 1 1 3.8450 1 * I
 15202602 540020000 0 1 1 1.9230 2 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15202701 0 0 0 0 0 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15202801 0 0.384 0 3.8450 1 *
 15202802 0 0.208 0 1.9230 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15202901 0 0.083 0 3.8450 1 *
 15202902 0 0.105 0 1.9230 2 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ FINE SEPERATOR

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15203000 1 3 1 1 0.0 *
 * FLAG FLAG
 15203100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 15203101 2 0.001 *
 * COMPOSITION NO. INTERVAL NO.
 15203201 5 2 *
 * SOURCE VALUE INTERVAL NO.
 15203301 0.0 2 *
 * TEMP POINT NO
 15203401 554.21 3 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15203501 520150000 0 1 1 3.4 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15203601 530010000 0 1 1 3.4 1 * I
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15203701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15203801 0 0.187 0 0.3 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15203901 0 0.020 0 0.3 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ TUBE SHEET1(ADJACENT TO INLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15204000 1 5 2 1 0.0098 *
 * FLAG FLAG
 15204100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 15204101 4 0.0218 *
 * COMPOSITION NO. INTERVAL NO.
 15204201 5 4 *
 * SOURCE VALUE INTERVAL NO.

15204301 0.0 4 *

* TEMP POINT NO

15204401 568.45 5 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

15204501 230050000 0 1 1 2.16 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

15204601 520110000 0 1 1 2.16 1 * I

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO

15204701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

15204801 0 0.156 0 2.16 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

15204901 0 0.022 0 2.16 1 *

*

*STEAM GENERATOR(SECONDARY SIDE)_TUBE SHEET2(ADJACENT TO OUTLET CHAMBER)

* NH NP G.TYPE FLAG LEFT BOUNDARY

15205000 1 5 2 1 0.0098 *

* FLAG FLAG

15205100 0 1 *

* NO INTERVAL RIGHT COORDINATE

15205101 4 0.0218 *

* COMPOSITION NO. INTERVAL NO.

15205201 5 4 *

* SOURCE VALUE INTERVAL NO.

15205301 0.0 4 *

* TEMP POINT NO

15205401 558.49 5 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

15205501 230280000 0 1 1 2.16 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

15205601 520110000 0 1 1 2.16 1 * I

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO

15205701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

15205801 0 0.156 0 2.16 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

15205901 0 0.022 0 2.16 1 *

*

*STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER (VOLUME 54001)_OUTER WALL

* NH NP G.TYPE FLAG LEFT BOUNDARY

15400000 1 10 2 1 0.2335 *

* FLAG FLAG

15400100 0 1 *

* NO INTERVAL RIGHT COORDINATE

15400101 6 0.2640 *

15400102 3 0.2940 *

* COMPOSITION NO. INTERVAL NO.

15400201 5 6 *

15400202 9 9 *

* SOURCE VALUE INTERVAL NO.

15400301 0.0 9 *

* TEMP POINT NO

15400401 484.15 10 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO

15400501 540010000 0 1 1 0.8600 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15400601 -919 0 3969 1 0.8600 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15400701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15400801 0 0.0830 0.0 0.0 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER (VOLUME 54002)_OUTER WALL

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15401000 1 10 2 1 0.2050 *
 * FLAG FLAG
 15401100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 15401101 6 0.2326 *
 15401102 3 0.2626 *
 * COMPOSITION NO. INTERVAL NO.
 15401201 5 6 *
 15401202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 15401301 0.0 9 *
 * TEMP POINT NO
 15401401 479.97 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15401501 540020000 0 1 1 0.8430 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15401601 -919 0 3969 1 0.8430 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15401701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15401801 0 0.1050 0.0 0.0 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER NARROW REGION _OUTER WALL

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 15500000 01 10 2 1 0.16450 *
 * FLAG FLAG
 15500100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 15500101 4 0.187832 *
 15500102 5 0.217832 *
 * COMPOSITION NO. INTERVAL NO.
 15500201 5 4 *
 15500202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 15500301 0.0 9 *
 * TEMP POINT NO
 15500401 468.11 10 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15500501 550010000 0 1 1 0.4327 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 15500601 -919 0 3969 1 0.4327 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 15500701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 15500801 0 0.0240 0.0 0.0 1 *
 *

*STEAM GENERATOR (SECONDARY SIDE)_ STEAM DOME_OUTER WALL

* NH NP G.TYPE FLAG LEFT BOUNDARY
15600000 1 10 2 1 0.2305 *

* FLAG FLAG
15600100 0 1 *

* NO INTERVAL RIGHT COORDINATE
15600101 5 0.2640 *
15600102 4 0.2940 *

* COMPOSITION NO. INTERVAL NO.
15600201 5 5 *
15600202 9 9 *

* SOURCE VALUE INTERVAL NO.
15600301 0.0 9 *

* TEMP POINT NO
15600401 468.93 10 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
15600501 560010000 0 1 1 0.4290 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
15600601 -919 0 3969 1 0.4290 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
15600701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
15600801 0 0.4610 0.0 0.0 1 *

*

* NH NP G.TYPE FLAG LEFT BOUNDARY
15601000 1 10 1 1 0.0 *

* FLAG FLAG
15601100 0 1 *

* NO INTERVAL RIGHT COORDINATE
15601101 5 0.0320 *
15601102 4 0.0620 *

* COMPOSITION NO. INTERVAL NO.
15601201 5 5 *
15601202 9 9 *

* SOURCE VALUE INTERVAL NO.
15601301 0.0 9 *

* TEMP POINT NO
15601401 491.79 10 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
15601501 560010000 0 1 1 0.202841 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
15601601 -919 0 3969 1 0.202841 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
15601701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
15601801 0 0.4610 0.0 0.0 1 *

*

*

*STEAM GENERATOR II

*

*

*SG2 CONTROL VARIABLES

*

20560000 DUMMY SUM 1. 0. 1
20560001 0. 1. CPUTIME 0

*

* LIQUID MASS INVENTORY

*

20560100	F	MULT	0.0018612	0	1*F.W INLET RING (60001)
20560200	D	MULT	0.0022861	0	1*DOWNCOMER (61001)
20560300	D	MULT	0.0024592	0	1*DOWNCOMER (61002)
20560400	D	MULT	0.0024592	0	1*DOWNCOMER (61003)
20560500	D	MULT	0.0024592	0	1*DOWNCOMER (61004)
20560600	D	MULT	0.0024592	0	1*DOWNCOMER (61005)
20560700	D	MULT	0.0024592	0	1*DOWNCOMER (61006)
20560800	D	MULT	0.0024592	0	1*DOWNCOMER (61007)
20560900	D	MULT	0.0024592	0	1*DOWNCOMER (61008)
20561000	D	MULT	0.0024592	0	1*DOWNCOMER (61009)
20561100	D	MULT	0.0024592	0	1*DOWNCOMER (61010)
20561200	D	MULT	0.0022196	0	1*DOWNCOMER (61011)
20561300	D	MULT	0.0022861	0	1*DOWNCOMER (65001)
20561400	R	MULT	0.0052485	0	1*RISER/BOILER (62001)
20561500	R	MULT	0.0058150	0	1*RISER/BOILER (62002)
20561600	R	MULT	0.0058150	0	1*RISER/BOILER (62003)
20561700	R	MULT	0.0058150	0	1*RISER/BOILER (62004)
20561800	R	MULT	0.0058150	0	1*RISER/BOILER (62005)
20561900	R	MULT	0.0058150	0	1*RISER/BOILER (62006)
20562000	R	MULT	0.0058150	0	1*RISER/BOILER (62007)
20562100	R	MULT	0.0058150	0	1*RISER/BOILER (62008)
20562200	R	MULT	0.0058150	0	1*RISER/BOILER (62009)
20562300	R	MULT	0.0058150	0	1*RISER/BOILER (62010)
20562400	R	MULT	0.0108557	0	1*RISER/BOILER (62011)
20562500	R	MULT	0.0108557	0	1*RISER/BOILER (62012)
20562600	R	MULT	0.0106890	0	1*RISER/BOILER (62013)
20562700	R	MULT	0.0133332	0	1*RISER/BOILER (62014)
20562800	R	MULT	0.0298122	0	1*RISER/BOILER (62015)
20562900	S	MULT	0.0248491	0	1*SEPERATOR (63001)
20563000	D	MULT	0.0303994	0	1*DOWNCOMER (64001)
20563100	D	MULT	0.0206243	0	1*DOWNCOMER (64002)
20563200	M1	SUM	1.0	0	1* MASS INVENTORY
20563300	M2	SUM	1.0	0	1* MASS INVENTORY
20563400	INVENT2	SUM	1.0	0	1*TOTAL MASS INVENTORY

*

20563500	CL83BN	SUM	1.000	0	1* STEAM GEN. SEC. SIDE
----------	--------	-----	-------	---	-------------------------

*

20560101	RHOF	605010000	VOIDF	605010000
20560201	RHOF	610010000	VOIDF	610010000
20560301	RHOF	610020000	VOIDF	610020000
20560401	RHOF	610030000	VOIDF	610030000
20560501	RHOF	610040000	VOIDF	610040000
20560601	RHOF	610050000	VOIDF	610050000
20560701	RHOF	610060000	VOIDF	610060000
20560801	RHOF	610070000	VOIDF	610070000
20560901	RHOF	610080000	VOIDF	610080000
20561001	RHOF	610090000	VOIDF	610090000
20561101	RHOF	610100000	VOIDF	610100000
20561201	RHOF	610110000	VOIDF	610110000
20561301	RHOF	650010000	VOIDF	650010000

*

* EXIT POWER (MW), ENERGY (MJ)

20563600	DELTAU	SUM	1.	0.	1
20563601	0.	1.	U	660010000	-1. U 600010000
20563700	POWSGII	MULT	1.-6	0.	1
20563701	CNTRLVAR	636	MFLOWJ	660010000	
20563800	HWSGII	INTEGRAL	1.0	0.	1
20563801	CNTRLVAR	637			

*

20561401	RHOF	620010000	VOIDF	620010000
20561501	RHOF	620020000	VOIDF	620020000
20561601	RHOF	620030000	VOIDF	620030000
20561701	RHOF	620040000	VOIDF	620040000
20561801	RHOF	620050000	VOIDF	620050000
20561901	RHOF	620060000	VOIDF	620060000
20562001	RHOF	620070000	VOIDF	620070000
20562101	RHOF	620080000	VOIDF	620080000
20562201	RHOF	620090000	VOIDF	620090000
20562301	RHOF	620100000	VOIDF	620100000
20562401	RHOF	620110000	VOIDF	620110000
20562501	RHOF	620120000	VOIDF	620120000
20562601	RHOF	620130000	VOIDF	620130000
20562701	RHOF	620140000	VOIDF	620140000
20562801	RHOF	620150000	VOIDF	620150000

20562901	RHOF	630010000	VOIDF	630010000
----------	------	-----------	-------	-----------

20563001	RHOF	640010000	VOIDF	640010000
20563101	RHOF	640020000	VOIDF	640020000

20563201	0.	1.0	CNTRLVAR 601	1.0	CNTRLVAR 602
+		1.0	CNTRLVAR 603	1.0	CNTRLVAR 604
+		1.0	CNTRLVAR 605	1.0	CNTRLVAR 606
+		1.0	CNTRLVAR 607	1.0	CNTRLVAR 608
+		1.0	CNTRLVAR 609	1.0	CNTRLVAR 610
+		1.0	CNTRLVAR 611	1.0	CNTRLVAR 612
+		1.0	CNTRLVAR 613	1.0	CNTRLVAR 614
+		1.0	CNTRLVAR 615	1.0	CNTRLVAR 616
+		1.0	CNTRLVAR 617	1.0	CNTRLVAR 618
20563301	0.	1.0	CNTRLVAR 619	1.0	CNTRLVAR 620
+		1.0	CNTRLVAR 621	1.0	CNTRLVAR 622
+		1.0	CNTRLVAR 623	1.0	CNTRLVAR 624
+		1.0	CNTRLVAR 625	1.0	CNTRLVAR 626
+		1.0	CNTRLVAR 627	1.0	CNTRLVAR 628
+		1.0	CNTRLVAR 629	1.0	CNTRLVAR 630
+		1.0	CNTRLVAR 631		
20563401	0.	1.0	CNTRLVAR 632	1.0	CNTRLVAR 633

*

*	A0	LENGTH	VAR.	CODE	LENGTH	VAR.	CODE
20563501	0.0	0.9254	VOIDF	640010000	0.8006	VOIDF	640020000
+		0.5773	VOIDF	610010000	0.6210	VOIDF	610020000
+		0.6210	VOIDF	610030000	0.6210	VOIDF	610040000
+		0.6210	VOIDF	610050000	0.6210	VOIDF	610060000
+		0.6210	VOIDF	610070000	0.6210	VOIDF	610080000
+		0.6210	VOIDF	610090000	0.6210	VOIDF	610100000
+		0.5605	VOIDF	610110000	0.5773	VOIDF	650010000
+		0.9550	VOIDF	620150000			

*

* PRESSURE DROPS

*

20564300	DNCOMBS	SUM	1.-6	0	1*	B & S (DOWNCOMER)
20564400	DNCOMRS	SUM	1.-6	0	1*	R & S (DOWNCOMER)
20564500	DNCSDOM	SUM	1.-6	0	1*	S & T
20564600	PD83FB	SUM	1.-6	0	1*	PD83FB76
20564700	PD85BF	SUM	1.-6	0	1*	PD85BF62

*

20564301 0.0 0.5 P 610110000 1.5512 RHO 610110000
+ 0.5 P 620010000 1.5512 RHO 620010000
+ -1.0 P 640010000 3.9407 RHO 640010000
20564401 0.0 1.0 P 640020000 2.3083 RHO 640020000
+ -1.0 P 640010000 3.9407 RHO 640010000
20564501 0.0 1.0 P 640010000 -3.9407 RHO 640010000
+ -1.0 P 660010000 -0.5101 RHO 660010000
20564601 0.0 1.0 P 610090000 -2.3544 RHO 610090000
+ -0.5 P 610110000 -1.5512 RHO 610110000
+ -0.5 P 620010000 -1.5512 RHO 620010000
20564701 0.0 0.5 P 610110000 1.5512 RHO 610110000
+ 0.5 P 620010000 1.5512 RHO 620010000
+ -1.0 P 620030000 -2.3544 RHO 620030000
*

* HEAT LOSSES

*
20566300 LOSS-S2 SUM 1.-3 0. 1*HEAT LOSS IN S.G
20566301 0 0.55370 HTRNR 650000101
+ 0.55370 HTRNR 610000101 0.59562 HTRNR 610000201
+ 0.59562 HTRNR 610000301 0.59562 HTRNR 610000401
+ 0.59562 HTRNR 610000501 0.59562 HTRNR 610000601
+ 0.59562 HTRNR 610000701 0.59562 HTRNR 610000801
+ 0.59562 HTRNR 610000901 0.59562 HTRNR 610001001
+ 0.53759 HTRNR 610001101
+ 1.0089 HTRNR 640000101
+ 0.78906 HTRNR 640100101
+ 1.0921 HTRNR 620100101
+ 0.25839 HTRNR 660000101
+ 0.070910 HTRNR 660100101
*

*SG2 CONTROLLER

*
*STEAM FLOW CONTROLLER
*
20565100 DELTA-T SUM 1.0 0.0 1
20565101 652.00 -1.-4 P 660010000
*0565101 566.46 -1.0 TEMP 395030000
*
20565200 DEADBAND FUNCTION 1.0 0.0 1
20565201 CNTRLVAR 651 609
*
20565300 INTDELT INTEGRAL 1.0 0.0 1
20565301 CNTRLVAR 652
*
*0565400 TCONTROL SUM 1.0 0.0362 0 3 0.0 1.0 *.0362
*0565401 0.0362 -0.00469 CNTRLVAR 652 *.0362
*0565402 -0.00047 CNTRLVAR 653
20565400 STEMPOS SUM 1. 0.0666 0 3 0. 1. *.0.0666
20565401 0.0666 -.0144 CNTRLVAR 652 -.0015 CNTRLVAR 653 *.0.0666
*

*LIQUID LEVEL CONTROLLER

*
20566400 SGLVLERR SUM 1.0 0.0 1
20566401 9.10 -1.0 CNTRLVAR 635
*
20566500 FEEDMULT FUNCTION 1.0 0.0 1
20566501 CNTRLVAR 664 604
*
20566600 FEEDFLOW MULT 1.0 0.72 0

20566601 CNTRLVAR 665 MFLOWJ 660010000 CNTRLVAR 667
 20566700 CLOSE FUNCTION 1.0 1.0 0 *
 20566701 CNTRLVAR 668 576
 20566800 ARGUM MULT 1.0 0.0 0
 20566801 CNTRLVAR 670 CNTRLVAR 671
 20566900 TRIP TRIPDLAY 1.0 0.0 1
 20566901 506
 20567000 ARGUM SUM 1.0 0.0 1
 20567001 0. 1. TIME 0 -1. CNTRLVAR 669
 20567100 ONOFF TRIPUNIT 1.0 0.0 1
 20567101 506

* QUANTITIES TO BE PREDICTED

*

 20567200 TF85B SUM 1. 0. 1
 20567201 -273.15 1. TEMP 620010000
 20567300 TF95K SUM 1. 0. 1
 20567301 -273.15 1. TEMP 620110000
 20567400 TF87T SUM 1. 0. 1
 20567401 -273.15 1. TEMP 660010000
 20567500 CM83G SUM 1. 0. 1
 20567501 0. 1. MFLOWJ 610070000
 20567600 CM66 SUM 1. 0. 1
 20567601 0. 1. MFLOWJ 660010000

*

 *

 *SGII VOLUMES

 *

 * 'NAME' TYPE

 6000000 '5-09-84' TMDPVOL * FEED WATER INLET

 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE

 6000101 0.002788 0.6676 0.0 0. 0.0 0.0 2.0-5 0.0350 00*

 * CNTL TRIP VARIABLE CODE

 6000200 0 501 TIME 0 *

 * SEARCH VAR. PRESSU ENERGY QUALITY

 6000201 0. 6.0000+6 9.0559+5 0. *

 *

 * 'NAME' TYPE

 6010000 '05-09-84' TMDPJUN * FEED WATER

 * FROM TO AREA

 6010101 600000000 605000000 0.0 *

 * CNTL TRIP NO. VARIABLE CODE

 6010200 1 501 CNTRLVAR 666 *

 * SEARCH VAR. LIQUID V. VAPOR V. 0

 6010201 0. 0.0 0.0 0.0

 6010202 1.5 1.5 0.0 0.0

 *

 6050000 '05-09-84' SNGLVOL * FEED WATER INLET RING

 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE

 6050101 .000000 0.6676 .0018612 0.0 +00.000 +0.0000 2.0-5 .0350 00*

 * CONTROL PRESSURE ENERGY QUALITY

 6050200 0 6.5331+6 9.7572+5 0.0 *

 *

 6100000 '05-09-84' ANNULUS * DOWNCOMER NARROW REGION

 * VOLUMES

 6100001 11 *

 * AREA VOL.NO.

 6100101 .003960 11 *

 * J.AREA JUN.NO.

 6100201 .000000 10 *

* LENGTH VOL.NO.
 6100301 0.5773 1 *
 6100302 0.6210 10 *
 6100303 0.5605 11 *
 * VOLUME V.NO.
 6100401 .0000000 11 *
 * H.A V.NO.
 6100501 0.0 11 *
 * V.ANGLE V.NO.
 6100601 -90.000 11 *
 * ELEVAT. V.NO.
 6100701 -0.5773 1 *
 6100702 -0.6210 10 *
 6100703 -0.5605 11 *
 * ROUGH. DIAM. V.NO.
 6100801 2.0-5 .0120 11 *
 * K(FORD) K(REV) J.NO.
 6100901 00.00 00.00 10 *
 * FE V.NO
 6101001 00 11 *
 * CAHS J.NO.
 6101101 0000 10 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 6101201 0 6.5375+6 1.1904+6 0. 0. 1 *
 6101202 0 6.5410+6 1.1924+6 0. 0. 2 *
 6101203 0 6.5445+6 1.1943+6 0. 0. 3 *
 6101204 0 6.5480+6 1.1961+6 0. 0. 4 *
 6101205 0 6.5516+6 1.1977+6 0. 0. 5 *
 6101206 0 6.5551+6 1.1992+6 0. 0. 6 *
 6101207 0 6.5586+6 1.2005+6 0. 0. 7 *
 6101208 0 6.5621+6 1.2016+6 0. 0. 8 *
 6101209 0 6.5656+6 1.2026+6 0. 0. 9 *
 6101210 0 6.5691+6 1.2034+6 0. 0. 10 *
 6101211 0 6.5725+6 1.2045+6 0. 0. 11 *
 * CONTROL
 6101300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
 6101301 1.5385 1.5385 0. 1 *
 6101302 1.5400 1.5400 0. 2 *
 6101303 1.5414 1.5414 0. 3 *
 6101304 1.5426 1.5426 0. 4 *
 6101305 1.5438 1.5438 0. 5 *
 6101306 1.5449 1.5449 0. 6 *
 6101307 1.5458 1.5458 0. 7 *
 6101308 1.5467 1.5467 0. 8 *
 6101309 1.5474 1.5474 0. 9 *
 6101310 1.5479 1.5479 0. 10 *
 *
 * SINGLE JUNCTION
 6150000 '05-09-84' SNGLJUN *DOWNCOMER TO RISER
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 6150101 610010000 620000000 .000000 05.00 05.00 0000 * 4.0
 * C.WORD INIT L VEL INIT V VEL INTERFACE VEL (4.20,4.20)
 6150201 0 1.5487 1.5487 0.0 *
 *
 6200000 '05-09-84' PIPE * BOILER
 * VOLUMES
 6200001 15 *
 * AREA VOL.NO.

6200101 .0093640 10 *
 6200102 .0188043 12 *
 6200103 .0133512 13 *
 6200104 .0144080 14 *
 6200105 .0312170 15 *
 * J. AREA JUN. NO.
 6200201 .008000 11 *
 6200202 .000000 12 *
 6200203 .014408 14 *
 * LENGTH VOL.NO.
 6200301 0.5605 1 *
 6200302 0.6210 10 *
 6200303 0.5773 12 *
 6200304 0.8006 13 *
 6200305 0.9254 14 *
 6200306 0.9550 15 *
 * VOLUME V.NO.
 6200401 .0000000 15 *
 * H.A V.NO.
 6200501 0.0 15 *
 * V. ANGLE V.NO.
 6200601 +90.000 15 *
 * ROUGH. DIAM. V.NO.
 6200801 2.0-5 .0220 12 *
 6200802 2.0-5 .1280 13 *
 6200803 2.0-5 .2050 14 *
 6200804 2.0-5 .1200 15 *
 * K(FORD) K(REV) J.NO.
 6200901 00.00 00.00 14 *
 * FE V.NO
 6201001 00 15 *
 * CAHS J.NO.
 6201101 0000 11 *
 6201102 0100 12 *
 6201103 0000 14 *
 * CONTROL PRESSURE ENERGY QUALITY VOL NO.
 6201201 0 6.5681+6 1.2301+6 0. 0. 1 *
 6201202 0 6.5641+6 1.2485+6 9.18-3 0. 2 *
 6201203 0 6.5603+6 1.2595+6 1.75-2 0. 3 *
 6201204 0 6.5568+6 1.2695+6 2.51-2 0. 4 *
 6201205 0 6.5536+6 1.2772+6 3.09-2 0. 5 *
 6201206 0 6.5506+6 1.2839+6 3.60-2 0. 6 *
 6201207 0 6.5476+6 1.2892+6 4.00-2 0. 7 *
 6201208 0 6.5447+6 1.2944+6 4.40-2 0. 8 *
 6201209 0 6.5419+6 1.3002+6 4.84-2 0. 9 *
 6201210 0 6.5392+6 1.3136+6 5.84-2 0. 10 *
 6201211 0 6.5369+6 1.2927+6 4.31-2 0. 11 *
 6201212 0 6.5349+6 1.3379+6 7.66-2 0. 12 *
 6201213 0 6.5323+6 1.2989+6 4.78-2 0. 13 *
 6201214 0 6.5291+6 1.2911+6 4.22-2 0. 14 *
 6201215 0 6.5253+6 1.2763+6 3.14-2 0. 15 *
 * CONTROL
 6201300 0
 * LIQUID VEL VAPOUR VEL INTE. VEL. JUN NO.
 6201301 0.77618 0.84912 0.0 1 *
 6201302 0.92592 1.2529 0.0 2 *
 6201303 1.05380 1.7128 0.0 3 *
 6201304 1.16750 2.0506 0.0 4 *
 6201305 1.24970 2.4014 0.0 5 *

6201306	1.31920	2.7255	0.0	6	*
6201307	1.36870	3.0554	0.0	7	*
6201308	1.41640	3.3557	0.0	8	*
6201309	1.46960	3.6182	0.0	9	*
6201310	1.61820	3.6865	0.0	10	*
6201311	1.33400	4.8920	0.0	11	*
6201312	1.33390	2.2615	0.0	12	*
6201313	0.78444	2.5778	0.0	13	*
6201314	0.74125	2.7428	0.0	14	*

*

6300000 '05-09-84' SEPARATR*

* NO.J CONTROL

6300001	03	0 *
* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE		
6300101	.026020	0.9550 .0000000 0.0 +90.000 +0.9550 2.0-5 .0100 00*
* CONTROL PRESSURE ENERGY QUALITY		
6300200	0	6.5236+6 1.6699+6 0.32253 *
* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS		
6301101	630010000	660000000 .020000 00.00 00.00 0100 *
6302101	620010000	630010000 .013000 00.00 00.00 0100 *
6303101	630000000	640000000 .000000 00.00 00.00 0000 *
* LIQUID VEL VAPOR VEL. INTERFACE VEL		
6301201	-0.77395	0.75293 0.0 *
6302201	0.35417	1.79930 0.0 *
6303201	2.35840	1.6676-3 0.0 *

*

*

6400000 '05-09-84' ANNULUS * DOWNCOMER

* VOLUMES

6400001	2 *	
* AREA VOL.NO.		
6400101	.032850	1 *
6400102	.025761	2 *
* J.AREA JUN.NO.		
6400201	.000000	01 *
* LENGTH VOL.NO.		
6400301	0.9254	1 *
6400302	0.8006	2 *
* VOLUME V.NO.		
6400401	.0000000	2 *
* H.A V.NO.		
6400501	0.0	2 *
* V.ANGLE V.NO.		
6400601	-90.000	2 *
* ELEVAT. V.NO.		
6400701	-0.9254	1 *
6400702	-0.8006	2 *
* ROUGH. DIAM. V.NO.		
6400801	2.0-5 .0650	1 *
6400802	2.0-5 .0350	2 *
* K(FORD) K(REV) J.NO.		
6400901	00.00 00.00	01 *
* FE V.NO		
6401001	00	2 *
* CAHS J.NO.		
6401101	0000 01	*
* CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.		
6401201	0	6.5251+6 1.3019+6 5.03-2 0. 01 *
6401202	0	6.5305+6 1.2338+6 0. 0. 02 *

* CONTROL
 6401300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL JUN NO.
 6401301 0.45005 -2.11600 0.0 1 *
 *
 6500000 '05-09-84' BRANCH *
 * NO.J CONTROL
 6500001 03 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 6500101 .003960 0.5773 .0000000 0.0 -90.000 -0.5773 2.0-5 .0120 00*
 * CONTROL PRESSURE ENERGY QUALITY
 6500200 0 6.5343+6 1.1888+6 0. *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 6501101 605010000 650000000 .000664 00.00 00.00 0100 *
 6502101 640010000 650000000 .000000 00.00 00.00 0100 *
 6503101 650010000 610000000 .000000 00.00 00.00 0000 *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 6501201 0.28534 0.28534 0.0 *
 6502201 1.34740 1.34740 0.0 *
 6503201 1.53740 1.53740 0.0 *
 *
 6600000 '05-09-84' BRANCH * STEAM DOME
 * NO.J CONTROL
 6600001 01 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 6600101 .000000 0.2300 .0121690 0.0 +90.000 0.2300 2.0-5 .2640 00*
 * CONTROL PRESSURE ENERGY QUALITY
 6600200 0 6.5232+6 2.5857+6 1.0 *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 6601101 660010000 710000000 .000000 00.00 00.00 0100 *
 * LIQUID VEL VAPOR VEL. INTERFACE VEL
 6601201 14.318 14.318 0.0 *
 *
 *

 *STEAM GENERATOR(SECONDARY SIDE)_FEED WATER INLET

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16000000 1 7 2 1 0.024 *
 * FLAG FLAG
 16000100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16000101 6 0.031 *
 * COMPOSITION NO. INTERVAL NO.
 16000201 5 6 *
 * SOURCE VALUE INTERVAL NO.
 16000301 0.0 6 *
 16000400 -1
 * TEMP POINT NO
 16000401 521.46 525.35 529.06 532.59 535.96 539.20 542.29
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16000501 605010000 0 1 1 5.255 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16000601 650010000 0 1 1 5.255 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16000701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16000801 0 0.035 0 5.255 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.

16000901 0 0.012 0 5.255 1 *

*

*STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER NARROW REGION_OUTER WALL

* NH NP G.TYPE FLAG LEFT BOUNDARY

16100000 11 10 2 1 0.108 *

* FLAG FLAG

16100100 0 1 *

* NO INTERVAL RIGHT COORDINATE

16100101 4 0.12265 *

16100102 5 0.15265 *

* COMPOSITION NO. INTERVAL NO.

16100201 5 4 *

16100202 9 9 *

* SOURCE VALUE INTERVAL NO.

16100301 0.0 9 *

16100400 -1

* TEMP POINT NO

	16100401	545.80	545.65	545.50	545.36	545.23	491.49	440.24
+		391.28	344.41	299.45				
16100402		546.20	546.05	545.91	545.77	545.63	491.80	440.47
+		391.43	344.49	299.45				
16100403		546.58	546.43	546.28	546.14	546.00	492.10	440.69
+		391.57	344.56	299.46				
16100404		546.92	546.77	546.63	546.49	546.35	492.37	440.89
+		391.71	344.63	299.46				
16100405		547.24	547.09	546.95	546.80	546.67	492.62	441.07
+		391.83	344.69	299.47				
16100406		547.53	547.38	547.23	547.09	546.95	492.84	441.24
+		391.94	344.75	299.47				
16100407		547.79	546.64	547.49	547.35	547.21	493.05	441.39
+		392.04	344.80	299.48				
16100408		548.01	547.86	547.72	547.58	547.44	493.22	441.52
+		392.12	344.84	299.48				
16100409		548.21	548.06	547.91	547.77	547.63	493.37	441.63
+		392.20	344.88	299.49				
16100410		548.35	548.20	548.06	547.91	547.78	493.49	441.71
+		392.25	344.91	299.49				
16100411		548.57	548.42	548.27	548.13	547.99	493.66	441.84
+		392.34	344.95	299.49				
*		BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO						
16100501		610010000 0 1 1 0.5773 1 *						
16100502		610020000 10000 1 1 0.6210 10 *						
16100503		610110000 0 1 1 0.5605 11 *						
*		BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO						
16100601		-919 0 3979 1 0.5773 1 *						
16100602		-919 0 3979 1 0.6210 10 *						
16100603		-919 0 3979 1 0.5605 11 *						
*		SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO						
16100701		0 0 0 0 0 11 *						
*		CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.						
16100801		0 0.0120 0.0 0.0 11 *						
*		*****						
*		TUBE WRAPPER						
*		*****						
*		NH NP TYPE FLAG LEFT BOUNDARY						
16150000	13 3 2 1 0.1005 *							
*		FLAG FLAG						

16150100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 16150101 2 0.102 *
 * COMPOS. NO INTERVAL NO
 16150201 5 2 *
 * SOURCE INTERVAL NO
 16150301 0.0 2 *
 16150400 -1
 * TEMP. , POINT NO OR TEMPS.
 16150401 551.12 550.47 549.83 *
 16150402 549.99 549.58 549.18 *
 16150403 550.30 549.77 549.25 *
 16150404 550.47 549.85 549.23 *
 16150405 550.54 549.85 549.15 *
 16150406 550.59 549.81 549.04 *
 16150407 550.60 549.74 548.90 *
 16150408 550.58 549.65 548.73 *
 16150409 550.53 549.53 548.53 *
 16150410 550.41 549.34 548.28 *
 16150411 549.22 548.35 547.49 *
 16150412 549.05 548.15 547.26 *
 16150413 554.36 554.38 554.40 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 16150501 620010000 0000 1 1 0.5605 1
 16150502 620020000 10000 1 1 0.6210 10
 16150503 620110000 0000 1 1 0.5773 12
 16150504 620130000 0000 1 1 0.2010 13
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 16150601 610110000 0000 1 1 0.5605 1
 16150602 610100000 -10000 1 1 0.6210 10
 16150603 610010000 0000 1 1 0.5773 11
 16150604 650010000 0000 1 1 0.5773 12
 16150605 620020000 0000 1 1 0.2010 13
 * SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO
 16150701 0. 0. 0. 0. 0. 13
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 16150801 0 0.022 0. 0. 0. 13
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 16150901 0 0.024 0. 0. 0. 13
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ FILLER TUBE

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16200000 11 4 2 1 0.0629 *
 * FLAG FLAG
 16200100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16200101 3 0.070 *
 * COMPOSITION NO. INTERVAL NO.
 16200201 5 3 *
 * SOURCE VALUE INTERVAL NO.
 16200301 0.0 3 *
 16200400 -1
 * TEMP POINT NO
 16200401 553.52 553.52 553.52 553.52 *
 16200402 554.62 554.62 554.62 554.62 *
 16200403 554.59 554.59 554.58 554.58 *
 16200404 554.55 554.55 554.55 554.55 *

16200405 554.52 554.52 554.52 554.52 *
 16200406 554.49 554.49 554.49 554.49 *
 16200407 554.46 554.46 554.46 554.46 *
 16200408 554.43 554.43 554.43 554.43 *
 16200409 554.40 554.40 554.40 554.40 *
 16200410 554.37 554.37 554.37 554.37 *
 16200411 554.35 554.35 554.35 554.35 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16200501 0 0 0 1 0.5605 1 *
 16200502 0 0 0 1 0.6210 10 *
 16200503 0 0 0 1 0.5705 11 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16200601 620010000 0 1 1 0.5605 1 *
 16200602 620020000 10000 1 1 0.6210 10 *
 16200603 620110000 0 1 1 0.5705 11 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16200701 0 0 0 0 0 11 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16200901 0 0.022 0 0.5605 1 *
 16200902 0 0.022 0 0.6210 10 *
 16200903 0 0.022 0 0.5705 11 *
 *
 ***** RISER TOP VOLUME OUTER WALL *****

 * NH NP TYPE FLAG LEFT BOUNDARY
 16201000 1 10 2 1 0.135 *
 * FLAG FLAG
 16201100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 16201101 6 0.152 *
 16201102 3 0.182 *
 * COMPOS. NO INTERV. NO
 16201201 5 6 *
 16201202 9 9 *
 * SOURCE INTERV. NO
 16201301 0.0 9 *
 16201400 -1
 * TEMP. , POINT NO OR TEMPS.
 16201401 553.94 553.82 553.71 553.59 553.48 553.38 553.27
 + 463.38 379.08 299.66
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 16201501 620150000 0 1 1 0.955 1 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 16201601 -919 0 3979 1 0.955 1 *
 * SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO
 16201701 0. 0. 0. 0. 0. 1 *
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 16201801 0 0.120 0. 0. 0. 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ COURSE SEPERATOR

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16202000 2 3 2 1 0.069 *
 * FLAG FLAG
 16202100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16202101 2 0.070 *

* COMPOSITION NO. INTERVAL NO.
 16202201 5 2 *
 * SOURCE VALUE INTERVAL NO.
 16202301 0.0 2 *
 16202400 -1
 * TEMP POINT NO
 16202401 554.25 554.24 554.24 *
 16202402 554.27 554.26 554.26 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16202501 620140000 0 1 1 2.9930 1 *
 16202502 620130000 0 1 1 1.3350 2 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16202601 640010000 0 1 1 2.9930 1 *
 16202602 640020000 0 1 1 1.3350 2 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16202701 0 0 0 0 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16202801 0 0.205 0 2.9930 1 *
 16202802 0 0.128 0 1.3350 2 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16202901 0 0.065 0 2.9930 1 *
 16202902 0 0.035 0 1.3350 2 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ FINE SEPERATOR

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16203000 1 3 1 1 0.0 *
 * FLAG FLAG
 16203100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16203101 2 0.001 *
 * COMPOSITION NO. INTERVAL NO.
 16203201 5 2 *
 * SOURCE VALUE INTERVAL NO.
 16203301 0.0 2 *
 16203400 -1
 * TEMP POINT NO
 16203401 554.22 554.22 554.22 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16203501 620150000 0 1 1 0.805 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16203601 630010000 0 1 1 0.805 1 * I
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16203701 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16203801 0 0.120 0 0.3 1 * CHANNEL L ?
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16203901 0 0.010 0 0.37 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_TUBE SHEET1(ADJACENT TO INLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16204000 1 5 2 1 0.0098 *
 * FLAG FLAG
 16204100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16204101 4 0.0335 *

* COMPOSITION NO. INTERVAL NO.
 16204201 5 4 *

* SOURCE VALUE INTERVAL NO.
 16204301 0.0 4 *

*

16204400 -1

* TEMP POINT NO
 16204401 589.62 576.83 568.02 561.29 555.84 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16204501 330050000 0 1 1 0.48 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16204601 620110000 0 1 1 0.48 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16204701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16204801 0 0.102 0 0.48 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16204901 0 0.022 0 0.48 1 *

 *STEAM GENERATOR(SECONDARY SIDE)_TUBE SHEET2(ADJACENT TO OUTLET CHAMBER)

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16205000 1 5 2 1 0.0098 *

* FLAG FLAG
 16205100 0 1 *

* NO INTERVAL RIGHT COORDINATE
 16205101 4 0.0335 *

* COMPOSITION NO. INTERVAL NO.
 16205201 5 4 *

* SOURCE VALUE INTERVAL NO.
 16205301 0.0 4 *

16205400 -1

* TEMP POINT NO
 16205401 564.32 560.75 558.30 556.44 554.94 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16205501 330280000 0 1 1 0.48 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16205601 620110000 0 1 1 0.48 1 *

* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16205701 0 0 0 0 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16205801 0 0.102 0 0.48 1 *

* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16205901 0 0.022 0 0.48 1 *

 *STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER (VOLUME 64001)_OUTER WALL

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16400000 1 10 2 1 0.1350 *

* FLAG FLAG
 16400100 0 1 *

* NO INTERVAL RIGHT COORDINATE
 16400101 6 0.143522 *

16400102 3 0.173522 *

* COMPOSITION NO. INTERVAL NO.
 16400201 5 6 *

16400202 9 9 *

* SOURCE VALUE INTERVAL NO.
16400301 0.0 9 *
16400400 -1
* TEMP POINT NO
16400401 553.70 553.64 553.59 553.53 553.48 553.43 553.37
+ 463.18 378.85 299.65
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
16400501 640010000 0 1 1 0.9254 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
16400601 -919 0 3979 1 0.9254 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
16400701 0 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
16400801 0 0.0650 0.0 0.0 1 *
*

*STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER (VOLUME 64002)_OUTER WALL

* NH NP G.TYPE FLAG LEFT BOUNDARY
16401000 1 10 2 1 0.1195 *
* FLAG FLAG
16401100 0 1 *
* NO INTERVAL RIGHT COORDINATE
16401101 6 0.12686 *
16401102 3 0.15686 *
* COMPOSITION NO. INTERVAL NO.
16401201 5 6 *
16401202 9 9 *
* SOURCE VALUE INTERVAL NO.
16401301 0.0 9 *
16401400 -1
* TEMP POINT NO
16401401 554.00 553.95 553.90 553.86 553.81 553.76 553.72
+ 462.76 378.34 299.61
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
16401501 640020000 0 1 1 0.8006 1 *
* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
16401601 -919 0 3979 1 0.8006 1 *
* SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
16401701 0 0 0 0 0 1 *
* CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
16401801 0 0.0350 0.0 0.0 1 *
*

*STEAM GENERATOR (SECONDARY SIDE)_ DOWNCOMER NARROW REGION _OUTER WALL

* NH NP G.TYPE FLAG LEFT BOUNDARY
16500000 01 10 2 1 0.108 *
* FLAG FLAG
16500100 0 1 *
* NO INTERVAL RIGHT COORDINATE
16500101 4 0.12265 *
16500102 5 0.15265 *
* COMPOSITION NO. INTERVAL NO.
16500201 5 4 *
16500202 9 9 *
* SOURCE VALUE INTERVAL NO.
16500301 0.0 9 *
16500400 -1

* TEMP POINT NO
 16500401 545.50 545.35 545.20 545.06 544.93 491.26 440.07
 + 391.17 344.36 299.44
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16500501 650010000 0 1 1 0.5773 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16500601 -919 0 3979 1 0.5773 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16500701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16500801 0 0.0120 0.0 0.0 1 *
 *

 *STEAM GENERATOR (SECONDARY SIDE)_ STEAM DOME_OUTER WALL

 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16600000 1 10 2 1 0.132 *
 * FLAG FLAG
 16600100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16600101 5 0.1488 *
 16600102 4 0.1788 *
 * COMPOSITION NO. INTERVAL NO.
 16600201 5 5 *
 16600202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 16600301 0.0 9 *
 16600400 -1
 * TEMP POINT NO
 16600401 553.92 553.78 553.65 553.52 553.39 553.26 485.20
 + 420.45 358.70 299.66
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16600501 660010000 0 1 1 0.2300 1 *
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16600601 -919 0 3979 1 0.2300 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16600701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16600801 0 0.2640 0.0 0.0 1 *
 *
 * NH NP G.TYPE FLAG LEFT BOUNDARY
 16601000 1 10 1 1 0.0 *
 * FLAG FLAG
 16601100 0 1 *
 * NO INTERVAL RIGHT COORDINATE
 16601101 5 0.02 *
 16601102 4 0.12 *
 * COMPOSITION NO. INTERVAL NO.
 16601201 5 5 *
 16601202 9 9 *
 * SOURCE VALUE INTERVAL NO.
 16601301 0.0 9 *
 16601400 -1
 * TEMP POINT NO
 16601401 554.13 554.08 554.04 553.99 553.95 553.91 489.10
 + 424.90 360.78 296.66
 * BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16601501 660010000 0 1 1 0.07091 1 *

* BOUND.VOLUME INCRE TYPE S.AREA CODE VALUE H.STR.NO
 16601601 -919 0 3979 1 0.07091 1 *
 * SOURCE TYPE MULTIP DIRECT HEAT LEFT DIRECT HEAT RIGHT H.STR.NO
 16601701 0 0 0 0 0 1 *
 * CHF FLAG HYD.DIA HEAT.DIA CHANNEL LENGTH H.STR.NO.
 16601801 0 0.264 0.0 0.0 1 *
 *
 *
 *STEAM LINE
 *
 *
 *SL CONTROL VARIABLES
 *
 20570000 DUMMY SUM 1. 0. 1
 20570001 0. 1. CPUTIME 0
 *
 20570100 LOSS-SH SUM 1.-3 0. 1
 20570101 0. 1.2903 HTRNR 700000101 1.2833 HTRNR 700000201
 + 1.1359 HTRNR 700100101 0.9914 HTRNR 700200101
 + 1.1800 HTRNR 700300101 1.3231 HTRNR 710000101
 + 1.1464 HTRNR 710000201 1.3551 HTRNR 710200101
 + 0.90127 HTRNR 715000101 1.6094 HTRNR 720000101
 *
 7000000 '84-12-15' PIPE * STEAM LINE FROM S.G. I
 * VOLUMES
 7000001 04 *
 * AREA VOL.NO.
 7000101 .003728 02 *
 7000102 .004778 04 *
 * J.AREA JUN.NO.
 7000201 .000000 03 *
 * LENGTH VOL.NO.
 7000301 1.4870 01 *
 7000302 1.4790 02 *
 7000303 1.2020 03 *
 7000304 0.9770 04 *
 * V.A.
 7000601 +00.000 04 *
 * ELEVAT. V.NO.
 7000701 0.0000 04 *
 * ROUGH. DIAM. V.NO.
 7000801 2.0-5 .0689 02 *
 7000802 2.0-5 .0780 04 *
 * K(FORD) K(REV) J.NO.
 7000901 6.32 6.32 01 * 12.32 6.32
 7000902 01.79 01.79 03 * 3.79 1.79
 * FE V.NO
 7001001 00 04 *
 * CAHS J.NO.
 7001101 0000 03 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 7001201 0 6.5158+6 2.5855+6 1.0000 0. 01 *
 7001202 0 6.4847+6 2.5854+6 1.0000 0. 02 *
 7001203 0 6.4769+6 2.5854+6 1.0000 0. 03 *
 7001204 0 6.4712+6 2.5853+6 1.0000 0. 04 *
 * CONTROL
 7001300 0
 * LIQUID V VAPOUR VEL INTERFACE VEL. JUN NO.
 7001301 16.644 16.644 0.0 1 *

7001302 16.724 16.724 0.0 2 *
 7001303 13.064 13.064 0.0 3 *
 *
 7010000 '20-08-84' BRANCH * HEADER INLET
 * NO.J CONTROL
 7010001 01 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 7010101 .003728 1.1730 .0000000 0.0 -9.016 -0.105 2.0-5 .0689 00*
 * CONTROL PRESSURE ENERGY QUALITY
 7010200 0 6.4685+6 2.5852+6 1.0 *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 7011101 700010000 701000000 .000000 00.00 00.00 0000 *
 * INIT L VEL INIT V VEL INTERFACE VEL
 7011201 16.758 16.758 0.0 *
 *
 *
 7050000 '20-08-84' VALVE ** S.G. I ISOL. VALVE * AND HEADER INLET
 * FROM TO AREA FORW REV CAHS
 7050101 701010000 720000000 0.003728 0.0 0.0 0100*
 * CNTL LIQU VEL VAP VEL 0
 7050201 0 16.763 16.763 0.*
 * VALVE * TYPE
 7050300 SRVVLV*
 * CNTRLVAR TABLE
 7050301 571 501*
 *
 *
 7100000 '05-09-84' PIPE * STEAM LINE EXIT
 * VOLUMES
 7100001 03 *
 * AREA VOL.NO.
 7100101 .001368 02 * .001459
 7100102 .001698 03 * .001787
 * J.AREA JUN.NO.
 7100201 .000000 02 *
 * LENGTH VOL.NO.
 7100301 1.6955 01 *
 7100302 1.4690 02 *
 7100303 1.4970 03 *
 * VOLUME V.NO.
 7100401 .0000000 03 *
 * H.A V.NO.
 7100501 0.0 03 *
 * V.ANGLE V.NO.
 7100601 +00.000 03 *
 * ELEVAT. V.NO.
 7100701 0.0000 03 *
 * ROUGH. DIAM. V.NO.
 7100801 2.0-5 .0431 02 *
 7100802 2.0-5 .0477 03 *
 * K(FORD) K(REV) J.NO.
 7100901 6.80 6.80 01 * 6.8
 7100902 6.96 6.96 02 * 6.96
 * FE V.NO
 7101001 00 03 *
 * CAHS J.NO.
 7101101 0000 2 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 7101201 0 6.5173+6 2.5855+6 1. 0. 01 *

7101202 0 6.4915+6 2.5853+6 1. 0. 02 *
 7101203 0 6.4669+6 2.5852+6 1. 0. 03 *
 * CONTROL
 7101300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
 7101301 14.327 14.327 0.0 01 *
 7101302 14.382 14.382 0.0 02 *
 *
 7110000 '20-08-84' BRANCH * HEADER INLET
 * NO.J CONTROL
 7110001 01 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 7110101 .001459 1.0130 .0000000 0.0 -20.532 -0.242 2.0-5 .0431 00*
 * CONTROL PRESSURE ENERGY QUALITY
 7110200 0 6.4649+6 2.5850+6 1.0 *
 * CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS
 7111101 710010000 711000000 .0000000 00.00 00.00 0000 *
 * INIT L VEL INIT V VEL INTERFACE VEL
 7111201 13.534 13.534 0.0 *
 *
 *
 7150000 '20-08-84' VALVE ** S.G.II ISOL. VALVE * AND HEADER INLET
 * FROM TO AREA FORW REV CAHS
 7150101 711010000 720000000 0.001459 0.0 0.0 0100*
 * CNTL LIQU VEL VAP VEL 0
 7150201 0 13.536 13.536 0.*
 * VALVE * TYPE
 7150300 SRVVLV*
 * CNTRLVAR TABLE
 7150301 654 602*
 *
 7200000 '20-08-84' BRANCH * HEADER
 * NO.J CONTROL
 7200001 00 0 *
 * AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 7200101 .004608 1.6600 .0000000 0.0 0. 0. 8.0-5 .0766 00*
 * CONTROL PRESSURE ENERGY QUALITY
 7200200 0 6.4511+6 2.5851+6 1.0 *
 *
 7250000 '20-08-84' VALVE ** MAIN STEAM VALVE *
 * FROM TO AREA FORW REV CAHS
 7250101 720010000 730000000 0.004608 0.0 0.0 0100*
 * CNTL LIQU VEL VAP VEL 0
 7250201 0 17.892 17.892 0.*
 * VALVE * TYPE
 7250300 MTRVLV*
 * TRIP NO
 7250301 502 506 0.6667 1.0
 *
 7300000 '84-12-21' TMDPVOL * PIPING TO CONDENSER
 7300101 1. 1. 0. 0. 0. 0. 0. 00*
 7300200 2 501 TIME 0*
 7300201 0. 6.45+6 1.
 *
 7400000 '20-08-84' VALVE ** S.G.I RELIEF VALVE
 * FROM TO AREA FORW REV CAHS
 7400101 701010000 741000000 0.003728 0.0 0.0 0000*
 * CNTL LIQU VEL VAP VEL 0
 7400201 0 0.0 0.0 0.*

* VALVE * TYPE
 7400300 CHKVLV*

*
 7400301 0 0 0. 0.

*
 7410000 '84-12-21' TMDPVOL * COOL DOWN CONDITIONS
 7410101 1. 1. 0. 0. 0. 0. 0. 0. 00*
 *410200 1 506 *
 *410201 0. 570.773 1.
 *410202 5400. 420.773 1.
 7410200 3 506 *
 7410201 -14. 8.3445+6 573.
 7410202 166. 7.7686+6 568.
 7410203 346. 7.2237+6 563.
 7410204 526. 6.7085+6 558.
 7410205 706. 6.2219+6 553.
 7410206 886. 5.7627+6 548.
 7410207 1066. 5.3298+6 543.
 7410208 1246. 4.9223+6 538.
 7410209 1426. 4.5390+6 533.
 7410210 1606. 4.1789+6 528.
 7410211 1786. 3.8412+6 523.
 7410212 1966. 3.5247+6 518.
 7410213 2146. 3.2286+6 513.
 7410214 2326. 2.9521+6 508.
 7410215 2506. 2.6941+6 503.
 7410216 2686. 2.4538+6 498.
 7410217 2866. 2.2305+6 493.
 7410218 3046. 2.0232+6 488.
 7410219 3226. 1.8311+6 483.
 7410220 3406. 1.6536+6 478.
 7410221 3586. 1.4897+6 473.
 7410222 3766. 1.3388+6 468.
 7410223 3946. 1.2001+6 463.
 7410224 4126. 1.0730+6 458.
 7410225 4306. 9.5666+5 453.
 7410226 4486. 8.5053+5 448.
 7410227 4666. 7.5394+5 443.
 7410228 4846. 6.6625+5 438.
 7410229 5026. 5.8687+5 433.
 7410230 5206. 5.1523+5 428.
 7410231 5386. 4.5075+5 423.

*
 7500000 '20-08-84' VALVE ** S.G.II RELIEF VALVE
 * FROM TO AREA FORW REV CAHS
 7500101 711010000 751000000 0.001459 0.0 0.0 0000*
 * CNTL LIQU VEL VAP VEL 0
 7500201 0 0.0 0.0 0.*
 * VALVE * TYPE
 7500300 CHKVLV*

*
 7500301 0 0 0. 0.

*
 7510000 '84-12-21' TMDPVOL * COOL DOWN CONDITIONS
 7510101 1. 1. 0. 0. 0. 0. 0. 0. 00*
 *510200 1 506 *
 *510201 0. 570.773 1.

*510202	5400.	420.773	1.
7510200	3 506	*	
7510201	-14.	8.3445+6	573.
7510202	166.	7.7686+6	568.
7510203	346.	7.2237+6	563.
7510204	526.	6.7085+6	558.
7510205	706.	6.2219+6	553.
7510206	886.	5.7627+6	548.
7510207	1066.	5.3298+6	543.
7510208	1246.	4.9223+6	538.
7510209	1426.	4.5390+6	533.
7510210	1606.	4.1789+6	528.
7510211	1786.	3.8412+6	523.
7510212	1966.	3.5247+6	518.
7510213	2146.	3.2286+6	513.
7510214	2326.	2.9521+6	508.
7510215	2506.	2.6941+6	503.
7510216	2686.	2.4538+6	498.
7510217	2866.	2.2305+6	493.
7510218	3046.	2.0232+6	488.
7510219	3226.	1.8311+6	483.
7510220	3406.	1.6536+6	478.
7510221	3586.	1.4897+6	473.
7510222	3766.	1.3388+6	468.
7510223	3946.	1.2001+6	463.
7510224	4126.	1.0730+6	458.
7510225	4306.	9.5666+5	453.
7510226	4486.	8.5053+5	448.
7510227	4666.	7.5394+5	443.
7510228	4846.	6.6625+5	438.
7510229	5026.	5.8687+5	433.
7510230	5206.	5.1523+5	428.
7510231	5386.	4.5075+5	423.

*

***** STEAM LINE FROM S.G. TO MEASUREMENT INSERT *****

* NH NP TYPE FLAG LEFT BOUNDARY

17000000	2 7 2 1	0.0345 *
*	FLAG FLAG	
17000100	0 1	*
*	NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO	
17000101	3 0.0381	*
17000102	3 0.1381	*
*	COMPOS. NO INTERV. NO	
17000201	5 3	*
17000202	9 6	*
*	SOURCE INTERV. NO	
17000301	0.0 6	*
*	TEMP. , POINT NO	OR TEMPS.
17000401	382.26 7	*
*	VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO	
17000501	700010000 00000 1 1 1.487 1 *	
17000502	700020000 00000 1 1 1.479 2 *	
*	VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO	
17000601	-919 0 3949 1 1.487 1 *	
17000602	-919 0 3949 1 1.479 2 *	
*	SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO	
17000701	0. 0. 0. 0. 0. 2 *	

* CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 17000801 0 0.0689 0. 0. 2
 *
 **** STEAM LINE MEASUREMENT INSERT SECTION I ****

 * NH NP TYPE FLAG LEFT BOUNDARY
 17001000 1 7 2 1 0.0390 *
 * FLAG FLAG
 17001100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 17001101 3 0.0504 *
 17001102 3 0.1504 *
 * COMPOS. NO INTERV. NO
 17001201 5 3 *
 17001202 9 6 *
 * SOURCE INTERV. NO
 17001301 0.0 6 *
 * TEMP. , POINT NO OR TEMPS.
 17001401 393.81 7 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17001501 700030000 0 1 1 1.202 1 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17001601 -919 0 3949 1 1.202 1 *
 * SOURCE TYPE MULTI DIR. HEAT LEFT DIR. HEAT RIGHT ST.NO
 17001701 0. 0. 0. 0. 1 *
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 17001801 0 0.078 0. 0. 1 *
 *
 **** STEAM LINE MEASUREMENT INSERT SECTION II ****

 * NH NP TYPE FLAG LEFT BOUNDARY
 17002000 1 7 2 1 0.0390 *
 * FLAG FLAG
 17002100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 17002101 3 0.0615 *
 17002102 3 0.1615 *
 * COMPOS. NO INTERV. NO
 17002201 5 3 *
 17002202 9 6 *
 * SOURCE INTERV. NO
 17002301 0.0 6 *
 * TEMP. , POINT NO OR TEMPS.
 17002401 404.96 7 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17002501 700040000 0 1 1 0.977 1 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17002601 -919 0 3949 1 0.977 1 *
 * SOURCE TYPE MULTI DIR. HEAT LEFT DIR. HEAT RIGHT ST.NO
 17002701 0. 0. 0. 0. 1 *
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 17002801 0 0.078 0. 0. 1 *
 *
 **** STEAM LINE HEADER INLET FROM S.G. I ****

 * NH NP TYPE FLAG LEFT BOUNDARY

17003000 1 7 2 1 0.0381 *

* FLAG FLAG

17003100 0 1 *

* NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO

17003101 3 0.0601 *

17003102 3 0.1601 *

* COMPOS. NO INTERV. NO

17003201 5 3 *

17003202 9 6 *

* SOURCE INTERV. NO

17003301 0.0 6 *

* TEMP. , POINT NO OR TEMPS.

17003401 404.04 7 *

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

17003501 701010000 0 1 1 1.173 1 *

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

17003601 -919 0 3949 1 1.173 1 *

* SOURCE TYPE MULTI DIR. HEAT LEFT DIR. HEAT RIGHT ST.NO

17003701 0. 0. 0. 0. 0. 1 *

* CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO

17003801 0 0.078 0. 0. 0. 1 *

***** STEAM LINE FROM S.G. TILL VOL 71003 *****

* NH NP TYPE FLAG LEFT BOUNDARY

17100000 2 7 2 1 0.0216 *

* FLAG FLAG

17100100 0 1 *

* NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO

17100101 3 0.0242 *

17100102 3 0.1242 *

* COMPOS. NO INTERV. NO

17100201 5 3 *

17100202 9 6 *

* SOURCE INTERV. NO

17100301 0.0 6 *

* TEMP. , POINT NO OR TEMPS.

17100401 371.70 7**

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

17100501 710010000 00000 1 1 1.6955 1 *

17100502 710020000 00000 1 1 1.4690 2 *

* VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

17100601 -919 0 3949 1 1.6955 1 *

17100602 -919 0 3949 1 1.4690 2 *

* SOURCE TYPE MULTI DIRECT HEAT LEFT DIRECT HEAT RIGHT NO

17100701 0. 0. 0. 0. 0. 2 *

* CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO

17100801 0 0.0431 0. 0. 0. 2

***** STEAM LINE MEASUREMENT INSERT SECTION *****

* NH NP TYPE FLAG LEFT BOUNDARY

17102000 1 7 2 1 0.02385*

* FLAG FLAG

17102100 0 1 *

* NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO

17102101 3 0.04407 *

17102102 3 0.14407 *

* COMPOS. NO INTERV. NO
 17102201 5 3 *
 17102202 9 6 *
 * SOURCE INTERV. NO
 17102301 0.0 6 *
 * TEMP. , POINT NO OR TEMPS.
 17102401 394.23 7*
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17102501 710030000 0 1 1 1.4970 1 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17102601 -919 0 3949 1 1.4970 1 *
 * SOURCE TYPE MULTI DIR. HEAT LEFT DIR. HEAT RIGHT ST.NO
 17102701 0. 0. 0. 0. 0. 1 *
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 17102801 0 0.0477 0. 0. 1 *
 *
 ***** STEAM LINE HEADER INLET FROM S.G. II *****

 * NH NP TYPE FLAG LEFT BOUNDARY
 17150000 1 7 2 1 0.0216 *
 * FLAG FLAG
 17150100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 17150101 3 0.0416 *
 17150102 3 0.1416 *
 * COMPOS. NO INTERV. NO
 17150201 5 3 *
 17150202 9 6 *
 * SOURCE INTERV. NO
 17150301 0.0 6 *
 * TEMP. , POINT NO OR TEMPS.
 17150401 392.42 7 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17150501 711010000 0 1 1 1.013 1 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17150601 -919 0 3949 1 1.013 1 *
 * SOURCE TYPE MULTI DIR. HEAT LEFT DIR. HEAT RIGHT ST.NO
 17150701 0. 0. 0. 0. 0. 1 *
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 17150801 0 0.0431 0. 0. 1 *

 * HEADER *****
 *
 * NH NP TYPE FLAG LEFT BOUNDARY
 17200000 1 7 2 1 0.0388 *
 * FLAG FLAG
 17200100 0 1 *
 * NO INTERV.,RIGHT COORD. OR MESH INTERV.,MESH NO
 17200101 3 0.0543 *
 17200102 3 0.1543 *
 * COMPOS. NO INTERV. NO
 17200201 5 3 *
 17200202 9 6 *
 * SOURCE INTERV. NO
 17200301 0.0 6 *
 * TEMP. , POINT NO OR TEMPS.
 17200401 397.94 7 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO

17200501 720010000 0 1 1 1.660 1 *
 * VOLUME INCRE TYPE AREA CODE VALUE STRUCT. NO
 17200601 -919 0 3949 1 1.660 1 *
 * SOURCE TYPE MULTI DIR. HEAT LEFT DIR. HEAT RIGHT ST.NO
 17200701 0 0. 0. 0. 0. 1 *
 * CHF FLAG HYDR.DIAM HEAT. DIAM CHANN.LENGTH STRUCT NO
 17200801 0 0.0766 0. 0. 1 *
 *
 *
***INJECTION SYSTEMS**
 *
 *
***IS CONTROL VARIABLES**
 *
 20580000 DUMMY SUM 1.0 0 1*
 20580001 0. 1. CPUTIME 0*
 *
 20580100 QM55 SUM 1.0 0 1*
 20580101 0. 1. MFLOWJ 855000000
 *
 20580500 SLFLOW SUM 1.0 0. 1*
 20580501 0. 1. MFLOWJ 810000000 1. MFLOWJ 830000000 *
 20580600 CHANGE FUNCTION 1.0 1.0 1 *
 20580601 CNTRLVAR 807 807
 20580700 ARGUM MULT 1.0 1.0 0
 20580701 CNTRLVAR 810 CNTRLVAR 811
 20580800 CLOSE MULT 1. 1. 1
 20580801 CNTRLVAR 805 CNTRLVAR 806
 20580900 TRIP TRIPDLAY 1.0 0.0 1
 20580901 504
 20581000 ARGUM SUM 1.0 0.0 1
 20581001 0. 1. TIME 0 -1. CNTRLVAR 809
 20581100 ONOFF TRIPUNIT 1.0 0.0 0
 20581101 504
 *
 *
***IS VOLUMES**
 *
***PUMP SEAL WATER**
 *
***PS INTACT LOOP**
 * 'NAME' TYPE
 8000000 '84-12-15' TMDPVOL * SEAL WATER TANK
 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
 8000101 0.011698 0.5140 0.0 0. 0.0 0.0 8.-5 0.0532 00*
 * CNTL TRIP VARIABLE CODE
 8000200 3 501 TIME 0 *
 * SEARCH VAR. FLUID COND. (2 QUANTITIES)
 8000201 0. 19.4+6 298.16 *
 *
 * 'NAME' TYPE
 8100000 '84-12-15' TMDPJUN * SEAL WATER
 * FROM TO AREA
 8100101 800000000 255000000 0.0005*
 * CNTL TRIP NO. VARIABLE CODE
 8100200 1 501 CNTRLVAR 198
 * SEARCH VAR(P) LIQUID F VAPOR F. 0
 8100201 2.5 0.01444 0.0 0.0 *
 8100202 3.0 0.01500 0.0 0.0 *

8100203	4.0	0.01583	0.0	0.0	*
8100204	5.0	0.01639	0.0	0.0	*
8100205	6.0	0.01722	0.0	0.0	*
8100206	7.0	0.01750	0.0	0.0	*
8100207	8.0	0.01778	0.0	0.0	*
8100208	9.0	0.01806	0.0	0.0	*
8100209	10.0	0.01806	0.0	0.0	*
8100210	11.0	0.01778	0.0	0.0	*
8100211	12.0	0.01750	0.0	0.0	*
8100212	13.0	0.01667	0.0	0.0	*
8100213	14.0	0.01528	0.0	0.0	*
8100214	15.0	0.01333	0.0	0.0	*
8100215	16.0	0.01111	0.0	0.0	*
8100216	17.0	0.00833	0.0	0.0	*

*

*PS BROKEN LOOP

* 'NAME' TYPE

8200000 '84-12-15' TMDPVOL * SEAL WATER TANK

* AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
8200101 0.011698 0.5140 0.0 0. 0.0 0.0 8.-5 0.0532 00*

* CNTL TRIP VARIABLE CODE

8200200 3 501 TIME 0 *

* SEARCH VAR. FLUID COND. (2 QUANTITIES)

8200201 0. 19.4+6 298.16 *

*

* 'NAME' TYPE

8300000 '84-12-15' TMDPJUN * SEAL WATER

* FROM TO AREA

8300101 820000000 355000000 0.0005*

* CNTL TRIP NO. VARIABLE CODE

8300200 1 501 CNTRLVAR 198

* SEARCH VAR(P) LIQUID F VAPOR F. 0

8300201	2.5	0.00944	0.0	0.0	*
8300202	3.0	0.01000	0.0	0.0	*
8300203	4.0	0.01083	0.0	0.0	*
8300204	5.0	0.01167	0.0	0.0	*
8300205	6.0	0.01222	0.0	0.0	*
8300206	7.0	0.01278	0.0	0.0	*
8300207	8.0	0.01306	0.0	0.0	*
8300208	9.0	0.01333	0.0	0.0	*
8300209	10.0	0.01361	0.0	0.0	*
8300210	11.0	0.01361	0.0	0.0	*
8300211	12.0	0.01333	0.0	0.0	*
8300212	13.0	0.01278	0.0	0.0	*
8300213	14.0	0.01194	0.0	0.0	*
8300214	15.0	0.01028	0.0	0.0	*
8300215	16.0	0.00861	0.0	0.0	*
8300216	17.0	0.00639	0.0	0.0	*

*

*PS UPPER PLENUM DRAINAGE

*

* 'NAME' TYPE

8350000 '84-12-15' TMDPJUN * SEAL WATER DRAINAGE

* FROM TO AREA

8350101 190010000 840000000 0.001*

* CNTL TRIP NO. VARIABLE CODE

8350200 1 501 CNTRLVAR 808

* SEARCH VAR(F) LIQUID F VAPOR F. 0

8350201 0.0 0.0 0.0 0.0 *

8350202 1.0 1.0 0.0 0.0 *

* 'NAME' TYPE
 8400000 '84-12-15' TMDPVOL *
 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
 8400101 0.011698 0.5140 0.0 0. 0.0 0.0 8.-5 0.0532 00*
 * CNTL TRIP VARIABLE CODE
 8400200 3 501 TIME 0 *
 * SEARCH VAR. FLUID COND. (2 QUANTITIES)
 8400201 0. 15.7+6 600.00 *
 *
 *HIGH PRESSURE INJECTION SYSTEM
 *
 * 'NAME' TYPE
 8500000 '85-01-29' TMDPVOL *
 * AREA LENGTH VOLUME 0 ANGLE ELEV. ROUGHN DIAM FE
 8500101 0.000113 0.0 0.1 0. 0.0 0.0 2.-5 0.012 00*
 * CNTL TRIP VARIABLE CODE
 8500200 3 501 TIME 0 *
 * SEARCH VAR. FLUID COND. (2 QUANTITIES)
 8500201 0. 11.7+6 303.15 *
 *
 * 'NAME' TYPE
 8550000 '85-01-29' TMDPJUN *
 * FROM TO AREA
 8550101 850000000 270000000 0.001*
 * CNTL TRIP NO. VARIABLE CODE
 8550200 1 509 CNTRLVAR 198
 * SEARCH VAR(P) LIQUID F VAPOR F. 0
 8550201 0.0 0.000 0.0 0.0 *
 8550202 0.1 0.201 0.0 0.0
 8550203 1.1 0.192 0.0 0.0 *
 8550204 2.1 0.183 0.0 0.0 *
 8550205 3.1 0.172 0.0 0.0 *
 8550206 4.1 0.160 0.0 0.0 *
 8550207 5.1 0.147 0.0 0.0 *
 8550208 6.1 0.132 0.0 0.0 *
 8550209 7.1 0.1164 0.0 0.0 *
 8550210 8.1 0.098 0.0 0.0 *
 8550211 9.1 0.077 0.0 0.0 *
 8550212 10.1 0.0520 0.0 0.0 *
 8550213 11.1 0.0218 0.0 0.0 *
 8550214 11.7 0.000 0.0 0.0 *
 *
 *
 *TABLES
 *
 *
 **** HEAT STRUCTURE THERMAL PROPERTY DATA ****
 *
 *
 * CNTL WORD FLAG FLAG
 20100100 TBL/FCTN 1 1 *INCOLNEL 625
 20100200 TBL/FCTN 1 1 *INCOLNEL 718
 20100300 TBL/FCTN 1 1 *1.4948
 20100400 TBL/FCTN 1 1 *NI 201
 20100500 TBL/FCTN 1 1 *1.4571
 20100600 TBL/FCTN 1 1 *AL203

20100700	TBL/FCTN	1	1	*INCOLOY 800
20100800	TBL/FCTN	1	1	*HONEYCOMB
20100900	TBL/FCTN	1	1	*ROCKWOOL

* INCONEL 625 _ THERMAL CONDUCTIVITY

* TEMP(K) (WATT/M-K)

20100101	293.0	12.5	*
20100102	473.0	12.5	*
20100103	573.0	13.9	*
20100104	673.0	15.3	*

* INCONEL 625 _ VOLUMETRIC HEAT CAPACITY

* TEMP(K) (JOULE/M3-K)

20100151	293.0	3.460E6	*
20100152	373.0	3.671E6	*
20100153	473.0	3.866E6	*
20100154	573.0	4.051E6	*
20100155	673.0	4.262E6	*

* INCONEL 718 _ THERMAL CONDUCTIVITY

* TEMP(K) (WATT/M-K)

20100201	293.0	11.1	*
20100202	373.0	12.4	*
20100203	473.0	14.0	*
20100204	573.0	15.7	*
20100205	673.0	17.4	*

* INCONEL 718 _ VOLUMETRIC HEAT CAPACITY

* TEMP(K) (JOULE/M3-K)

20100251		3.522E6	*
----------	--	---------	---

* 1.4948 _ THERMAL CONDUCTIVITY

* TEMP(K) (WATT/M-K)

20100301	293.0	16.9	*
20100302	300.0	17.0	*
20100303	400.0	18.3	*
20100304	500.0	18.9	*
20100305	600.0	20.1	*
20100306	700.0	21.2	*
20100307	800.0	22.4	*
20100308	900.0	23.5	*
20100309	1000.0	24.7	*
20100310	1050.0	25.3	*

* 1.4948 _ VOLUMETRIC HEAT CAPACITY

* TEMP(K) (JOULE/M3-K)

20100351	293.0	3.966E6	*
20100352	300.0	3.988E6	*
20100353	400.0	4.125E6	*
20100354	500.0	4.261E6	*
20100355	600.0	4.401E6	*
20100356	700.0	4.535E6	*
20100357	800.0	4.669E6	*

20100358	900.0	4.792E6	*
20100359	1000.0	4.968E6	*
20100360	1050.0	5.066E6	*

* NI 201 _ THERMAL CONDUCTIVITY

	TEMP(K)	(WATT/M-K)	
20100401	293.0	79.2	*
20100402	533.0	61.9	*
20100403	813.0	59.0	*
20100404	1088.0	64.8	*

* NI 201 _ VOLUMETRIC HEAT CAPACITY

	TEMP(K)	(JOULE/M3-K)	
20100451		4.054E6	*

* 1.4571 _ THERMAL CONDUCTIVITY

	TEMP(K)	(WATT/M-K)	
20100501	293.0	14.0	*
20100502	623.0	18.6	*

* 1.4571 _ VOLUMETRIC HEAT CAPACITY

	TEMP(K)	(JOULE/M3-K)	
20100551	293.0	3.620E6	*
20100552	623.0	4.210E6	*

* AL203 _ THERMAL CONDUCTIVITY

	TEMP(K)	(WATT/M-K)	
20100601	293.0	41.9	*
20100602	373.0	35.6	*
20100603	773.0	12.6	*
20100604	1073.0	8.4	*

* AL203 _ VOLUMETRIC HEAT CAPACITY

	TEMP(K)	(JOULE/M3-K)	
20100651		4042.5	*

* INCOLOY 800 _ THERMAL CONDUCTIVITY

	TEMP(K)	(WATT/M-K)	
20100701	294.0	11.5	*
20100702	533.0	15.7	*
20100703	811.0	20.1	*
20100704	1089.0	25.1	*

* INCOLOY 800 _ VOLUMETRIC HEAT CAPACITY

	TEMP(K)	(JOULE/M3-K)	
20100751		4.030E6	*

* HONEYCOMB _ THERMAL CONDUCTIVITY

	TEMP(K)	(WATT/M-K)	
20100801	293.0	8.4	*

20100802 623.0 11.16 *

* HONEYCOMB _ VOLUMETRIC HEAT CAPACITY

* TEMP(K) (JOULE/M3-K)
20100851 293.0 1.540E6 *
20100852 623.0 1.790E6 *

* ROCKWOOL _ THERMAL CONDUCTIVITY

* TEMP(K) (WATT/M-K)
20100901 0.07 *

* ROCKWOOL _ VOLUMETRIC HEAT CAPACITY

20100951 0.140E6 *

*
*

***** POWER AND HEAT STRUCTURE *****
***** BOUNDARY CONDITIONS *****

*
* CONTROLLER TABLES
*

20226200 REAC-T * PUMP COASTDOWN
20226201 0. 1.0
20226202 5. 0.78
20226203 10. 0.60
20226204 15. 0.46
20226205 20. 0.36
20226206 25. 0.30
20226207 30. 0.25
20226208 40. 0.18
20226209 65. 0.10
20226210 70. 0.0

*

20250100 NORMAREA * STEAM EXIT VALVE CHARACTERISTICS
20250101 0.0 0.05
20250102 0.0001 0.05
20250103 1.0 1.0

*

20250200 REAC-T * DEADBAND FUNCTION
20250201 -100. -100.
20250202 -0.6 -0.6
20250203 -0.5 -0.45
20250204 -0.45 -0.4
20250205 -0.4 -0.2
20250206 -0.35 -0.1
20250207 -0.3 -0.05
20250208 -0.25 -0.02
20250209 -0.2 0.0
20250210 0.2 0.0
20250211 0.25 0.02
20250212 0.3 0.05
20250213 0.35 0.1
20250214 0.4 0.2
20250215 0.45 0.4

20250216	.5	0.45
20250217	.6	.6
20250218	100.	100.
*		
20250300	REAC-T	* FEEDMULT FUNCTION
20250301	-0.20	0.5
20250302	-0.15	0.7
20250303	-0.10	0.85
20250304	-0.07	0.90
20250305	-0.04	0.95
20250306	-0.02	0.985
20250307	0.0	1.0
20250308	0.02	1.005
20250309	0.04	1.015
20250310	0.07	1.05
20250311	0.10	1.075
20250312	0.15	1.15
20250313	0.20	1.3
20250314	1.0	3.0
*		
20257600	REAC-T	* CLOSING STEAM VALVES
20257601	0.	1.0
20257602	1.5	0.0
*		
20260200	NORMAREA	* STEAM EXIT VALVE CHARACTERISTICS
20260201	0.0	0.05
20260202	0.0001	0.05
20260203	1.0	1.00
*		
20260900	REAC-T	* DEADBAND FUNCTION
20260901	-100.0	-100.0
20260902	-0.6	-0.6
20260903	-0.5	-0.45
20260904	-0.45	-0.4
20260905	-0.4	-0.2
20260906	-0.35	-0.1
20260907	-0.3	-0.05
20260908	-0.25	-0.02
20260909	-0.2	0.0
20260910	0.2	0.0
20260911	0.25	0.02
20260912	0.3	0.05
20260913	0.35	0.1
20260914	0.4	0.2
20260915	0.45	0.4
20260916	.5	0.45
20260917	.6	.6
20260918	100.	100.
*		
20260400	REAC-T	* FEEDMULT FUNCTION
20260401	-0.35	0.700
20260402	-0.30	0.850
20260403	-0.20	0.925
20260404	-0.15	0.950
20260405	-0.10	0.985
20260406	-0.05	0.995
20260407	0.00	1.000
20260408	0.05	1.005
20260409	0.10	1.015

20260410 0.15 1.050
 20260411 0.20 1.075
 20260412 0.30 1.150
 20260413 0.35 1.300
 20260414 0.50 1.5
 *

20280700 REAC-T * DRAIN VALVE CHARACTERISTICS

20280701 0. 1.0
 20280702 8. 0.0
 *

* HEATING POWER

20290000	POWER	507	1.0	5.206+6*
20290001		-1.0	1.00	
20290002		0.0	1.00	*POWER DOWN
20290003		1.0	0.90	
20290004		2.0	0.73	
20290005		3.0	0.65	
20290006		5.0	0.51	
20290007		7.0	0.40	
20290008		9.0	0.32	
20290009		13.0	0.20	
20290010		15.0	0.161	
20290011		16.0	0.15	
20290012		17.0	0.14	
20290013		18.0	0.13	
20290014		20.0	0.12	
20290015		24.0	0.10	
20290016		30.0	0.08	
20290017		40.0	0.065	
20290018		68.0	0.048	
20290019		110.0	0.04	
20290020		170.0	0.035	
20290021		270.0	0.028	
20290022		470.0	0.023	
20290023		870.0	0.02	
20290024		1000.0	0.019	
20290025		2000.0	0.016	
20290026		4000.0	0.013	
20290027		6000.0	0.011	
20290028		10000.0	0.01	

*

* ENVIRONMENTAL HEAT LOSS BOUNDARY TEMPERATURE

20291900 TEMP *

20291901 0.0 295.16 *

* ENVIRONMENTAL HEAT LOSS TRANSFER COEFFICIENTS

20292900 HTC-T * VESSEL SIM. UPPER DOWNCOMER

20292901 0.0 50. * 51.

*

20293900 HTC-T * VESSEL SIM. LOWER DOWNCOMER

20293901 0.0 30. * 20.

*

20294900 HTC-T * VESSEL SIM. DOWNCOMER,LOW. PLENUM, UPPER HEAD&STEAM L.

20294901 0.0 20. *

*PR

20295900 HTC-T *

20295901 0.0 10. *

*SG1

20296900 HTC-T * SG I SEC. SIDE

20296901 0.0 120. *

*SG2
20297900 HTC-T * SG II SEC. SIDE
20297901 0.0 120. *

*IL
20298000 HTC-T *
20298001 0.0 05. *

*PUMP I
20298100 HTC-T *
20298101 0.0 100. *

*BL
20298200 HTC-T *
20298201 0.0 30. *

*PUMP II
20298300 HTC-T *
20298301 0.0 100. *

.END

*

 =LOBI-MOD2 TEST A2-81(ISP18) 85/03/14

 100 RESTART TRANSNT *

 103 17600

 *04 NONE

 201 440. 1.0E-6 .05 00001 100 2000 2000*

 202 700. 1.0E-10 .025 00001 200 2000 2000*

 03 5000. 1.0E-10 .05 00001 100 2000 2000
 *

 600 511
 *

 *

 *PARAMETERS TO BE PREDICTED
 *

 301 CNTRLVAR 198* * PA38

 302 CNTRLVAR 401* * PA40

 303 CNTRLVAR 199* * WH-POWER

 304 CNTRLVAR 207* * RP71

 305 CNTRLVAR 301* * CM05

 306 CNTRLVAR 801* * QM55

 307 CNTRLVAR 204* * TF11T

 308 CNTRLVAR 203* * TF11B

 309 CNTRLVAR 206* * TF16T

 310 CNTRLVAR 205* * TF16B

 311 CNTRLVAR 351* * TF21T

 312 CNTRLVAR 350* * TF21B

 313 CNTRLVAR 353* * TF26T

 314 CNTRLVAR 352* * TF26B

 315 CNTRLVAR 189* * TF35

 316 CNTRLVAR 201* * DD11

 317 CNTRLVAR 208* * DD14

 318 CNTRLVAR 202* * DD16

 319 CNTRLVAR 354* * DD21

 320 CNTRLVAR 355* * DD24

 321 CNTRLVAR 356* * DD25

 322 CNTRLVAR 357* * DD26

 323 CNTRLVAR 184* * DS35

 324 CNTRLVAR 286* * PD9217

 325 CNTRLVAR 287* * PD1714

 326 CNTRLVAR 317* * PD8227

 327 CNTRLVAR 318* * PD2724

 328 CNTRLVAR 179* * PD3DBT

 329 CNTRLVAR 178* * PD3RTK

 330 CNTRLVAR 177* * PD3RKA

 331 CNTRLVAR 281* * PD90BN

 332 CNTRLVAR 312* * PD80BN

 333 CNTRLVAR 176* * PD3R39

 334 CNTRLVAR 405* * CL4340

 335 CNTRLVAR 175* * TH04

 336 CNTRLVAR 174* * TH07

 337 CNTRLVAR 173* * TH09

 338 CNTRLVAR 172* * TH11

 339 CNTRLVAR 171* * TH13

 340 CNTRLVAR 170* * TH14

 341 CNTRLVAR 544* * PA97S

 342 CNTRLVAR 545* * TF95B

 343 CNTRLVAR 546* * TF95N

 344 CNTRLVAR 547* * TF97T

 345 CNTRLVAR 672* * TF85B

 346 CNTRLVAR 673* * TF85K

347 CNTRLVAR 674* * TF87T
 348 CNTRLVAR 548* * CM93G
 349 CNTRLVAR 675* * CM83G
 350 CNTRLVAR 549* * CM65
 351 CNTRLVAR 676* * CM66
 352 CNTRLVAR 552* * CL93BN
 353 CNTRLVAR 635* * CL83BN
*

*OTHER MINOR EDIT VARIABLES

*

* LIQUID MASS INVENTORY

354 CNTRLVAR 534 * SGI
 355 CNTRLVAR 634 * SGII
 356 CNTRLVAR 190 * WH-POW ALT. DEF.
 357 CNTRLVAR 001 * TOT. HEAT LOSS
 358 CNTRLVAR 031 * VESSEL COLL. LIQUID LEVEL
 359 CNTRLVAR 222 * THTSG1
 360 CNTRLVAR 332 * THTSG2
 361 CNTRLVAR 308 * LEAK MASS LOSS
 362 CNTRLVAR 310 * LEAK HEAT REMOVAL
 363 PMPVEL 250
 364 PMPVEL 350
 365 MFLOWJ 210020000
 366 MFLOWJ 300010000
 367 MFLOWJ 395020000
 368 MFLOWJ 390010000
**

* * PUMP I COAST DOWN

* *
 20526100 TRIPCOND TRIPUNIT 1.0 1.0 0
 20526101 510
 20526200 TRIPTIME TRIPDLAY 1.0 -1. 1
 20526201 510
 20526400 ARGUMENT SUM 1.0 0. 0
 20526401 0. 1. TIME 0 -1. CNTRLVAR 262
 20526800 MULTIP MULT 1.0 0. 0
 20526801 CNTRLVAR 261 CNTRLVAR 264
 20526300 TABLE FUNCTION 514.73 514.73 0
 20526301 CNTRLVAR 268 262 *

**

* * PUMP II COAST DOWN

* *
 20536100 TRIPCOND TRIPUNIT 1.0 1.0 0
 20536101 510
 20536200 TRIPTIME TRIPDLAY 1.0 -1. 1
 20536201 510
 20536400 ARGUMENT SUM 1.0 0. 0
 20536401 0. 1. TIME 0 -1. CNTRLVAR 362
 20536800 MULTIP MULT 1.0 0. 0
 20536801 CNTRLVAR 361 CNTRLVAR 364
 20536300 TABLE FUNCTION 408.52 408.52 0
 20536301 CNTRLVAR 368 262 *

*

* PRESURIZER UPPER VOLUMES

20540500	CL4340	SUM	1.	0.	1		
20540501	0.	0.790	VOIDF	410010000	0.585	VOIDF	420010000
+		0.6375	VOIDF	420020000	0.6375	VOIDF	420030000
+		0.6375	VOIDF	420040000	0.6375	VOIDF	420050000
+		0.6375	VOIDF	420060000	0.6375	VOIDF	420070000

+ 0.6325 VOIDF 420080000 0.6325 VOIDF 420090000
 + 0.6325 VOIDF 420100000 0.6325 VOIDF 420110000
 *
 4200000 '84-12-12' PIPE * UPPER VOLUME
 * VOLUMES
 4200001 11 *
 * AREA VOL.NO.
 4200101 .008227 1 *
 4200102 .011962 11 *
 * J.AREA JUN.NO.
 4200201 .000000 10 *
 * LENGTH VOL.NO.
 4200301 0.5850 1 *
 4200302 0.6375 07 *
 4200303 0.6325 11 *
 * VOLUME V.NO.
 4200401 .0000000 11 *
 * H.A V.NO.
 4200501 0.0 11 *
 * V.ANGLE V.NO.
 4200601 +90.000 11 *
 * ROUGH. DIAM. V.NO.
 4200801 8.0-5 .0320 1 *
 4200802 8.0-5 .1240 11 *
 * K(FORD) K(REV) J.NO.
 4200901 00.00 00.00 10 *
 * FE V.NO
 4201001 00 11 *
 * CAHS J.NO.
 4201101 0000 10 *
 * CONTROL PRESSURE ENERGY/TEMP QUALITY VOL NO.
 4201201 0 15.754+6 1.5818+6 0. 0. 01 *
 4201202 0 15.750+6 1.5837+6 0. 0. 02 *
 4201203 0 15.747+6 1.5839+6 0. 0. 03 *
 4201204 0 15.743+6 1.5839+6 0. 0. 04 *
 4201205 0 15.739+6 1.5839+6 0. 0. 05 *
 4201206 0 15.735+6 1.5844+6 0. 0. 06 *
 4201207 0 15.731+6 1.5879+6 0. 0. 07 *
 4201208 0 15.731+6 2.4580+6 1. 0. 11 *
 * CONTROL
 4201300 0
 * LIQUID VEL VAPOUR VEL INTERFACE VEL. JUN NO.
 4201301 -5.0480-5 -5.0480-5 0.0 01 *
 4201302 -4.6966-5 -4.6966-5 0.0 02 *
 4201303 -5.9220-5 -5.9220-5 0.0 03 *
 4201304 -7.1478-5 -7.1478-5 0.0 04 *
 4201305 -8.3739-5 -8.3739-5 0.0 05 *
 4201306 -9.6012-5 -9.6012-5 0.0 06 *
 4201307 -9.6012-5 -9.6012-5 0.0 10 *
 *
 4210000 '84-12-12' DELETE
 4220000 '84-12-12' DELETE
 *
 .END

*
 =LOBI-MOD2 TEST A2-81(ISP18) 85/03/19
 100 RESTART TRANSNT * SECOND RESTART WITH PUMP LOCKED ROTOR
 103 22819
 *04 NONE
 201 440. 1.0E-6 .05 00001 100 2000 2000*
 202 600. 1.0E-10 .025 00001 200 2000 2000*
 203 5000. 1.0E-10 .05 00001 100 2000 2000*
 *
 600 512
 *
 *PARAMETERS TO BE PREDICTED
 *
 301 CNTRLVAR 198* * PA38
 302 CNTRLVAR 401* * PA40
 303 CNTRLVAR 199* * WH-POWER
 304 CNTRLVAR 207* * RP71
 305 CNTRLVAR 301* * CM05
 306 CNTRLVAR 801* * QM55
 307 CNTRLVAR 204* * TF11T
 308 CNTRLVAR 203* * TF11B
 309 CNTRLVAR 206* * TF16T
 310 CNTRLVAR 205* * TF16B
 311 CNTRLVAR 351* * TF21T
 312 CNTRLVAR 350* * TF21B
 313 CNTRLVAR 353* * TF26T
 314 CNTRLVAR 352* * TF26B
 315 CNTRLVAR 189* * TF35
 316 CNTRLVAR 201* * DD11
 317 CNTRLVAR 208* * DD14
 318 CNTRLVAR 202* * DD16
 319 CNTRLVAR 354* * DD21
 320 CNTRLVAR 355* * DD24
 321 CNTRLVAR 356* * DD25
 322 CNTRLVAR 357* * DD26
 323 CNTRLVAR 184* * DS35
 324 CNTRLVAR 286* * PD9217
 325 CNTRLVAR 287* * PD1714
 326 CNTRLVAR 317* * PD8227
 327 CNTRLVAR 318* * PD2724
 328 CNTRLVAR 179* * PD3DBT
 329 CNTRLVAR 178* * PD3RTK
 330 CNTRLVAR 177* * PD3RKA
 331 CNTRLVAR 281* * PD90BN
 332 CNTRLVAR 312* * PD80BN
 333 CNTRLVAR 176* * PD3R39
 334 CNTRLVAR 405* * CL4340
 335 CNTRLVAR 175* * TH04
 336 CNTRLVAR 174* * TH07
 337 CNTRLVAR 173* * TH09
 338 CNTRLVAR 172* * TH11
 339 CNTRLVAR 171* * TH13
 340 CNTRLVAR 170* * TH14
 341 CNTRLVAR 544* * PA97S
 342 CNTRLVAR 545* * TF95B
 343 CNTRLVAR 546* * TF95N
 344 CNTRLVAR 547* * TF97T
 345 CNTRLVAR 672* * TF85B
 346 CNTRLVAR 673* * TF85K

347 CNTRLVAR 674* * TF87T
 348 CNTRLVAR 548* * CM93G
 349 CNTRLVAR 675* * CM83G
 350 CNTRLVAR 549* * CM65
 351 CNTRLVAR 676* * CM66
 352 CNTRLVAR 552* * CL93BN
 353 CNTRLVAR 635* * CL83BN
*

*OTHER MINOR EDIT VARIABLES

*

* LIQUID MASS INVENTORY

354 CNTRLVAR 534 * SGI
 355 CNTRLVAR 634 * SGII
 356 CNTRLVAR 190 * WH-POW ALT. DEF.
 357 CNTRLVAR 001 * TOT. HEAT LOSS
 358 CNTRLVAR 031 * VESSEL COLL. LIQUID LEVEL
 359 CNTRLVAR 222 * THTSG1
 360 CNTRLVAR 332 * THTSG2
 361 CNTRLVAR 308 * LEAK MASS LOSS
 362 CNTRLVAR 310 * LEAK HEAT REMOVAL
*63 PMPVEL 250
*64 PMPVEL 350
 365 MFLOWJ 210020000
 366 MFLOWJ 300010000
 367 MFLOWJ 395020000
 368 MFLOWJ 390010000
*

20520700 RP71 TRIPDLAY 1.0 0. 0
 20520701 501

2500000 '20-01-85' BRANCH * PUMP I

* NO.J CONTROL

2500001 2 0 *
* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 2500101 .0033183 0.0 .002370 0.0 17.14 .2105 1.0-4 .01 00*
* CONTROL PRESSURE ENERGY QUALITY
 2500200 0 8.5675+6 1.3119+6 0. *
* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 2501101 240010000 250000000 .0 20. 20. 0000 *
 2502101 250010000 255000000 .0 20. 20. 0000 *
* LIQUID VEL VAPOR VEL. INTERFACE VEL
 2501201 0.92478 0.92478 0.0 *
 2502201 0.92327 0.92327 0.0 *
**
*

3500000 '20-01-85' BRANCH * PUMP II

* NO.J CONTROL

3500001 2 0 *
* AREA LENGTH VOLUME H.A. V.ANGLE ELEVAT. ROUGH DIAM. FE
 3500101 .0033183 0.0 .002370 0.0 17.14 .2105 1.0-4 .01 00*
* CONTROL PRESSURE ENERGY QUALITY
 3500200 0 8.5654+6 1.3114+6 0. *
* CODE(FROM) CODE(TO) AREA K(FORD) K(REV)CAHS COEFFICIENT
 3501101 340010000 350000000 .0 55. 55. 0000 *
 3502101 350010000 355000000 .0 55. 55. 0000 *
* LIQUID VEL VAPOR VEL. INTERFACE VEL
 3501201 1.0324 1.0324 0.0 *
 3502201 1.0244 1.0244 0.0 *
**

*.END

***** DATE: 1985/03/27 *****
=LOBI-MOD2 TEST A2-81(ISP18) POST TEST PREDICTION II
100 RESTART TRANSNT * SECOND RESTART WITH PUMP LOCKED ROTOR
103 55309
*04 NONE
201 440. 1.0E-6 .05 00002 100 2000 2000*
202 600. 1.0E-10 .025 00002 200 2000 2000*
203 5000. 1.0E-10 .025 00002 200 2000 2000*
*
600 512
*
20556800 DT DELETE 0. 0. 0
20556900 DEADBAND DELETE 0. 0. 0
20557000 INTDELT DELETE 0. 0. 0
20557100 STEMPOS TRIPUNIT 1. 1. 0
20557101 501
*
*
20565100 DELTA-T DELETE 0. 0. 0
20565200 DEADBAND DELETE 0. 0. 0
20565300 INTDELT DELETE 0. 0. 0
20565400 STEMPOS TRIPUNIT 1. 1. 0
20565401 501
.END

***** DATE: 1985/04/06 *****
=LOBI-MOD2 TEST A2-81(ISP18) POST TEST PREDICTION II
100 RESTART TRANSNT *
103 274523
*04 NONE
201 440. 1.0E-6 .05 00002 100 2000 2000*
202 600. 1.0E-10 .025 00002 200 2000 2000*
203 5001. 1.0E-10 .025 00002 200 2000 2000*
*
600 502
*
.END